1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 454

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Hampton Inn*	*Date:*	*12/4/24*
		Time:	11:40 AM
Address:	*3000 Mosside Blvd.*	*Method:*	*Grab*
	Monroeville, PA 15146		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/7/24*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/4/24	11:40 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	11:40 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 454

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Hampton Inn*	*Date:*	*12/4/24*
		Time:	11:40 AM
Address:	*3000 Mosside Blvd.*	*Method:*	*Grab*
	Monroeville, PA 15146		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/7/24*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/4/24	11:40 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	11:40 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith