1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 118

Customer

Facility Name: *Hampton Inn*

Address: *2805 Freeport Rd.*
Pittsburgh, PA 15238

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/5/23*
Time: 6:47 AM
Method: *Grab*

Sample Final Analysis

Date: *12/8/23*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	9:55 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	9:55 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/5/23	6:47 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/5/23	6:47 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	6:47 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 118

Customer

Facility Name: *Hampton Inn*

Address: *2805 Freeport Rd.*
Pittsburgh, PA 15238

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/5/23*
Time: 6:47 AM
Method: *Grab*

Sample Final Analysis

Date: *12/8/23*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	9:55 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	9:55 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/5/23	6:47 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/5/23	6:47 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	6:47 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith