1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 440

Customer

Facility Name: *Hampton Inn Washington*

Address: *119 Murtland Ave.*
Washington, PA 15301

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/2/24*
Time: 11:50 AM
Method: *Grab*

Sample Final Analysis

Date: *12/5/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24	11:50 AM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/2/24	11:50 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	11:50 AM	JM	Visual

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 440

Customer

Facility Name: *Hampton Inn Washington*

Address: *119 Murtland Ave.*
Washington, PA 15301

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/2/24*
Time: 11:50 AM
Method: *Grab*

Sample Final Analysis

Date: *12/5/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24	11:50 AM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/2/24	11:50 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	11:50 AM	JM	Visual

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith