1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 216

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Longwood at Oakmont*	*Date:*	*12/3/24*
		Time:	7:50 AM
Address:	*500 Rt. 909*	*Method:*	*Grab*
	Verona, PA 15147		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/6/24*
		Time:	*9:00 AM*
Source Type:	*Spa*	*Analyst:*	*AS*

Laboratory Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	8.0 SU	7.2 - 7.8 SU	12/3/24	7:50 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/3/24	7:50 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	7:50 AM	AH	Visual

Sample comments

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 216

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Longwood at Oakmont*	*Date:*	*12/3/24*
		Time:	7:50 AM
Address:	*500 Rt. 909*	*Method:*	*Grab*
	Verona, PA 15147		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/6/24*
		Time:	*9:00 AM*
Source Type:	*Spa*	*Analyst:*	*AS*

Laboratory Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	8.0 SU	7.2 - 7.8 SU	12/3/24	7:50 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/3/24	7:50 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	7:50 AM	AH	Visual

Sample comments

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)