1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 312

[redacted]

Customer		***Sample Collection***	
Facility Name:	*UPMC Lemieux Sports Complex*	*Date:*	*5/29/24*
		Time:	10:13 AM
Address:	*8000 Cranberry Springs Drive*	*Method:*	*Grab*
	Cranberry Township, PA 16066		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/1/24*
		Time:	*9:00 AM*
Source Type:	*Cold Plunge*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/30/24	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/30/24	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/24	6:15 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/29/24	10:13 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/29/24	10:13 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/24	10:13 AM	AF	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 312

[redacted]

Customer		***Sample Collection***	
Facility Name:	*UPMC Lemieux Sports Complex*	*Date:*	*5/29/24*
		Time:	10:13 AM
Address:	*8000 Cranberry Springs Drive*	*Method:*	*Grab*
	Cranberry Township, PA 16066		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/1/24*
		Time:	*9:00 AM*
Source Type:	*Cold Plunge*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/30/24	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/30/24	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/24	6:15 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/29/24	10:13 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/29/24	10:13 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/24	10:13 AM	AF	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith