1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 312

[redacted]

Customer		***Sample Collection***	
Facility Name:	*UPMC Lemieux Sports Complex*	*Date:*	*12/3/24*
		Time:	9:00 AM
Address:	*8000 Cranberry Springs Drive*	*Method:*	*Grab*
	Cranberry Township, PA 16066		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/6/24*
		Time:	*9:00 AM*
Source Type:	*Cold Plunge*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	190/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	NA	7.2 - 7.8 SU	12/3/24	9:00 AM	JP	DPD
Chlorine:	NA	1.0 - 5.0 mg/l	12/3/24	9:00 AM	JP	DPD
Turbidity:	NA	1 - 2 NTU	12/3/24	9:00 AM	JP	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith