# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**Service**

***Lab# 379***

[redacted]

***Customer***

*Facility Name:* *PPG Paints Arena*

*Address:* *1001 Fifth Ave*
*Pittsburgh, PA 15219*

*Matrix:* *Recreational Water*

*Source Type:* *Spa*

***Sample Collection***

*Date:* *2/5/24*
*Time:* 9:35 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *2/8/24*
*Time:* *9:00 AM*
*Analyst:* *AS*

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 2/6/24 | 9:50 AM | PS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 2/6/24 | 9:50 AM | PS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 2/5/24 | 4:49 PM | DG | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 1/0/00 | 12:00 AM | 0 | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 2/5/24 | 9:35 AM | BH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 2/5/24 | 9:35 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 2/5/24 | 9:35 AM | BH | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

Andre Smith

( When exceeding reporting limit pool or spa is unfit)

# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**Service**

***Lab# 379***

[redacted]

***Customer***

*Facility Name:* *PPG Paints Arena*

*Address:* *1001 Fifth Ave*
*Pittsburgh, PA 15219*

*Matrix:* *Recreational Water*

*Source Type:* *Spa*

***Sample Collection***

*Date:* *2/5/24*
*Time:* 9:35 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *2/8/24*
*Time:* *9:00 AM*
*Analyst:* *AS*

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 2/6/24 | 9:50 AM | PS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 2/6/24 | 9:50 AM | PS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 2/5/24 | 4:49 PM | DG | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 1/0/00 | 12:00 AM | 0 | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 2/5/24 | 9:35 AM | BH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 2/5/24 | 9:35 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 2/5/24 | 9:35 AM | BH | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

Andre Smith

( When exceeding reporting limit pool or spa is unfit)