1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 258

Customer

Facility Name: *Providence Pointe*

Address: *301 Kane Blvd.*
Pittsburgh, PA 15243

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/4/24*
Time: 4:10 PM
Method: *Grab*

Sample Final Analysis

Date: *12/7/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/4/24	4:10 PM	SCL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/4/24	4:10 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	4:10 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 258

Customer

Facility Name: *Providence Pointe*

Address: *301 Kane Blvd.*
Pittsburgh, PA 15243

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/4/24*
Time: 4:10 PM
Method: *Grab*

Sample Final Analysis

Date: *12/7/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/4/24	4:10 PM	SCL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/4/24	4:10 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	4:10 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith