1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 434

Customer		***Sample Collection***	
Facility Name:	*SRU Field House*	*Date:*	*12/5/23*
		Time:	1:10 PM
Address:	*101 Field House Rd.* *Slippery Rock, PA 16057*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/8/23*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	1:10 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/5/23	1:10 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	1:10 PM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 434

Customer		***Sample Collection***	
Facility Name:	*SRU Field House*	*Date:*	*12/5/23*
		Time:	1:10 PM
Address:	*101 Field House Rd.* *Slippery Rock, PA 16057*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/8/23*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	1:10 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/5/23	1:10 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	1:10 PM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith