# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**S-1**

***Lab# 429***

***Customer***

*Facility Name:* *Upper St. Clair High School*

*Address:* *1825 McLaughlin Run Rd.*
*Upper St. Clair, PA 15241*

*Matrix:* *Recreational Water*

*Source Type:* *Lap Pool Shallow*

***Sample Collection***

*Date:* *12/4/24*
*Time:* 3:12 PM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *12/7/24*
*Time:* *9:00 AM*
*Analyst:* *AS*

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 12/5/24 | 9:50 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/5/24 | 9:50 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/4/24 | 6:00 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 12/4/24 | 3:12 PM | SCL | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 12/4/24 | 3:12 PM | SCL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/4/24 | 3:12 PM | SCL | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**S-1**

***Lab# 429***

***Customer***

*Facility Name:* *Upper St. Clair High School*

*Address:* *1825 McLaughlin Run Rd.*
*Upper St. Clair, PA 15241*

*Matrix:* *Recreational Water*

*Source Type:* *Lap Pool Shallow*

***Sample Collection***

*Date:* *12/4/24*
*Time:* 3:12 PM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *12/7/24*
*Time:* *9:00 AM*
*Analyst:* *AS*

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 12/5/24 | 9:50 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/5/24 | 9:50 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/4/24 | 6:00 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 12/4/24 | 3:12 PM | SCL | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 12/4/24 | 3:12 PM | SCL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/4/24 | 3:12 PM | SCL | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

Andre Smith