1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 214

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Liberty Hills*	*Date:*	*12/2/24*
		Time:	1:07 PM
Address:	*100 Liberty Lane* *Freedom, PA 15042*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/5/24*
		Time:	*9:00 AM*
Source Type:	*Spa*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	275/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	12/2/24	1:07 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	1:07 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	1:07 PM	AH	Visual

Sample comments

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 214

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Liberty Hills*	*Date:*	*12/2/24*
		Time:	1:07 PM
Address:	*100 Liberty Lane* *Freedom, PA 15042*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/5/24*
		Time:	*9:00 AM*
Source Type:	*Spa*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	275/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	12/2/24	1:07 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	1:07 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	1:07 PM	AH	Visual

Sample comments

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)