# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**N-2**

***Lab# 211***

**[redacted]**

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *L.A. Fitness North Hills* | *Date:* | *12/6/23* |
| | | *Time:* | 8:45 AM |
| *Address:* | *8700 Duncan Ave.*<br>*Pittsburgh, PA 15237* | *Method:* | *Grab* |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *12/8/23* |
| | | *Time:* | *1:00 PM* |
| *Source Type:* | *Spa* | *Analyst:* | *PS* |

| **Laboratory Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 12/6/23 | 3:22 PM | DG | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/6/23 | 3:22 PM | DG | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/6/23 | 2:40 PM | DG | SM 9215B |

| **Additional Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 12/6/23 | 3:22 PM | DG | SM 9230C |

| **Field Analysis** | **Results** | **Reporting limit** | **Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 12/6/23 | 8:45 AM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 12/6/23 | 8:45 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/6/23 | 8:45 AM | VH | Visual |

**Sample comments**

Andrea Smith

( When exceeding reporting limit pool or spa is unfit)

# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**N-2**

***Lab# 211***

**[redacted]**

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *L.A. Fitness North Hills* | *Date:* | *12/6/23* |
| | | *Time:* | 8:45 AM |
| *Address:* | *8700 Duncan Ave.*<br>*Pittsburgh, PA 15237* | *Method:* | *Grab* |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *12/8/23* |
| | | *Time:* | *1:00 PM* |
| *Source Type:* | *Spa* | *Analyst:* | *PS* |

| **Laboratory Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 12/6/23 | 3:22 PM | DG | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/6/23 | 3:22 PM | DG | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/6/23 | 2:40 PM | DG | SM 9215B |

| **Additional Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 12/6/23 | 3:22 PM | DG | SM 9230C |

| **Field Analysis** | **Results** | **Reporting limit** | **Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 12/6/23 | 8:45 AM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 12/6/23 | 8:45 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/6/23 | 8:45 AM | VH | Visual |

**Sample comments**

Andrea Smith

( When exceeding reporting limit pool or spa is unfit)