1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 010

Customer

Facility Name: *Arsenal Middle*

Address: *220 40th St.*
Pittsburgh, PA 15201

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *12/3/24*
Time: 8:30 AM
Method: *Grab*

Sample Final Analysis

Date: *12/6/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	A	12/3/24	8:30 AM	JM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	A	12/3/24	8:30 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/3/24	8:30 AM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 010

Customer

Facility Name: *Arsenal Middle*

Address: *220 40th St.*
Pittsburgh, PA 15201

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *12/3/24*
Time: 8:30 AM
Method: *Grab*

Sample Final Analysis

Date: *12/6/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	A	12/3/24	8:30 AM	JM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	A	12/3/24	8:30 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/3/24	8:30 AM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)