1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 026

Customer

Facility Name: *Brashear High School*

Address: *590 Crane Ave*
Pittsburgh, PA 15216

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *12/4/24*
Time: 9:08 AM
Method: *Grab*

Sample Final Analysis

Date: *12/6/24*
Time: *3:30 PM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	A	12/4/24	9:08 AM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	A	12/4/24	9:08 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/4/24	9:08 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 026

Customer

Facility Name: *Brashear High School*

Address: *590 Crane Ave*
Pittsburgh, PA 15216

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *12/4/24*
Time: 9:08 AM
Method: *Grab*

Sample Final Analysis

Date: *12/6/24*
Time: *3:30 PM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	A	12/4/24	9:08 AM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	A	12/4/24	9:08 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/4/24	9:08 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)