# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**P.P.S.**

***Lab# 058***

***Customer***

*Facility Name:* *Colfax Elementary*

*Address:* *2332 Beechwood Blvd.*
*Pittsburgh, PA 15217*

*Matrix:* *Recreational Water*

*Source Type:* *Pool Deep*

***Sample Collection***

*Date:* *12/3/24*
*Time:* 9:39 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *12/6/24*
*Time:* *9:00 AM*
*Analyst:* *AS*

| Laboratory Analysis | Results | Reporting limit | Rating | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | A | 12/4/24 | 11:00 AM | PS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | A | 12/4/24 | 11:00 AM | PS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | A | 12/3/24 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Rating | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|---|
| pH: | 7.8 SU | 7.2 - 7.8 SU | C | 12/3/24 | 9:39 AM | SCL | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | B | 12/3/24 | 9:39 AM | SCL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | A | 12/3/24 | 9:39 AM | SCL | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

Andre Smith

( When exceeding reporting limit pool or spa is unfit)

# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**P.P.S.**

***Lab# 058***

***Customer***

*Facility Name:* *Colfax Elementary*

*Address:* *2332 Beechwood Blvd.*
*Pittsburgh, PA 15217*

*Matrix:* *Recreational Water*

*Source Type:* *Pool Deep*

***Sample Collection***

*Date:* *12/3/24*
*Time:* 9:39 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *12/6/24*
*Time:* *9:00 AM*
*Analyst:* *AS*

| Laboratory Analysis | Results | Reporting limit | Rating | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | A | 12/4/24 | 11:00 AM | PS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | A | 12/4/24 | 11:00 AM | PS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | A | 12/3/24 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Rating | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|---|
| pH: | 7.8 SU | 7.2 - 7.8 SU | C | 12/3/24 | 9:39 AM | SCL | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | B | 12/3/24 | 9:39 AM | SCL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | A | 12/3/24 | 9:39 AM | SCL | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

Andre Smith

( When exceeding reporting limit pool or spa is unfit)