1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 111

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Greenfield Elementary*	*Date:*	*1/0/00*
		Time:	12:00 AM
Address:	*1 Alger St.*	*Method:*	*Grab*
	Pittsburgh, PA 15207		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*1/0/00*
		Time:	*12:00 AM*
Source Type:	*Deep End*	*Analyst:*	*1/0/00*

Laboratory Analysis	Results	Reporting limit	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	A	1/0/00	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	1/0/00	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	A	1/0/00	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	E	1/0/00	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	E	1/0/00	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	A	1/0/00	12:00 AM	0	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 111

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Greenfield Elementary*	*Date:*	*1/0/00*
		Time:	12:00 AM
Address:	*1 Alger St.*	*Method:*	*Grab*
	Pittsburgh, PA 15207		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*1/0/00*
		Time:	*12:00 AM*
Source Type:	*Deep End*	*Analyst:*	*1/0/00*

Laboratory Analysis	Results	Reporting limit	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	A	1/0/00	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	1/0/00	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	A	1/0/00	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	E	1/0/00	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	E	1/0/00	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	A	1/0/00	12:00 AM	0	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)