

Lab# 438

**Customer**

Facility Name: Atria Cranberry Woods

Address: 3020 Fairport Lane  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99 12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99 12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99 12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99 12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99 12:00 AM	0	Visual

**Sample comments**


---

 Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N - 1**

**Lab# 409**

**Customer**

Facility Name: Best Western Cranberry  
Address: 5001 Cranberry Springs Dr.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N - 1**

**Lab# 062**

**Customer**

**Facility Name:** Comfort Inn - Butler  
**Address:** 1 Comfort Ln.  
Butler, PA 16001

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 072

**Customer**

Facility Name: Courtyard by Marriott  
Address: 150 Cranberry Woods Dr.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N - 1**

**Lab# 453**

**Customer**

Facility Name: Fairfield Inn Butler

Address: 200 Fairfield Ln  
Butler, PA 16001

Matrix: Fairfield Inn Butler

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 389

**Customer**

Facility Name: Fairfield Inn & Suites  
Address: 1000 University Parkway  
Slippery Rock, PA 16057

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Fairfield Inn & Suites  
 Address: 1000 University Parkway  
 Slippery Rock, PA 16057

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/30/99  
 Time: 12:00 AM  
 Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
 Time: 12:00 AM  
 Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9230C
---------------------	----------	----------	----------	----------	---	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

N - 1

Lab# 436

**Customer**

Facility Name: Grove City College  
Address: 100 Campus Dr.  
Grove City, PA 16127

Matrix: Recreational Water

Source Type: Comp Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99 12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99 12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99 12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99 12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99 12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



N - 1

Lab# 437

**Customer**

Facility Name: Grove City College  
Address: 100 Campus Dr.  
Grove City, PA 16127

Matrix: Recreational Water

Source Type: Rec Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 126

**Customer**

Facility Name: Hampton Inn - Butler

Address: 610 Butler Crossing  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 421

**Customer**

Facility Name: Hampton Inn and Suites Mars

Address: 10015 Pendelton Way  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 153

**Customer**

Facility Name: Hilton Garden Inn  
Address: 2000 Garden View  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 154

**Customer**

Facility Name: Hilton Garden Inn  
Address: 2000 Garden View  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/30/99 12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99 12:00 AM	0	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9230C
---------------------	----------	----------	-------------------	---	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	0.0 SU	7.2 - 7.8 SU	12/30/99 12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99 12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99 12:00 AM	0	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N - 1**

**Lab# 164**

**Customer**

Facility Name: Holiday Inn Express - Butler

Address: 203 North Duffy Rd  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N - 1**

**Lab# 167**

**Customer**

**Facility Name:** Home 2 Suites  
**Address:** 1401 Cranberry Woods Dr.  
Cranberry, PA 16066

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

**Matrix:** Recreational Water

**Source Type:** Pool

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 217

**Customer**

Facility Name: Marriott  
Address: 100 Cranberry Woods Dr.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



N - 1

Lab# 248

**Customer**

Facility Name: Passavant Retirement

Address: 401 S Main St  
Zelienople, PA 16063

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 372

**Customer**

Facility Name: Pine Richland H.S.

Address: 700 Warrendale Rd.  
Gibsonia, PA 15044

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N - 1**

**Lab# 373**

**Customer**

Facility Name: Pine Richland H.S.  
Address: 700 Warrendale Rd.  
Gibsonia, PA 15044

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 271

**Customer**

Facility Name: Seneca Valley H.S.  
Address: 122 Seneca School Rd.  
Harmony, PA 16037

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

Matrix: Recreational Water

Source Type: Pool

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 408

**Customer**

Facility Name: Springhill Suites  
Address: 125 E. Jefferson St.  
Butler, PA 16001

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: SRU Field House

Address: 101 Field House Rd.  
Slippery Rock, PA 16057

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99 12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99 12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99 12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99 12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99 12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: SRU ARC

Address: 101 Stadium Dr.  
Slippery Rock, PA 16057

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99 12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99 12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99 12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99 12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99 12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 449

---

**Customer**

Facility Name: Super 8  
Address: 2001 Leesburg-Grove City Rd  
Mercer, PA 16137

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



N - 1

Lab# 369

**Customer**

Facility Name: Towne Place Suites

Address: Westside Square Dr.  
Mercer, PA 16137

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 388

**Customer**

Facility Name: Towne Place Suites  
Address: 2020 Cool Springs Dr.  
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N - 1

Lab# 2635

**Customer**

Facility Name: Village Cranberry Woods Apt.

Address: 5001 Pendleton Way  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N - 1**

**Lab# 353**

**Customer**

Facility Name: YMCA - Butler  
Address: 339 North Washington St.  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N - 1**

**Lab# 354**

**Customer**

Facility Name: YMCA - Butler  
Address: 339 North Washington St.  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Small Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: YMCA - Butler

Address: 339 North Washington St.  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/30/99 12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99 12:00 AM	0	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9230C
---------------------	----------	----------	-------------------	---	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	0.0 SU	7.2 - 7.8 SU	12/30/99 12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99 12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99 12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

## Recreational Water

## Collection

Lab ID #	Lab customer	Address	City, State, Zip	Source Ty	Date	Time	Ph	Chl	Turb	Collect
N - 1								Field Results		
438	Atria Cranberry Wood	3020 Fairport Lane	Cranberry, PA 16066	Pool						
409	Best Western Cranbei	5001 Cranberry Spring	Cranberry, PA 16066	Pool						
062	Comfort Inn - Butler	1 Comfort Ln.	Butler, PA 16001	Pool						
072	Courtyard by Marriott	150 Cranberry Woods	Cranberry, PA 16066	Pool						
453	Fairfield Inn Butler	200 Fairfield Ln	Butler, PA 16001	Pool						
389	Fairfield Inn & Suites	1000 University Parkw	Slippery Rock, PA 16051	Pool						
390	Fairfield Inn & Suites	1000 University Parkw	Slippery Rock, PA 16051	Spa						
436	Grove City College	100 Campus Dr.	Grove City, PA 16127	Comp Pool						
437	Grove City College	100 Campus Dr.	Grove City, PA 16127	Rec Pool						
126	Hampton Inn - Butler	610 Butler Crossing	Butler, PA 16001	Pool						
421	Hampton Inn and Suit	10015 Pendelton Way	Cranberry, PA 16066	Pool						
153	Hilton Garden Inn	2000 Garden View	Cranberry, PA 16066	Pool						
154	Hilton Garden Inn	2000 Garden View	Cranberry, PA 16066	Spa						
164	Holiday Inn Express -	203 North Duffy Rd	Butler, PA 16001	Pool						
167	Home 2 Suites	1401 Cranberry Woods	Cranberry, PA 16066	Pool						
217	Marriott	100 Cranberry Woods	Cranberry, PA 16066	Pool						
248	Passavant Retirement	401 S Main St	Zelienople, PA 16063	Pool						
372	Pine Richland H.S.	700 Warrendale Rd.	Gibsonia, PA 15044	Deep End						
373	Pine Richland H.S.	700 Warrendale Rd.	Gibsonia, PA 15044	Shallow End						
271	Seneca Valley H.S.	122 Seneca School Rd	Harmony, PA 16037	Pool						
408	Springhill Suites	125 E. Jefferson St.	Butler, PA 16001	Pool						
434	SRU Field House	101 Field House Rd.	Slippery Rock, PA 16051	Pool						
435	SRU ARC	101 Stadium Dr.	Slippery Rock, PA 16051	Pool						
449	Super 8	2001 Leesburg-Grove	Mercer, PA 16137	Pool						
369	Towne Place Suites	Westside Square Dr.	Mercer, PA 16137	Pool						
388	Towne Place Suites	2020 Cool Springs Dr.	Cranberry Township, PA	Pool						
2635	Village Cranberry Wox	5001 Pendleton Way	Cranberry, PA 16066	Spa						
353	YMCA - Butler	339 North Washington	Butler, PA 16001	Pool						
354	YMCA - Butler	339 North Washington	Butler, PA 16001	Small Pool						
355	YMCA - Butler	339 North Washington	Butler, PA 16001	Spa						





Lab ID #	Lab customer	Address	City, State, Zip	Source Ty	Final Analysis Date/Time	Escherichia Coli	Coliforms	HPC	Fecal Stepto	Analyst
N - 1						Laboratory Results				
438	Atria Cranberry Woods	3020 Fairport Lane	Cranberry, PA 16066	Pool						
409	Best Western Cranberry	5001 Cranberry Springs Dr.	Cranberry, PA 16066	Pool						
062	Comfort Inn - Butler	1 Comfort Ln.	Butler, PA 16001	Pool						
072	Courtyard by Marriott	150 Cranberry Woods Dr.	Cranberry, PA 16066	Pool						
453	Fairfield Inn Butler	200 Fairfield Ln	Butler, PA 16001	Pool						
834	Courtyard by Marriott	151 Cranberry Woods Dr.	Cranberry, PA 16066	Pool						
1215	Fairfield Inn Butler	201 Fairfield Ln	Butler, PA 16002	Pool						
436	Grove City College	100 Campus Dr.	Grove City, PA 16122	Comp Pool						
437	Grove City College	100 Campus Dr.	Grove City, PA 16122	Rec Pool						
126	Hampton Inn - Butler	610 Butler Crossing	Butler, PA 16001	Pool						
421	Hampton Inn and Suites	10015 Pendleton Way	Cranberry, PA 16066	Pool						
153	Hilton Garden Inn	2000 Garden View	Cranberry, PA 16066	Pool						
154	Hilton Garden Inn	2000 Garden View	Cranberry, PA 16066	Spa						
164	Holiday Inn Express - Bu	203 North Duffy Rd	Butler, PA 16001	Pool						
167	Home 2 Suites	1401 Cranberry Woods Dr.	Cranberry, PA 16066	Pool						
217	Marriott	100 Cranberry Woods Dr.	Cranberry, PA 16066	Pool						
248	Passavant Retirement	401 S Main St	Zelienople, PA 16066	Pool						
372	Pine Richland H.S.	700 Warrendale Rd.	Gibsonia, PA 15044	Deep End						
373	Pine Richland H.S.	700 Warrendale Rd.	Gibsonia, PA 15044	Shallow End						
271	Seneca Valley H.S.	122 Seneca School Rd.	Harmony, PA 16037	Pool						
408	Springhill Suites	125 E. Jefferson St.	Butler, PA 16001	Pool						
434	SRU Field House	101 Field House Rd.	Slippery Rock, PA 1	Pool						
435	SRU ARC	101 Stadium Dr.	Slippery Rock, PA 1	Pool						
449	Super 8	2001 Leesburg-Grove City Rd	Mercer, PA 16137	Pool						
369	Towne Place Suites	Westside Square Dr.	Mercer, PA 16137	Pool						
388	Towne Place Suites	2020 Cool Springs Dr.	Cranberry Township	Pool						
2635	Village Cranberry Woods	5001 Pendleton Way	Cranberry, PA 16066	Spa						
353	YMCA - Butler	339 North Washington St.	Butler, PA 16001	Pool						
354	YMCA - Butler	339 North Washington St.	Butler, PA 16001	Small Pool						
355	YMCA - Butler	339 North Washington St.	Butler, PA 16001	Spa						

**Customer**

Facility Name: Atria Senior Living  
 Address: 8870 Duncan Ave.  
 Pittsburgh, PA 15237

**Sample Collection**

Date: 12/6/23  
 Time: 8:30 AM  
 Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 12/8/23  
 Time: 1:00 PM  
 Analyst: PS

Source Type: Pool

Laboratory Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/6/23	8:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	8:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	8:30 AM	VH	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 013**

**Customer**

Facility Name: Bairel Center  
Address: 2565 Nicholson Rd.  
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 12/6/23  
Time: 10:45 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	10:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	10:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	10:45 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 014**

**Customer**

Facility Name: Bairel Center  
Address: 2565 Nicholson Rd.  
Sewickley, PA 15143

Matrix: Recreational Water  
Source Type: Pool Shallow

**Sample Collection**

Date: 12/6/23  
Time: 10:45 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	10:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	10:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	10:45 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 464**

**Customer**

Facility Name: Big Blue Swim School

Address: 20412 US Rt19  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/6/23

Time: 12:00 PM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	12:00 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	12:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	12:00 PM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 033**

**Customer**

Facility Name: Candlewood Suites  
Address: 20036 Oak Tree Place  
Cranberry, PA 16066

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 12/6/23  
Time: 11:15 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	11:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	11:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	11:15 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Divine Providence

Address: 9000 Babcock Blvd  
Allision Park, PA 15101

**Sample Collection**

Date: 12/6/23  
Time: 9:30 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Matrix: Recreational Water

Source Type: Pool

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	9:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	9:30 AM	VH	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Doubletree Cranberry  
 Address: 910 Sheraton Dr  
 Mars, PA 16046

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/6/23  
 Time: 11:30 AM  
 Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
 Time: 1:00 PM  
 Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/6/23	11:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/6/23	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	11:30 AM	VH	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**Customer**

Facility Name: Extended Stay  
 Address: 136 Emeryville Dr.  
 Cranberry, PA 16066

Matrix: Extended Stay

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
 Time: 12:00 AM  
 Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
 Time: 12:00 AM  
 Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: *Fairfield Inn & Suites -North*

Address: *901 Providence Blvd.  
Pittsburgh, PA 15237*

**Sample Collection**

Date: *12/6/23*

Time: *9:15 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *12/8/23*

Time: *1:00 PM*

Analyst: *PS*

Matrix: *Recreational Water*

Source Type: *Pool*

<b>Laboratory Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	12/6/23	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	9:15 AM	VH	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Gold Fish Swim Club

Address: 160 Lake Dr.  
Wexford, PA 15090

**Sample Collection**

Date: 12/6/23  
Time: 10:00 AM  
Method: Grab

**Sample Final Analysis**

Matrix: Recreational Water

Source Type: Pool

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	10:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	10:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	10:00 AM	VH	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 115**

**Customer**

Facility Name: Hampton Inn  
Address: 2622 Wexford-Bayne Rd.  
Wexford, PA 15090

**Sample Collection**

Date: 12/6/23  
Time: 11:00 AM  
Method: Grab

**Sample Final Analysis**

Matrix: Recreational Water  
Source Type: Pool

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/6/23	11:00 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/6/23	11:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	11:00 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Hampton School District

Address: 2929 McCully Rd.  
Allison Park, PA 15101

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 12/6/23

Time: 1:00 PM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	1:00 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	1:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	1:00 PM	VH	Visual

**Sample comments**


---

 Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 135**

**Customer**

Facility Name: Hampton School District

Address: 2929 McCully Rd.  
Allison Park, PA 15101

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/6/23

Time: 1:00 PM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	1:00 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	1:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	1:00 PM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 168**

**Customer**

Facility Name: Home 2 Suites  
Address: 8630 Duncan Ave.  
Pittsburgh, PA 15237

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 12/6/23  
Time: 9:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	9:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	9:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	9:00 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 210**

**Customer**

Facility Name: L.A. Fitness North Hills

Address: 8700 Duncan Ave.  
Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/6/23

Time: 8:45 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	8:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	8:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	8:45 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**N-2**

**Lab# 211**

**Customer**

Facility Name: L.A. Fitness North Hills  
Address: 8700 Duncan Ave.  
Pittsburgh, PA 15237

Matrix: Recreational Water  
Source Type: Spa

**Sample Collection**

Date: 12/6/23  
Time: 8:45 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/6/23 3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23 3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23 2:40 PM	DG	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/6/23 3:22 PM	DG	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	12/6/23 8:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23 8:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23 8:45 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 122**

**Customer**

Facility Name: McKnight Hotel  
Address: 4575 McKnight Rd.  
Pittsburgh, PA 15237

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 12/6/23  
Time: 7:45 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	7:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/6/23	7:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	7:45 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 123**

**Customer**

Facility Name: McKnight Hotel  
Address: 4575 McKnight Rd.  
Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/30/99 12:00 AM	0	SM 9222G
-------------------	--------	--------	-------------------	---	----------

Total coliforms:	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9222B
------------------	----------	----------	-------------------	---	----------

Standard plate count:	0/ml	200/ml	12/30/99 12:00 AM	0	SM 9215B
-----------------------	------	--------	-------------------	---	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/30/99 12:00 AM	0	SM 9230C
---------------------	----------	----------	-------------------	---	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	0.0 SU	7.2 - 7.8 SU	12/30/99 12:00 AM	0	DPD
-----	--------	--------------	-------------------	---	-----

Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99 12:00 AM	0	DPD
-----------	----------	----------------	-------------------	---	-----

Turbidity:	0 NTU	1 - 2 NTU	12/30/99 12:00 AM	0	Visual
------------	-------	-----------	-------------------	---	--------

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 234**

**Customer**

Facility Name: North Allegheny High School

Address: 10375 Perry Hwy.  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 12/6/23

Time: 9:45 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	9:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	9:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	9:45 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 235**

**Customer**

Facility Name: North Allegheny High School

Address: 10375 Perry Hwy.  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/6/23

Time: 9:45 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	9:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	9:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	9:45 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: North Hills High School

Address: 53 Rochester Rd.  
Pittsburgh, PA 15229

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 12/6/23

Time: 8:15 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	8:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	8:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	8:15 AM	VH	Visual

**Sample comments**


---

 Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 237**

**Customer**

Facility Name: North Hills High School

Address: 53 Rochester Rd.  
Pittsburgh, PA 15229

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/6/23

Time: 8:15 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	8:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	8:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	8:15 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Northgate High School

Address: 589 Union Ave  
Pittsburgh, PA 15202

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 12/6/23

Time: 7:30 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	7:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	7:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	7:30 AM	VH	Visual

**Sample comments**


---

 Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**N-2****Lab# 239****Customer**

Facility Name: Northgate High School

Address: 589 Union Ave  
Pittsburgh, PA 15202

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/6/23

Time: 7:30 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	7:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	7:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	7:30 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2****Lab# 455****Customer**

**Facility Name:** Novacare McKnight  
**Address:** 4721 McKnight Rd.  
Pittsburgh, PA 15237

**Matrix:** Recreational Water  
**Source Type:** Therapy Pool

**Sample Collection**

**Date:** 12/6/23  
**Time:** 8:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/8/23  
**Time:** 1:00 PM  
**Analyst:** PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	8:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	8:00 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 245**

**Customer**

Facility Name: Oxford Athletic Club

Address: 100 Village Club Dr.  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 12/6/23

Time: 10:15 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/6/23	10:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	10:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	10:15 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 246**

**Customer**

Facility Name: Oxford Athletic Club

Address: 100 Village Club Dr.  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/6/23

Time: 10:15 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/6/23	10:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	10:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	10:15 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Oxford Athletic Club

Address: 100 Village Club Dr.  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/6/23

Time: 10:15 AM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 12:00 AM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/6/23 3:22 PM	DG	SM 9222G
-------------------	--------	--------	-----------------	----	----------

Total coliforms:	0/100mls	2/100mls	12/6/23 3:22 PM	DG	SM 9222B
------------------	----------	----------	-----------------	----	----------

Standard plate count:	0/ml	200/ml	12/6/23 2:40 PM	DG	SM 9215B
-----------------------	------	--------	-----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/6/23 3:22 PM	DG	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	12/6/23 10:15 AM	VH	DPD
-----	--------	--------------	------------------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23 10:15 AM	VH	DPD
-----------	----------	----------------	------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	12/6/23 10:15 AM	VH	Visual
------------	-------	-----------	------------------	----	--------

**Sample comments**


---

 Andre Smith, Lead Supervisor

**N-2**

**Lab# 386**

**Customer**

Facility Name: Residence Inn Cranberry

Address: 1308 Freedom RDd.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/6/23

Time: 12:30 PM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/6/23	12:30 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/6/23	12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	12:30 PM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 387**

**Customer**

Facility Name: Residence Inn Cranberry

Address: 1308 Freedom RDd.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/6/23

Time: 12:30 PM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/6/23 3:22 PM	DG	SM 9222G
-------------------	--------	--------	-----------------	----	----------

Total coliforms:	0/100mls	2/100mls	12/6/23 3:22 PM	DG	SM 9222B
------------------	----------	----------	-----------------	----	----------

Standard plate count:	0/ml	200/ml	12/6/23 2:40 PM	DG	SM 9215B
-----------------------	------	--------	-----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/6/23 3:22 PM	DG	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.0 SU	7.2 - 7.8 SU	12/6/23 12:30 PM	VH	DPD
-----	--------	--------------	------------------	----	-----

Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	12/6/23 12:30 PM	VH	DPD
-----------	-----------	----------------	------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	12/6/23 12:30 PM	VH	Visual
------------	-------	-----------	------------------	----	--------

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 277**

**Customer**

Facility Name: Shaler Areas Middle School

Address: 705 Scott Ave.  
Glenshaw, PA 15116

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 12/6/23

Time: 1:15 PM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	1:15 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	1:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	1:15 PM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**N-2**

**Lab# 278**

**Customer**

Facility Name: Shaler Area Middle School

Address: 705 Scott Ave.  
Glenshaw, PA 15116

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/6/23

Time: 1:15 PM

Method: Grab

**Sample Final Analysis**

Date: 12/8/23

Time: 1:00 PM

Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	1:15 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	1:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	1:15 PM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 399**

**Customer**

Facility Name: Stay Bridge Suites  
Address: 915 Brush Creek Rd.  
Warrendale, PA 15086

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/6/23  
Time: 11:45 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	12/6/23	11:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/6/23	11:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	11:45 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 119**

**Customer**

Facility Name: Wingate  
Address: 210 Executive Dr.  
Cranberry, PA 16066

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 12/6/23  
Time: 12:15 PM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	50/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	12:15 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/6/23	12:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	12:15 PM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Wingate  
 Address: 210 Executive Dr.  
 Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/6/23  
 Time: 12:15 PM  
 Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
 Time: 1:00 PM  
 Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG SM 9222G
-------------------	--------	--------	---------	---------	-------------

Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG SM 9222B
------------------	----------	----------	---------	---------	-------------

Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG SM 9215B
-----------------------	------	--------	---------	---------	-------------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/6/23	3:22 PM	DG SM 9230C
---------------------	----------	----------	---------	---------	-------------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	12/6/23	12:15 PM	VH DPD
-----	--------	--------------	---------	----------	--------

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	12:15 PM	VH DPD
-----------	----------	----------------	---------	----------	--------

Turbidity:	1 NTU	1 - 2 NTU	12/6/23	12:15 PM	VH Visual
------------	-------	-----------	---------	----------	-----------

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-2**

**Lab# 346**

**Customer**

Facility Name: Woodlands Camp  
Address: 134 Shenot Road  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/6/23  
Time: 10:30 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 1:00 PM  
Analyst: PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/6/23	10:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	10:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	10:30 AM	VH	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

## Recreational Water

## Collection

Lab ID #	Lab customer	Address	City, State, Zip	Source Type	Date	Time	Ph	Chl	Turb	Collec
N-2								Field Results		
433	Atria Senior Living	8870 Duncan Ave.	Pittsburgh, PA 15237	Pool	12/6/23	8:30 AM	7.6 /SU	3.0 mg/l	1 NTU	VH
013	Bairel Center	2565 Nicholson Rd.	Sewickley, PA 15143	Pool Deep	12/6/23	10:45 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
014	Bairel Center	2565 Nicholson Rd.	Sewickley, PA 15143	Pool Shallo	12/6/23	10:45 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
464	Big Blue Swim Sch	20412 US Rt19	Cranberry, PA 16066	Pool	12/6/23	12:00 PM	7.4 /SU	3.0 mg/l	1 NTU	VH
033	Candlewood Suites	20036 Oak Tree Pla	Cranberry, PA 16066	Pool	12/6/23	11:15 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
088	Divine Providence	9000 Babcock Blvd	Allison Park, PA 151	Pool	12/6/23	9:30 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
452	Doubletree Cranber	910 Sheraton Dr	Mars, PA 16046	Pool	12/6/23	11:30 AM	7.0 /SU	5.0 mg/l	1 NTU	VH
180	Extended Stay	136 Emeryville Dr.	Cranberry, PA 16066	Pool						
101	Fairfield Inn & Suite	901 Providence Blvc	Pittsburgh, PA 15237	Pool	12/6/23	9:15 AM	7.6 /SU	3.0 mg/l	1 NTU	VH
110	Gold Fish Swim Clu	160 Lake Dr.	Wexford, PA 15090	Pool	12/6/23	10:00 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
115	Hampton Inn	2622 Wexford-Bayn	Wexford, PA 15090	Pool	12/6/23	11:00 AM	7.6 /SU	5.0 mg/l	1 NTU	VH
134	Hampton School Di	2929 McCully Rd.	Allison Park, PA 1510	Pool Deep	12/6/23	1:00 PM	7.4 /SU	3.0 mg/l	1 NTU	VH
135	Hampton School Di	2929 McCully Rd.	Allison Park, PA 1510	Pool Shallo	12/6/23	1:00 PM	7.4 /SU	3.0 mg/l	1 NTU	VH
168	Home 2 Suites	8630 Duncan Ave.	Pittsburgh, PA 15237	Pool	12/6/23	9:00 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
210	L.A. Fitness North	18700 Duncan Ave.	Pittsburgh, PA 15237	Pool	12/6/23	8:45 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
211	L.A. Fitness North	18700 Duncan Ave.	Pittsburgh, PA 15237	Spa	12/6/23	8:45 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
122	McKnight Hotel	4575 McKnight Rd.	Pittsburgh, PA 15237	Pool	12/6/23	7:45 AM	7.4 /SU	5.0 mg/l	1 NTU	VH
123	McKnight Hotel	4575 McKnight Rd.	Pittsburgh, PA 15237	Spa						
234	North Allegheny Hi	10375 Perry Hwy.	Wexford, PA 15090	Pool Deep	12/6/23	9:45 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
235	North Allegheny Hi	10375 Perry Hwy.	Wexford, PA 15090	Pool Shallo	12/6/23	9:45 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
236	North Hills High Sch	53 Rochester Rd.	Pittsburgh, PA 15229	Pool Deep	12/6/23	8:15 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
237	North Hills High Sch	53 Rochester Rd.	Pittsburgh, PA 15229	Pool Shallo	12/6/23	8:15 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
238	Northgate High Sch	589 Union Ave	Pittsburgh, PA 15202	Pool Deep	12/6/23	7:30 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
239	Northgate High Sch	589 Union Ave	Pittsburgh, PA 15202	Pool Shallo	12/6/23	7:30 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
455	Novacare McKnight	4721 McKnight Rd.	Pittsburgh, PA 15237	Therapy Po	12/6/23	8:00 AM	7.4 /SU	3.0 mg/l	1 NTU	VH
245	Oxford Athletic Clu	100 Village Club Dr.	Wexford, PA 15090	Pool Deep	12/6/23	10:15 AM	7.6 /SU	3.0 mg/l	1 NTU	VH
246	Oxford Athletic Clu	100 Village Club Dr.	Wexford, PA 15090	Pool Shallo	12/6/23	10:15 AM	7.6 /SU	3.0 mg/l	1 NTU	VH
247	Oxford Athletic Clu	100 Village Club Dr.	Wexford, PA 15090	Spa	12/6/23	10:15 AM	7.6 /SU	3.0 mg/l	1 NTU	VH
386	Residence Inn Crar	1308 Freedom RDd.	Cranberry, PA 16066	Pool	12/6/23	12:30 PM	7.6 /SU	5.0 mg/l	1 NTU	VH
387	Residence Inn Crar	1308 Freedom RDd.	Cranberry, PA 16066	Spa	12/6/23	12:30 PM	7.0 /SU	10.0 mg/l	1 NTU	VH
277	Shaler Areas Middl	705 Scott Ave.	Glenshaw, PA 15116	Pool Deep	12/6/23	1:15 PM	7.4 /SU	3.0 mg/l	1 NTU	VH
278	Shaler Area Middle	705 Scott Ave.	Glenshaw, PA 15116	Pool Shallo	12/6/23	1:15 PM	7.4 /SU	3.0 mg/l	1 NTU	VH
399	Stay Bridge Suites	915 Brush Creek Rd	Warrendale, PA 1508	Pool	12/6/23	11:45 AM	8.0 /SU	5.0 mg/l	1 NTU	VH
119	Wingate	210 Executive Dr.	Cranberry, PA 16066	Pool	12/6/23	12:15 PM	7.4 /SU	5.0 mg/l	1 NTU	VH
120	Wingate	210 Executive Dr.	Cranberry, PA 16066	Spa	12/6/23	12:15 PM	7.6 /SU	3.0 mg/l	1 NTU	VH
346	Woodlands Camp	134 Shenot Road	Wexford, PA 15090	Pool	12/6/23	10:30 AM	7.6 /SU	3.0 mg/l	1 NTU	VH

		Fecal Coliform Incubation Start				Total Coliform Incubation Start				HPC Incubation Start			Fecal Streptococcus Incubation Start		
Lab ID #	Lab customer	Source	T	Date	Time	Analyst	Date	Time	Analyst	Date	Time	Analyst	Date	Time	Analyst
N-2															
433	Atria Senior Living	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
013	Bairel Center	Pool	Der	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
014	Bairel Center	Pool	Sh	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
464	Big Blue Swim Sch	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
033	Candlewood Suites	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
088	Divine Providence	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
452	Doubletree Cranber	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
180	Extended Stay	Pool													
101	Fairfield Inn & Suite	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
110	Gold Fish Swim Clu	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
115	Hampton Inn	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
134	Hampton School Di	Pool	Der	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
135	Hampton School Di	Pool	Sh	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
168	Home 2 Suites	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
210	L.A. Fitness North	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
211	L.A. Fitness North	Pool	Spa	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG	12/6/23	3:22 PM	DG
122	McKnight Hotel	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
123	McKnight Hotel	Spa													
234	North Allegheny Hi	Pool	Der	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
235	North Allegheny Hi	Pool	Sh	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
236	North Hills High Sch	Pool	Der	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
237	North Hills High Sch	Pool	Sh	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
238	Northgate High Sch	Pool	Der	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
239	Northgate High Sch	Pool	Sh	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
455	Novacare McKnight	Therapy		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
245	Oxford Athletic Clu	Pool	Der	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
246	Oxford Athletic Clu	Pool	Sh	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
247	Oxford Athletic Clu	Spa		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG	12/6/23	3:22 PM	DG
386	Residence Inn Crar	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
387	Residence Inn Crar	Spa		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG	12/6/23	3:22 PM	DG
277	Shaler Areas Middl	Pool	Der	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
278	Shaler Area Middle	Pool	Sh	12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
399	Stay Bridge Suites	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
119	Wingate	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			
120	Wingate	Spa		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG	12/6/23	3:22 PM	DG
346	Woodlands Camp	Pool		12/6/23	3:22 PM	DG	12/6/23	3:22 PM	DG	12/6/23	2:40 PM	DG			

Lab ID #	Lab customer	Address	City, State, Zip	Source Ty	Final Analysis Date/Time	Escherichia Coli	Coliforms	HPC	Fecal Stepto	Analyst	
N-2											
Laboratory Results											
433	Atria Senior Living	8870 Duncan Ave.	Pittsburgh, PA 15237	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml	PS	
013	Bairel Center	2565 Nicholson Rd.	Sewickley, PA 15143	Pool Dee	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
014	Bairel Center	2565 Nicholson Rd.	Sewickley, PA 15143	Pool Sha	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
464	Big Blue Swim Schor	20412 US Rt19	Cranberry, PA 16066	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
033	Candlewood Suites	20036 Oak Tree Place	Cranberry, PA 16066	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
088	Divine Providence	9000 Babcock Blvd	Allision Park, PA 15101	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
452	Doubletree Cranberr	910 Sheraton Dr	Mars, PA 16046	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
180	Extended Stay	136 Emeryville Dr.	Cranberry, PA 16066	Pool							
101	Fairfield Inn & Suites	901 Providence Blvd.	Pittsburgh, PA 15237	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
110	Gold Fish Swim Club	160 Lake Dr.	Wexford, PA 15090	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
115	Hampton Inn	2622 Wexford-Bayne	Wexford, PA 15090	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
134	Hampton School Dis	2929 McCully Rd.	Allison Park, PA 15101	Pool Dee	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
135	Hampton School Dis	2929 McCully Rd.	Allison Park, PA 15101	Pool Sha	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
168	Home 2 Suites	8630 Duncan Ave.	Pittsburgh, PA 15237	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
210	L.A. Fitness North Hi	8700 Duncan Ave.	Pittsburgh, PA 15237	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
211	L.A. Fitness North Hi	8700 Duncan Ave.	Pittsburgh, PA 15237	Spa	12/8/23	1:00 PM	Absent	0/100mls	0/ml	0/100mls	PS
122	McKnight Hotel	4575 McKnight Rd.	Pittsburgh, PA 15237	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		PS
123	McKnight Hotel	4575 McKnight Rd.	Pittsburgh, PA 15237	Spa							
234	North Allegheny High	10375 Perry Hwy.	Wexford, PA 15090	Pool Dee	12/8/23	1:00 PM	Absent	0/100mls	0/ml	PS	
235	North Allegheny High	10375 Perry Hwy.	Wexford, PA 15090	Pool Sha	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
236	North Hills High Sch	53 Rochester Rd.	Pittsburgh, PA 15229	Pool Dee	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
237	North Hills High Sch	53 Rochester Rd.	Pittsburgh, PA 15229	Pool Sha	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
238	Northgate High Scho	589 Union Ave	Pittsburgh, PA 15202	Pool Dee	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
239	Northgate High Scho	589 Union Ave	Pittsburgh, PA 15202	Pool Sha	12/8/23	1:00 PM	Absent	0/100mls	0/ml	PS	
455	Novacare McKnight	4721 McKnight Rd.	Pittsburgh, PA 15237	Therapy	12/8/23	1:00 PM	Absent	0/100mls	0/ml	PS	
245	Oxford Athletic Club	100 Village Club Dr.	Wexford, PA 15090	Pool Dee	12/8/23	1:00 PM	Absent	0/100mls	0/ml	PS	
246	Oxford Athletic Club	100 Village Club Dr.	Wexford, PA 15090	Pool Sha	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
247	Oxford Athletic Club	100 Village Club Dr.	Wexford, PA 15090	Spa	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
386	Residence Inn Crant	1308 Freedom RDd.	Cranberry, PA 16066	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		PS
387	Residence Inn Crant	1308 Freedom RDd.	Cranberry, PA 16066	Spa	12/8/23	1:00 PM	Absent	0/100mls	0/ml	0/100mls	PS
277	Shaler Areas Middle	705 Scott Ave.	Glenshaw, PA 15116	Pool Dee	12/8/23	1:00 PM	Absent	0/100mls	0/ml	PS	
278	Shaler Area Middle	705 Scott Ave.	Glenshaw, PA 15116	Pool Sha	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
399	Stay Bridge Suites	915 Brush Creek Rd.	Warrendale, PA 15086	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		
119	Wingate	210 Executive Dr.	Cranberry, PA 16066	Pool	12/8/23	1:00 PM	Absent	0/100mls	50/ml		
120	Wingate	210 Executive Dr.	Cranberry, PA 16066	Spa	12/8/23	1:00 PM	Absent	0/100mls	0/ml	0/100mls	PS
346	Woodlands Camp	134 Shenot Road	Wexford, PA 15090	Pool	12/8/23	1:00 PM	Absent	0/100mls	0/ml		PS



**Customer**

Facility Name: Burrell High School

Address: 1021 Puckety Church Rd.  
Lower Burrell, PA 15068

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

**Customer**

Facility Name: Comfort Inn - RIDC

Address: 180 Gamma Dr.  
Pittsburgh, PA 15238

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

**Customer**

**Facility Name:** Deer Lakes High School

**Address:** 163 East Union Rd.  
Russellton, PA 15076

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

**Source Type:** Pool Deep

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

**N-3**

**Lab# 085**

**Customer**

**Facility Name:** Deer Lakes High School  
**Address:** 163 East Union Rd.  
Russellton, PA 15076

**Matrix:** Recreational Water

**Source Type:** Pool Shallow

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Fox Chapel High School

Address: 611 Field Club Rd  
Pittsburgh, PA 15238

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

 Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-3**

**Lab# 448**

**Customer**

Facility Name: Fox Chapel High School

Address: 611 Field Club Rd  
Pittsburgh, PA 15238

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-3**

**Lab# 450**

**Customer**

**Facility Name:** Gold Fish  
**Address:** 1115 Freeport Rd.  
Fox Chapel, PA 15238

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N-3

Lab# 118

**Customer**

Facility Name: Hampton Inn  
Address: 2805 Freeport Rd.  
Pittsburgh, PA 15238

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**N-3**

**Lab# 146**

**Customer**

**Facility Name:** Highland High School  
**Address:** 1500 Pacific Ave.  
Natrona Heights, PA 15065

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

**Facility Name:** Highland High School

**Address:** 1500 Pacific Ave.  
Natrona Heights, PA 15065

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

**Source Type:** Pool Shallow

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

**N-3**

**Lab# 161**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *10 Landings Dr.  
Harmarville, PA 15238*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

**Sample Collection**

**Date:** *12/30/99*  
**Time:** *12:00 AM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *12/30/99*  
**Time:** *12:00 AM*  
**Analyst:** *12/30/99*

<b>Laboratory Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-3**

**Lab# 451**

**Customer**

**Facility Name:** Kiski Area H.S.  
**Address:** 240 Hyde Park Rd.  
Leechburg, PA 15656

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-3**

**Lab# 215**

**Customer**

Facility Name: Longwood at Oakmont

Address: 500 Rt. 909  
Verona, PA 15147

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Longwood at Oakmont

Address: 500 Rt. 909  
Verona, PA 15147

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

 Andre Smith, Lead Supervisor

**N-3**

**Lab# 226**

**Customer**

Facility Name: Mews 2 Fox Chapel

Address: 302 Fox Chapel Rd  
Pittsburgh, PA 15238

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-3**

**Lab# 227**

**Customer**

**Facility Name:** Mews 1 Fox Chapel

**Address:** 300 Fox Chapel Rd  
Pittsburgh, PA 15238

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 12/30/99

**Time:** 12:00 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99

**Time:** 12:00 AM

**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**N-3**

**Lab# 256**

**Customer**

**Facility Name:** Plum Boro High School  
**Address:** 900 Elicker Rd.  
Pittsburgh, PA 15239

**Matrix:** Recreational Water  
**Source Type:** Pool Deep

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N-3

Lab# 257

**Customer**

Facility Name: Plum Boro High School

Address: 900 Elicker Rd.  
Pittsburgh, PA 15239

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Shady Side Academy

Address: 423 Fox Chapel Rd  
Pittsburgh, PA 15221

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

 Andre Smith, Lead Supervisor

**N-3**

**Lab# 276**

**Customer**

Facility Name: Shady Side Academy

Address: 423 Fox Chapel Rd  
Pittsburgh, PA 15221

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/30/99

Time: 12:00 AM

Method: Grab

**Sample Final Analysis**

Date: 12/30/99

Time: 12:00 AM

Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

**Facility Name:** Springhill Suites

**Address:** 3015 Pittsburgh Mills Blvd.  
Tarentum, PA 15084

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

**Source Type:** Pool

<b>Laboratory Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**Customer**

Facility Name: Town Place Suites

Address: 2785 Freeport Rd  
Harmar, PA 15238

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Source Type: Pool

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**


---

Andre Smith, Lead Supervisor

**N-3**

**Lab# 323**

**Customer**

**Facility Name:** Valley High School  
**Address:** 703 Stevenson Blvd.  
New Kensington, PA 15068

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

N-3

Lab# 351

**Customer**

Facility Name: YMCA  
Address: 5021 Freeport Rd.  
Natrona Heights, PA 15065

Matrix: Recreational Water  
Source Type: Pool Deep

**Sample Collection**

Date: 12/30/99  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/30/99  
Time: 12:00 AM  
Analyst: 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**N-3****Lab# 352****Customer**

**Facility Name:** YMCA  
**Address:** 5021 Freeport Rd.  
Natrona Heights, PA 15065

**Matrix:** Recreational Water  
**Source Type:** Pool Shallow

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

**N-3**

**Lab# 456**

**Customer**

**Facility Name:** YMCA - New Kensington  
**Address:** 800 Constitution Blvd.  
New Kensington, PA 15068

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 12/30/99  
**Time:** 12:00 AM  
**Analyst:** 12/30/99

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/99	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/99	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/99	12:00 AM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	12/30/99	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/30/99	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	12/30/99	12:00 AM	0	Visual

**Sample comments**

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

## Recreational Water

## Collection

Lab ID #	Lab customer	Address	City, State, Zip	Source Type	Date	Time	Ph	Chl	Turb	Collec
N-3								Field Results		
028	Burrell High School	1021 Puckety Church	Flower Burrell, PA 15068	Pool						
064	Comfort Inn - RIDC	180 Gamma Dr.	Pittsburgh, PA 15238	Pool						
084	Deer Lakes High Sch	163 East Union Rd.	Russellton, PA 15076	Pool Deep						
085	Deer Lakes High Sch	163 East Union Rd.	Russellton, PA 15076	Pool Shallow						
447	Fox Chapel High Sch	611 Field Club Rd	Pittsburgh, PA 15238	Deep End						
448	Fox Chapel High Sch	611 Field Club Rd	Pittsburgh, PA 15238	Shallow End						
450	Gold Fish	1115 Freeport Rd.	Fox Chapel, PA 15238	Pool						
118	Hampton Inn	2805 Freeport Rd.	Pittsburgh, PA 15238	Pool						
146	Highland High School	1500 Pacific Ave.	Natrona Heights, PA 15084	Pool Deep						
147	Highland High School	1500 Pacific Ave.	Natrona Heights, PA 15084	Pool Shallow						
161	Holiday Inn Express	10 Landings Dr.	Harmarville, PA 15238	Pool						
451	Kiski Area H.S.	240 Hyde Park Rd.	Leechburg, PA 15656	Pool						
215	Longwood at Oakmon	500 Rt. 909	Verona, PA 15147	Pool						
216	Longwood at Oakmon	500 Rt. 909	Verona, PA 15147	Spa						
226	Mews 2 Fox Chapel	302 Fox Chapel Rd	Pittsburgh, PA 15238	Pool						
227	Mews 1 Fox Chapel	300 Fox Chapel Rd	Pittsburgh, PA 15238	Pool						
256	Plum Boro High Sch	900 Elicker Rd.	Pittsburgh, PA 15239	Pool Deep						
257	Plum Boro High Sch	900 Elicker Rd.	Pittsburgh, PA 15239	Pool Shallow						
275	Shady Side Academy	423 Fox Chapel Rd	Pittsburgh, PA 15221	Pool Deep						
276	Shady Side Academy	423 Fox Chapel Rd	Pittsburgh, PA 15221	Pool Shallow						
285	Springhill Suites	3015 Pittsburgh Mills B	Tarentum, PA 15084	Pool						
298	Town Place Suites	2785 Freeport Rd	Harmar, PA 15238	Pool						
323	Valley High School	703 Stevenson Blvd.	New Kensington, PA 15089	Pool						
351	YMCA	5021 Freeport Rd.	Natrona Heights, PA 15084	Pool Deep						
352	YMCA	5021 Freeport Rd.	Natrona Heights, PA 15084	Pool Shallow						
456	YMCA - New Kensi	800 Constitution Blv	New Kensington, PA 15089	Pool						

	Fecal Coliform	Total Coliform	HPC	Fecal Streptococcus
	Incubation Start	Incubation Start	Incubation Start	Incubation Start
Lab ID	#	Analyst	Analyst	Analyst
	Date	Date	Date	Date
	Time	Time	Time	Time
	Source T	Sample	Sample	Sample
	Location	Description	Description	Description
028	Burrell High School Pool			
064	Comfort Inn - RIDC Pool			
084	Deer Lakes High SchPool Deep			
085	Deer Lakes High SchPool Shallow			
447	Fox Chapel High SchDeep End			
448	Fox Chapel High SchShallow End			
450	Gold Fish Pool			
118	Hampton Inn Pool			
146	Highland High School Pool Deep			
147	Highland High School Pool Shallow			
161	Holiday Inn Express Pool			
451	Kiski Area H.S. Pool			
215	Longwood at OakmonPool			
216	Longwood at OakmonSpa			
226	Mews 2 Fox Chapel Pool			
227	Mews 1 Fox Chapel Pool			
256	Plum Boro High SchorPool Deep			
257	Plum Boro High SchorPool Shallow			
275	Shady Side Academy Pool Deep			
276	Shady Side Academy Pool Shallow			
285	Springhill Suites Pool			
298	Town Place Suites Pool			
323	Valley High School Pool			
351	YMCA Pool Deep			
352	YMCA Pool Shallow			
456	YMCA - New KensiPool			

Lab ID					Escherichia	Coliforms	HPC	Fecal Stepto	
#	Lab customer	Address	City, State, Zip	Source Ty	Final Analysis Date/Time	Coli			Analysis
Laboratory Results									
028	Burrell High School	1021 Puckety Church Rd	Lower Burrell, PA 15068	Pool					
064	Comfort Inn - RIDC	180 Gamma Dr.	Pittsburgh, PA 15238	Pool					
084	Deer Lakes High School	163 East Union Rd.	Russellton, PA 15076	Pool Deep					
085	Deer Lakes High School	163 East Union Rd.	Russellton, PA 15076	Pool Shallow					
447	Fox Chapel High School	611 Field Club Rd	Pittsburgh, PA 15238	Deep End					
448	Fox Chapel High School	611 Field Club Rd	Pittsburgh, PA 15238	Shallow End					
450	Gold Fish	1115 Freeport Rd.	Fox Chapel, PA 15238	Pool					
118	Hampton Inn	2805 Freeport Rd.	Pittsburgh, PA 15238	Pool					
146	Highland High School	1500 Pacific Ave.	Natrona Heights, PA 15065	Pool Deep					
147	Highland High School	1500 Pacific Ave.	Natrona Heights, PA 15065	Pool Shallow					
161	Holiday Inn Express	10 Landings Dr.	Harmarville, PA 15238	Pool					
451	Kiski Area H.S.	240 Hyde Park Rd.	Leechburg, PA 15656	Pool					
215	Longwood at Oakmont	500 Rt. 909	Verona, PA 15147	Pool					
216	Longwood at Oakmont	500 Rt. 909	Verona, PA 15147	Spa					
226	Mews 2 Fox Chapel	302 Fox Chapel Rd	Pittsburgh, PA 15238	Pool					
227	Mews 1 Fox Chapel	300 Fox Chapel Rd	Pittsburgh, PA 15238	Pool					
256	Plum Boro High School	900 Elicker Rd.	Pittsburgh, PA 15239	Pool Deep					
257	Plum Boro High School	900 Elicker Rd.	Pittsburgh, PA 15239	Pool Shallow					
275	Shady Side Academy	423 Fox Chapel Rd	Pittsburgh, PA 15221	Pool Deep					
276	Shady Side Academy	423 Fox Chapel Rd	Pittsburgh, PA 15221	Pool Shallow					
285	Springhill Suites	3015 Pittsburgh Mills Blvd	Tarentum, PA 15084	Pool					
298	Town Place Suites	2785 Freeport Rd	Harmar, PA 15238	Pool					
323	Valley High School	703 Stevenson Blvd.	New Kensington, PA 1506	Pool					
351	YMCA	5021 Freeport Rd.	Natrona Heights, PA 15065	Pool Deep					
352	YMCA	5021 Freeport Rd.	Natrona Heights, PA 15065	Pool Shallow					
456	YMCA - New Kensington	800 Constitution Blvd	New Kensington, PA 15	Pool					