

Risk Assessment No: P011		Task: Towable Fuel Bowser						
Prepared By: Derick Bibby		Date: 21.08.2025			Review Date: 20.08.2026			
		Reviewed By: Lee Hardy			Date: 21.08.2025			
PPE: Safety Footwear, High Visibility Jacket, High Visibility Trousers, Hard Hat, Gloves								
Hazard	Persons at Risk	L	S	R	Control Measures	L	S	R
Collision with persons, vehicles, or property while being towed	Operative Site personnel Pedestrians	3	5	15	- Ensure that there is sufficient clearance between the bowser and any obstruction (property, vehicles etc.) - If required, a banksman will be present when being towed. - Quick-hitch pins and R-clips to be in place prior to towing. - Clear segregation to mark all pedestrian routes from plant work areas - Where this is not possible, all persons to notify operator upon approach to plant, prior to entering work area. This must be by way of 'thumbs up', which will be instructed to all personnel and visitors upon site induction.	1	5	5
Towing hitch/Operation	Operative Site personnel Pedestrians	2	5	10	- Operative to ensure bowser towing apparatus is correctly attached to towing vehicle/machine. - Ensure jockey wheel and all safety cords are correctly stowed or attached before moving. - All pins and clips to be visually inspected as part of daily checks. - Pins and clips to be inspected before use – must be checked for cracks, warps, broken etc. - Only tow with a vehicle or machine that is equipped with the correct towing apparatus and is suitable for the job – Consider weight, distance, environment, ground conditions etc. - All attachments with hydraulic fittings to be thoroughly inspected before each use for tears, cracks, or rips in the hoses. Any visible oil must be cleaned up and its origin identified.	1	5	5

Equipment failure	Operative Site personnel	3	2	6	- All-round checks must be done before start of work each day. These will include all aspects of the machine and will be recorded on a checklist, provided to each operative at the start of the week. - All faults and damage must be recorded on the checklist and reported to Fox Group immediately. - All machinery will be thoroughly inspected before deployment to site, and an inspection certificate will be provided upon delivery.	1	2	2
Incorrect/Unauthorised Use	Operative Site personnel	4	4	16	- Bowser must be kept locked when not in use. - Fox Group supervisor to provide instruction and guidance to personnel on correct use of bowser (mechanical, battery powered etc).	1	4	4
COSHH & Environmental Hazards	Operative Site personnel Pedestrians	4	4	16	- Bowser will be banded to a minimum of 110% capacity. - Where possible, refuelling of machines should be done in a designated area, a minimum of 10 metres away from water courses and drains, and a minimum of 50 metres from any borehole. - Refuelling must be undertaken carefully, ensuring drip trays are used to catch any spillages. - Always wear gloves when handling any fuel or oils. - Spill kits will be provided with fuel bowser and will contain sufficient material to contain a refuelling spillage. - Report all spillages immediately	2	4	8
Slips, Trips and Falls	Operative	3	3	9	- Bowser to be positioned on flat, solid ground. - Bowser to be positioned in area with sufficient lighting, to allow operatives to see their way around bowser and avoid potential trip hazards. - Boots must be in good condition, with sufficient grip on the sole.	2	3	6

Fire	Operative Site personnel	2	4	8	• No smoking near any fuel bowser or refuelling operations. • All machinery to be switched off while refuelling takes place. • If smell or see smoke, report to Fox Group foreman/supervisor immediately. • Fire extinguisher to be positioned next to bowser.	1	4	4
------	-----------------------------	---	---	---	---	---	---	---