

Risk Assessment No: T002		Task: Loading Forward Tipping Dumper						
Prepared By: Derick Bibby		Date: 22.08.2025			RA Review Date: 21.08.2026			
		Reviewed By: Lee Hardy			Date: 22.08.2025			
PPE: Safety Footwear, High Visibility Jacket, High Visibility Trousers, Hard Hat								
Hazard	Persons at Risk	L	S	R	Control Measures	L	S	R
Striking dumper with excavator bucket	Operative	4	4	16	- Only assigned CPCS trained operatives are permitted to operate plant machinery. - Loading machine of suitable size and sufficient capability. - Machine positioned correctly, as per TMP/instruction from site foreman/supervisor. - Before loading operation commences, operative must ensure handbrake is applied, engine is switched off, keys are removed and that they are a safe distance from the machine (out of reach of excavator bucket). - Excavator operative will not slew over cab of dumper during loading operations. - Excavator driver will slew away from the dumper before alerting its driver that the skip is full, by signalling them with a horn blast. - Handbrake applied during loading, to prevent rolling and being struck by bucket on subsequent loads. - Machine to be positioned on level, solid ground for loading, to ensure ease of access for loading bucket. - Weather conditions must not be so bad as to impair visibility of loading operative. If conditions deteriorate during loading, STOP and reassess when suitable. - Ensure that there is sufficient clearance for machine to be loaded safely.	2	4	8
Overloading, falling debris	Site personnel	4	4	16	- Dumper driver to remain off machine during loading operations. - Ensure wagon skip bed is fully down, and the rear gate closed. - Wagon not to be loaded near pedestrian walkways, where loose	2	4	8

	Pedestrians				spoil could fall and injure personnel. • Load to be filled evenly across skip bed, ensuring that material is not overloaded or hanging over the sides. • Ensure skip bed is fully down in the horizontal position before moving off.			
--	-------------	--	--	--	--	--	--	--