

No work is to be done before this matter is finalized and a "Change Order" is issued. This copy to remain with your office. Do not return. Contractor to submit signed letter with price including cost breakdown and change (if any) to construction schedule. Authority having Jurisdiction shall advise of any objections.

TO: QUOREX CONSTRUCTION SERVICES LTD.
1630A 8th Avenue,
Regina, SK S4R 1E5

RE: AURORA FOOD STORE
2000 ANAQUOD ROAD
REGINA, SK
Commission No. 2445

DATE: June 17, 2025

PAGES: 2 (including cover)

RE: Refrigeration Gas Cooler Electrical

1.0 ELECTRICAL

- .1 Refer to attached Electrical PCN #8, dated June 16, 2025 (1 page text).

Distribution:

Sobeys Inc. – Jeff Craig
Sobeys Inc. – Shanwen Hsu
Quorex Construction Services Ltd. – Chris Walbaum
Lavergne Draward & Associates Inc. – Charles Koop
CGM Engineering – Justin Albo
CGM Engineering – Tony Mitousis
CGM Engineering – Brendan Simpson

jeff.craig@sobeys.com
shanwen.hsu@sobeys.com
c.walbaum@quorex.ca
ckoop@ldaeng.ca
justin_albo@cgmeng.ca
tony_mitousis@cgmeng.ca
brendan_simpson@cgmeng.ca



Principal
Kevin Fawley, SAA MRAIC

Project: Aurora Grocery Store
2000 Anaquod Road, Regina, Saskatchewan
Subject: Gas Cooler Circuitry
Date: 2025.06.16

Subject: Gas Cooler Circuitry
References: Electrical Drawing E0.2 – Schedules

1. Circuit breaker and wire for the gas cooler fed from 347/600V-3PH electrical panel '100A' is revised to the following:
 - 1.1. 25A-3P circuit breaker c/w #10 wire in lieu of a 20A-3P circuit breaker c/w #12 wire indicated.