

No work is to be done before this matter is finalized and a "Change Order" is issued. This copy to remain with your office. Do not return. Contractor to submit signed letter with price including cost breakdown and change (if any) to construction schedule. Authority having Jurisdiction shall advise of any objections.

TO: QUOREX CONSTRUCTION SERVICES LTD.
1630A 8th Avenue,
Regina, SK S4R 1E5

RE: AURORA FOOD STORE
2000 ANAQUOD ROAD
REGINA, SK
Commission No. 2445

DATE: October 10, 2025

PAGES: 3 (including cover)

RE: Janitor Room Smoke Damper

1.0 ARCHITECTURAL

.1 Modify/raise height of Janitor Room gypsum board ceiling if/as needed to install damper.

2.0 MECHANICAL

.1 Refer to attached Mechanical PCN #06, dated October 9, 2025 (1 page text).

3.0 ELECTRICAL

.1 Refer to attached Electrical PCN #20, dated October 9, 2025 (1 page text).

Distribution:

Sobeys Inc. – Jeff Craig
Sobeys Inc. – Shanwen Hsu
Quorex Construction Services Ltd. – Chris Walbaum
Quorex Construction Services Ltd. – Dustin Williamson
Lavergne Draward & Associates Inc. – Charles Koop
CGM Engineering – Justin Albo
CGM Engineering – Tony Mitousis
CGM Engineering – Brendan Simpson

jeff.craig@sobeys.com
shanwen.hsu@sobeys.com
c.walbaum@quorex.ca
d.williamson@quorex.ca
ckoop@ldaeng.ca
justin_albo@cgmeng.ca
tony_mitousis@cgmeng.ca
brendan_simpson@cgmeng.ca



Principal
Kevin Fawley, SAA MRAIC

Project: Aurora Food Store
4801 Optimist Drive, Regina, Saskatchewan
Subject: Add Fire/Smoke Damper to Janitor Room
Date: 2025.10.09

Subject: Add Fire/Smoke Damper to Janitor Room
References: Mechanical Drawing – M2.1 – Main Floor Plan - HVAC

1. Delete the fire damper indicated to serve Janitor Room 107 and install a new fire/smoke damper as per the manufacturer's written installation instructions. Coordinate the final requirements with the General Contractor and Electrical Contractor

Project: Aurora Grocery Store
2000 Anaquod Road, Regina, Saskatchewan
Subject: Add Fire/Smoke Damper to Janitor Room
Date: 2025.10.09

Subject: Add Fire/Smoke Damper to Janitor Room
References: Electrical Drawing E0.3 – Schedules
Electrical Drawing E3.0 – Floor Plan – Life Safety

1. Wire and connect 120V power for one(1) new fire/smoke damper being added to 'Janitor Room 107'. Provide power to damper actuator from dedicated, unswitched circuit on panel 'C1'. Provide, wire and connect duct type smoke detector for new fire/smoke damper on supply side of the duct. Interconnect duct type smoke detector with fire alarm system as required. Coordinate exact requirements with General Contractor and Mechanical Contractor on site.