

This notice is clarification and authorization on work to be performed. There will be no change to Contract Price or construction schedule. If a change is to occur, notify Architect and appropriate action will follow.

TO: **QUOREX CONSTRUCTION SERVICES LTD.**
1630A 8th Avenue,
Regina, SK S4R 1E5

RE: **AURORA FOOD STORE**
2000 ANAQUOD ROAD
REGINA, SK
Commission No. 2445

DATE: December 23, 2025

PAGES: 3 (including cover)

RE: Lighting at RTU-1

1.0 ELECTRICAL

- .1 Refer to attached Electrical PCN #2, dated December 10, 2025.
(1 page text, 1 full size drawing E1.0)

Distribution:

Sobeys Inc. – Jeff Craig
Sobeys Inc. – Shanwen Hsu
Quorex Construction Services Ltd. – Chris Walbaum
Quorex Construction Services Ltd. – Dustin Williamson
Lavergne Draward & Associates Inc. – Charles Koop
CGM Engineering – Justin Albo
CGM Engineering – Tony Mitousis
CGM Engineering – Brendan Simpson

jeff.craig@sobeys.com
shanwen.hsu@sobeys.com
c.walbaum@quorex.ca
d.williamson@quorex.ca
ckoop@ldaeng.ca
justin_albo@cgmeng.ca
tony_mitousis@cgmeng.ca
brendan_simpson@cgmeng.ca






Principal
Kevin Fawley, SAA MRAIC

Project: Aurora Grocery Store
2000 Anaquod Road, Regina, Saskatchewan
Subject: Relocation of Lights for RTU-1 Duct Work
Date: 2025.12.10

Subject: Relocation of Lights for RTU-1 Duct Work
References: Electrical Drawing E1.0 – Floor Plan - Lighting

1. Refer to attached drawing E1.0 – Floor Plan - Lighting for the relocation of two(2) type S luminaires to accommodate the RTU-1 duct work. Example site photo is shown below for reference.





DRAWING NOTES - LIGHTING

- ALL TRACK LIGHTING TO BE SUSPENDED ON THREADED ROD. FOLLOW MANUFACTURER'S DIRECTIONS FOR QUANTITIES OF SUSPENSION POINTS. TYPICAL.
- PROVIDE TOUGH-HAT OF ALL COOLER/FREEZER LUMINAIRES. COORDINATE WITH THE REFRIGERATION CONTRACTOR TO AVOID CONFLICT WITH EVAPORATION COILS. SEAL CONDUIT TO LUMINAIRES. TYPICAL.
- PROVIDE CEILING MOUNT LOW TEMPERATURE OCCUPANCY SENSOR. COORDINATE WITH REFRIGERATION CONTRACTOR SO SENSOR IS NOT IN DIRECT LINE OF COIL AIR FLOW. TYPICAL OF ALL COOLERS.
- PROVIDE DUAL-TECH OCCUPANCY SENSOR. PROVIDE VOLTAGE TO SUIT. SENSOR TO PROVIDE LOCAL CONTROL OF THE LIGHTS IN THE AREA. TYPICAL.
- LIGHT FIXTURE TYPE 'S' TO BE SUSPENDED WITH AIRCRAFT CABLE FROM UNITS/ST. SUPPORT BETWEEN GUESTS. TYPICAL.
- CONFIRM EXACT ILLUMINATION AND POWER SUPPLY REQUIREMENTS WITH ILLUMINATED SIGNAGE SUPPLIER.

LIGHTING ZONE SCHEDULE

ZONE	LIGHTING CIRCUIT	AREA DESCRIPTION	CONTROL SCHEME
1	6L-27	VESTIBULE	EMS TIMELOCK
2	6L-2, 6L-4, 6L-6, 6L-8, 6L-10, 6L-12, 6L-14	SALES AREA HIGH BAYS - WEST	EMS TIMELOCK
3	6L-1, 6L-3, 6L-5, 6L-7	SALES AREA HIGH BAYS - EAST	EMS TIMELOCK
4	6L-1, 6L-3, 6L-5, 6L-7	347V SALES AREA POT LIGHTS	EMS TIMELOCK
5	2L-2, 2L-4, 2L-6, 2L-8, 2L-10, 2L-12	120V SALES AREA TRACK AND BULKHEAD LIGHTING	EMS TIMELOCK
6	6L-16, 2L-11	WAREHOUSE / RECEIVING	EMS TIMELOCK
7	6L-16	COMPRESSOR ROOM	EMS TIMELOCK
8	6L-17	BAKERY	EMS TIMELOCK / OCCUPANCY SENSORS
9	6L-15	PHARMACY	EMS TIMELOCK / OCCUPANCY SENSORS
10	6L-21	SEAFOOD / MEATS / PRODUCE	EMS TIMELOCK / OCCUPANCY SENSORS
11	6L-19	H.M.R.	EMS TIMELOCK / OCCUPANCY SENSORS
12	6L-20	LARGE COOLERS	OCCUPANCY SENSOR
13	2L-2	SEATING	EMS TIMELOCK
14	6L-11	OFFICE	OCCUPANCY SENSOR
15	6L-24	EXTERIOR LIGHTS	EMS TIMELOCK

NOTES:
1. ZONE SCHEDULE SHOWN FOR INFORMATION ONLY. WIRING, COMPONENT AND PROGRAMMING REQUIREMENTS TO BE COORDINATED WITH THE SUPPLIER FOR THE SYSTEM USED.

GENERAL NOTES

- ALL SUSPENDED FIXTURE ACCESSORIES AND VISIBLE JUNCTION BOXES TO MATCH CEILING FINISH.
- ELECTRICAL CONTRACTOR TO COORDINATE, INSTALL AND WIRE ALL MILLWORK/FURNITURE LIGHTING FIXTURES SUPPLIED BY OTHERS, INCLUDING FINAL CONNECTIONS.
- UNLESS OTHERWISE NOTED, ALL LIGHTING FIXTURES ARE SUPPLIED AND INSTALLED BY ELECTRICAL CONTRACTOR, INCLUDING, BUT NOT LIMITED TO, ALL NECESSARY MOUNTING HARDWARE SUCH AS STEEL CABLES, GUT CONDUIT, SUPPORTED UNITS, ETC.
- REFER TO ARCHITECTURAL DECOR LIGHTING AND REFLECTED CEILING PLAN FOR EXACT MOUNTING HEIGHTS OF ALL LUMINAIRES. COORDINATE WITH ARCHITECT.
- LIGHTING CONTROLS (INCLUDING LOW VOLTAGE CONTROLS) SHALL BE PROVIDED AND INSTALLED BY EC.
- COORDINATE THE PURCHASE AND INSTALLATION OF ALL LIGHTING CONTROL EQUIPMENT THROUGH MICRO THERMO WEST. ALL LIGHTING CONTROLS ARE TO BE TIED IN WITH BUILDING EMS SYSTEM AS REQUIRED. COORDINATE EXACT REQUIREMENTS FOR THE LIGHTING CONTROL SYSTEM WITH MICRO THERMO WEST ON SITE.

1 CLAR-02 2025.12.10 KC
No. ISSUED FOR DATE BY
DRAWN BY: BS
PRINTING DATE: DECEMBER 10, 2025

CGM 200-1100 CORYDON AVE
WINNIPEG, MB R3M 0Y3
(204) 272-3255
ENGINEERING LTD. PROJECT NO: 24258

NEJ MARK
ARCHITECT

2-54 Adelaide Street Winnipeg Manitoba R3A 0V7
P 204 947 3775 F 204 947 3789 www.nejmark.mb.ca

Drawings and specifications, as instruments of service are the property of the Architect, the copyright is the same being reserved to them. No reproduction may be made without the permission of the architect, and when made, must bear their name. All plans to be returned.

The contractor is to verify dimensions and date noted herein with conditions on the site and is held responsible for reporting discrepancies to the architect for adjustment.

PROJECT TITLE:

AURORA GROCERY
STORE
2000 ANAQUOD ROAD
REGINA, SASKATCHEWAN

SHEET TITLE:
FLOOR PLAN -
LIGHTING
COMMISSION NUMBER:
2445
SHEET NUMBER:
E.10