

No work is to be done before this matter is finalized and a "Change Order" is issued. This copy to remain with your office. Do not return. Contractor to submit signed letter with price including cost breakdown and change (if any) to construction schedule. Authority having Jurisdiction shall advise of any objections.

TO: QUOREX CONSTRUCTION SERVICES LTD.

1630A 8th Avenue,
Regina, SK S4R 1E5

RE: AURORA FOOD STORE

2000 ANAQUOD ROAD
REGINA, SK
Commission No. 2445


DATE: March 17, 2025

PAGES: 1 (including cover)

RE: Storm Connection

1.0 MECHANICAL

- .1 Refer to drawing M1.1 FOUNDATION PLAN PLUMBING AND PIT.
Modify Keynote #4 to refer to 12" storm sewer size.
Modify storm line connection size/location, and trench drain pipe size:



- .2 6" outlets on the trench drains are acceptable. Mechanical Contractor to upsize to 10" before they combine as per the tender drawings. Contractor to upsize again to a 12" near the service connection to reduce the amount of material costs for the project.
- .3 Quorex to coordinate storm line connection with Landlord's civil scope/location.

Distribution:

Sobeys Inc. – Jeff Craig
Sobeys Inc. – Shanwen Hsu
Quorex Construction Services Ltd. – Chris Walbaum
Lavergne Draward & Associates Inc. – Charles Koop
CGM Engineering – Justin Albo
CGM Engineering – Marc Pelland
CGM Engineering – Brendan Simpson
Nejmark Architect – Kevin Fawley

jeff.craig@sobeys.com
shanwen.hsu@sobeys.com
c.walbaum@quorex.ca
ckoop@ldaeng.ca
justin_albo@cgmeng.ca
marc_pelland@cgmeng.ca
brendan_simpson@cgmeng.ca
kevin@nejmark.mb.ca

Kempuz

Principal
Kevin Fawley, SAA MRAIC