From:	Kevin Fawley
To:	Chris Walbaum
Subject:	RE: Aurora Food Store - RFI# 005 - Steel Colum Spray Foam
Date:	Thursday, March 20, 2025 10:38:33 AM
Attachments:	image001.png image002.png image003.png image004.png image005.png

---

Spray foam not required inside the vertical columns

From: Chris Walbaum <c.walbaum@quorex.ca>
Sent: Thursday, March 20, 2025 9:55 AM
To: Kevin Fawley <kevin@nejmark.mb.ca>
Subject: Aurora Food Store - RFI# 005 - Steel Colum Spray Foam

Hey Kevin,
Attached is RFI# 005 - Steel Colum Spray Foam for your rexponse.

Chris Walbaum
Project Manager

Quorex Construction Services Ltd.
1630A 8th Avenue, Regina, SK S4R 1E5
Direct 306 992 6364 | **Cell** 306 807 3479 | c.walbaum@quorex.ca
Main 306 761 2222 | **Fax** 306 761 2300
www.quorex.ca