

No work is to be done before this matter is finalized and a "Change Order" is issued. This copy to remain with your office. Do not return. Contractor to submit signed letter with price including cost breakdown and change (if any) to construction schedule. Authority having Jurisdiction shall advise of any objections.

**TO: QUOREX CONSTRUCTION SERVICES LTD.**  
 1630A 8th Avenue,  
 Regina, SK S4R 1E5

**RE: AURORA FOOD STORE**  
 2000 ANAQUOD ROAD  
 REGINA, SK  
 Commission No. 2445

**DATE:** June 5, 2025

**PAGES:** 2 (including cover)

**RE: Vestibule Steel Studs**

### 1.0 ARCHITECTURAL

- .1 Provide 6" steel studs in lieu of 3 5/8" at Vestibule interior walls as per Clarification 2445-05. Provide credit for deletion of 3 5/8" studs.
- .2 Include scope in p.eng sealed shop drawings as per Wall Type Note #6.13 on drawing A0.0:
  13. ALL INTERIOR WALLS THAT...
    - ...EXTEND 17'-0" A.F.F. OR HIGHER TO BE CONSTRUCTED WITH 18 GAUGE MIN. STEEL STUDS.
    - ...EXTEND 12'-0" TO 17'-0" A.F.F. TO BE CONSTRUCTED WITH 20 GAUGE MIN. STEEL STUDS.
    - ...ARE LOWER THAN OR EQUAL TO 12'-0" A.F.F. IN HEIGHT TO BE CONSTRUCTED W/ 25 GAUGE MIN. STEEL STUDS. PROVIDE P.ENG SEALED SHOP DRAWINGS.
- .3 Refer to Section 05 41 00 Structural Metal Framing.
- .4 Provide credit for reduction of aluminum frames/glazing as per Clarification 2445-05.

#### Distribution:

Sobeys Inc. – Jeff Craig  
 Sobeys Inc. – Shanwen Hsu  
 Quorex Construction Services Ltd. – Chris Walbaum  
 Lavergne Draward & Associates Inc. – Charles Koop  
 CGM Engineering – Justin Albo  
 CGM Engineering – Tony Mitousis  
 CGM Engineering – Brendan Simpson

jeff.craig@sobeys.com  
 shanwen.hsu@sobeys.com  
 c.walbaum@quorex.ca  
 ckoop@ldaeng.ca  
 justin\_albo@cgmeng.ca  
 tony\_mitousis@cgmeng.ca  
 brendan\_simpson@cgmeng.ca



Principal  
 Kevin Fawley, SAA MRAIC

