No.

FORM VI

Odisha Boiler Inspection Department

CERTIFICATE FOR USE OF A BOILER

(Regulation 389) Maker's Number of Boiler - OR/1119 Type of Boiler Boiler Rating - 5120 Place and year manufacture - Pune,2005 Maximum continues Evaporation – 45 TPH Name of owner -M/S Tata Sponge Iron Ltd Situation of Boiler-At-Beleipada, PO- Joda, Dist- Keonjhar. Repairs-Remarks-Hydraulically Tested on 20.04.2019 to 81.00 Kg/cm² I hereby certify that the above described Boiler is permitted by me/the Chief Inspector under the provisions of Section 7/8 of the Boilers Act, No. V of 1923 to be worked at a maximum pressure of 54.00 Kilogram per square centimetre) For period from **20.04.2019** to **19.04.2020** . The loading of the Full lift safety Valve is not to exceed 54.00Kg/cm² 24,500.00 Fee Rs paid on -12.04.2019 Dated at day of

Countersigned

Chief Inspector

See Reverse for "Conditions"