

No. BGR/BLR/67/2018

FORM VI
ODISHA BOILER INSPECTION DEPARTMENT
CERTIFICATE FOR USE OF A BOILER
(Regulation 389)

Registry Number of Boiler..... OR-927 Type of Boiler..... H.M.T Boiler
Boiler Rating 110 Place and Year of Manufacture
Pune, 2004
Maximum Continuous Evaporation..... 3000 Kg/Hr

Name of owner..... M/s Radhaswami Food Products.

Situation of Boiler..... At-Lachut, P.O.- Saintala,
Dist-Bolangir, Odisha

Repairs..... No Repair

Remarks.....
Hydraulically Tested on 25.09.2018 to 13.2 Kg/Cm²

I hereby certify that the above described Boiler is permitted by me/ the Chief
Inspector under the provisions of Section 7/8 of the Indian Boilers Act, No. V of 1923,
to be worked at a maximum pressure of... 10.54 ...Kilogram per square centimeter)

for the period of from 25.09.2018 to 24.09.2019
The loading of the..... Full Lift Spring Loadedsafety valve not to exceed
10.54 Kg/Cm²

Fees Rs..... 4000.00paid on..... 18.09.2018

Dated at..... Bolangir

This 25th day of SEPTEMBER 2018

Countersigned

[Signature]
Inspector
Asst. Director of Factories
& Boilers Balangir Zone

See Reverse for "conditions"

Chief Inspector