## Odisha Boiler Inspection Department CERTIFICATE FOR USE OF A BOILER

(Regulation 389)

Registry Number of Boiler - OD-23 Type of Boiler - HMT

Boiler Rating 107 Place and year of Manufacture- M/s Veesons Energy Systems Pvt Ltd, Tiruchirapalli/Year Of Mfg. 2014

Maximum Continuous Evaporation- 3000 Kgs/Hr.

Name of owner M/s Sri Laxmi Narayan Paddy Processing,

Hydraulically Tested on 02/02/2019 to 15.81 Kg/cm<sup>2</sup>

I hereby certify that the above described boiler is permitted by me/ the Chief Inspector under the provisions of Section 7/8 of the Boilers Act. No. V of 1923, to be worked at a maximum pressure of 10.54 ( Ten point five four) Kilogram per square centimeter) for the period from 02/02/2019 to 01/02/2020. The loading of the Full Lift spring loaded safety valve is not to exceed 10.54 ( Ten point five four) Kg.per Centimeter Square.

Fee Rs. 4000/- paid on 26/11/2018

Dated at Bhawanipatna

This \_\_\_\_\_\_\_day of \_\_\_\_\_\_\_2

Remarks:

Countersigned

Asst. Director of Factories & Boilers, Kalahandi Zone, Bhawanipatna.

Chief Inspector

See Reverse for "Conditions"

## CONDITIONS (REVERSE OF FORM VI)

- (1)No structural alteration, addition of renewal shall be made to the boiler otherwise than in accordance with section 12 of the Act.
- (2)Under the provisions of section 8 of the Act this certificate shall cease to be in force.
- (a)on the expiry of the period for which it was granted, or
- (b) when any accident occurs to the boiler, or
- (c) when the boiler is moved, the boiler not being vertical boiler, the heating surface of which is less than two hundred square feet, or a portable or vehicular boiler or
- (d)when any structural alteration, addition, or renewal is made in or to the boiler or
- (e) if the Chief Inspector in any particular case so directs when any structural alteration, addition, or renewal is made in or to any steam pipe attached to the boiler; or
- (f)on the communication to the owner of the boiler of an order of the Chief Inspector prohibiting its use on the ground that it or any steam pipe attached there to is in a dangerous condition. Under section 10 of the Act, when the period of a certificate relating to a boiler has expired, the owner shall provided that he has applied before the expiry of that period for a renewal of the certificate, be entitled to use the boiler at the maximum pressure entered in the former certificate, pending the issue of orders on the application but this shall not be deemed to authorize the use of a boiler in any of the cases referred to clauses(b), (c), (d), (e) & (f) of subsection (1) of section 8 occurring after the expiry of the period of the certificate.
- (3) The boiler shall not be used at a pressure greater than the pressure entered in the certificate as the maximum pressure nor with the safety valve set to a pressure exceeding such maximum pressure.
- (4) The boiler shall not be used otherwise than in a condition which the owner reasonably believes to be compatible with safe working
- (5) Form VI shall be countersigned by the Chief Inspector at the time of registration only as per the provisions of sub section 5 of Section 7 of the Act.

Note: The particulars and dimensions regarding this boiler may be obtained by the owner on payment in the prescribed manner on application to the Chief Inspector.