

No. SBP/BLR/65/2018,

Dated 03.08.2018

FORM VI

Odisha Boiler Inspection Department  
CERTIFICATE FOR USE OF A BOILER  
(Regulation 389)

Registry Number of Boiler- OR-1618 Type of Boiler- HMT

Boiler Rating-25 Place and year of manufacture-Pune,2013

Maximum Continuous Evaporation – 600 kg./Hr.

Name of owner- M/s Western Land Diary Pvt. Ltd,

Situation of Boiler- At/ PO-Hatibari, Dist-Sambalpur.

Repairs-

Remarks-

Hydraulically Tested on 03-08-2018 to 13.5 Kg/cm<sup>2</sup>

I hereby certify that the above described Boiler is permitted by me under the provisions of Section 7/8 of the Boilers Act, No. V of 1923 to be worked at a maximum pressure of 10.54 Kilogram per square centimeter for the period from 03-08-2018 to 02-08-2019.

The loading of the Full Lift Safety Valve is not to exceed 10.54 Kg /cm<sup>2</sup>.

Fee Rs.2100/- paid on 21-07-2018.

Dated at Sambalpur.

This 3<sup>rd</sup> day of August, 2018.



See Reverse for "Conditions"

Asst. Director of Factories  
& Boilers, Sambalpur Zone-1

Inspector