

<p>No. 42/18</p> <p align="center">Odisha Boiler Inspection Department. FORM VI</p> <p>Registry Number of Boiler OR-1677, Type of Boiler HMT</p> <p>Boiler Rating- 155, Place and year of manufacture Pune, 2014</p> <p>Maximum Continuous Evaporation 4 TPH</p> <p>Name of owner M/s Tulshi Ricetech Pvt. Ltd.,</p> <p>Situation of Boiler At- Santri, P.O. Banarpal, Dist- Angul.</p> <p>Repair :- Repaired as per repair order approved vide memo No. 4412 dtd. 31.07.2018 of DF&B, Odisha, Bhubaneswar.</p> <p>Remarks _____</p> <p>Hydraulically tested on 29.08.2018 to 14 Kg/cm²</p> <p>I hereby certify that the above described Boiler is permitted by me/ the Chief Inspector under the provisions of Section 7/8 of the Boiler Act, No. V of 1923 to be worked at a maximum pressure of 10.54 Kilogram per square centimeter) for the period from 29.08.2018 to 28.08.2019.</p> <p>The loading of the Single post safety valve is not to exceed ten decimal five four Kg/cm²</p> <p>Fee Rs. 4500/- paid on 09.08.2018(On line)</p> <p>Dated at Nalco Nagar.</p> <p>This 29th day of August 2018</p> <p align="right"> <i>Asst. Dy. Insp. of Factories and Boilers, Angul Zone-I</i> Nalcomagar Countersigned Chief Inspector </p>	<p>No. 42/18</p> <p align="center">FORM VI Odisha Boiler Inspection Department CERTIFICATE FOR USE OF A BOILER <i>(Regulation 389)</i></p> <p>Registry Number of Boiler OR- 1677, Type of Boiler HMT</p> <p>Boiler Rating- 155, Place and year of manufacture Pune, 2014</p> <p>Maximum Continuous Evaporation 4 TPH</p> <p>Name of owner M/s Tulshi Ricetech Pvt. Ltd.,</p> <p>Situation of Boiler At- Santri, P.O. Banarpal, Dist- Angul.</p> <p>Repairs:- Repaired as per repair order approved vide Memo No. 4412 dtd. 31.07.2018 of DF&B, Odisha, Bhubaneswar.</p> <p>Remarks _____</p> <p>Hydraulically tested on 29.08.2018 to 14 Kg/cm²</p> <p>I hereby certify that the above described Boiler is permitted by me / the Chief Inspector under the provisions of Section 7/8 of the Boiler Act. No. v of 1923, to be worked at a maximum pressure of 10.54 Kilogram per square centimeter) for the period of from 29.08.2018 to 28.08.2019.</p> <p>The loading of the Single post safety valve is not to exceed Ten decimal Five four kg/cm²</p> <p>Fee Rs. 4500/- paid on 09.08.2018(On line)</p> <p>Dated at Nalco Nagar.</p> <p>This 29th day of August 2018</p> <p align="right"> <i>Asst. Dy. Insp. of Factories and Boilers, Angul Zone-I</i> Nalcomagar Countersigned Chief Inspector </p> <p>See Reverse for "Conditions"</p>
--	--

CONDITIONS
(Reverse of Form VI)

1. No Structural alteration addition or renewal shall be made to the boiler otherwise than in accordance with section 12 of the Act.
 2. Under the provisions section 8 of the Act this certificate shall cease to be in force: -
 - (a) on the expiry of the period for which it was granted; or
 - (b) when any accident occurs to the boiler; or
 - (c) when the boiler is moved, the boiler not being a vertical boiler the heating surface of which is less than two hundred square..... or a portable or vehicular boiler; or
 - (d) when any structural alteration, addition or renewal is made in or to the boiler; or
 - (e) If the Chief inspector in any particular case so directs when any structural alteration, addition or renewal is made in or to any steam pipe attached to the boiler; or
 - (f) on the communication to the owner of the boiler of an order of the Chief Inspector or Inspector prohibiting its use on the ground that it or any boiler component attached there to is in a dangerous condition.
- Under Section 10 of the Act, when the period of a certificate relating to a boiler has expired, the owner shall, provided that he has applied before the expiry of that period for a renewal of the certificate be entitled to use the boiler at the maximum pressure entered in the former certificate, pending the issue of orders on the application but this shall not be deemed to authorise the use of a boiler in any of the cases referred to in clauses (b), (c), (d), (e) and (f), of sub-section (1) of section 8 occurring after the expiry of the period of the certificate.
3. The boiler shall not be used at a pressure greater than the pressure entered in the certificate as the maximum pressure nor with the pressure valve set to a pressure exceeding such-maximum pressure.
 4. The boiler shall not be used otherwise than in a condition which the owner reasonably believes to be compatible with safe working.
 5. Form VI shall be countersigned by the Chief Inspector at the time of registration only as per the provisions of sub section 5 of Section 7 of the Act.
- Note. — The particulars and dimensions regarding this boiler may be obtained by the owner on payment in the prescribed manner on application to the Chief Inspector.