

Odisha Boiler Inspection Department  
FORM VI

Counterfoil

No. 38

Registry Number of Boiler- OR-756 Type of Boiler- H.M.T

Boiler Rating- 121 Place and year of manufacture - Tiruchirappalli, 2003  
Maximum Continuous Evaporation - 3630Kg/Cm<sup>2</sup>

Name of owner- M/s Jasoda Agro Foods (P) Ltd.

Situation of Boiler- At: Talanagar, P.O- Soro, Dist- Balasore.

Repairs

Remarks

Hydraulically Tested on 16.08.2018 to 14 kg. Per sq. centimeter  
I hereby certify that the above described Boiler is permitted by me/the Chief  
Inspector under the provision of Section 7/8 of the Boilers Act, No. V of 1923 to  
be worked at a maximum pressure of 10.54 Kilogram per square centimeter  
for the period from 16.08.2018 to 15.08.2019  
The loading of the double post high lift safety valve not to exceed Ten decimal  
five four Kg/Cm<sup>2</sup>

Fee Rs. 4500/- paid on 03/08/2018

Dated at Balasore

This \_\_\_\_\_ day of \_\_\_\_\_ 20

ASST. DIRECTOR OF  
FACTORIES & BOILERS  
BALASORE  
Inspector  
18.8.18

Countersigned