

No. JSG/BLR/47/2018,

Dated 10.12.2018.

FORM VI

Odisha Boiler Inspection Department  
CERTIFICATE FOR USE OF A BOILER  
(Regulation 389)

Registry Number of Boiler- OR- 1013

Type of Boiler- Water Tube (AFBC)

Boiler Rating- 1024

Place and year of manufacture- Tiruchirapalli, 2005

Maximum Continuous Evaporation – 22 T/Hr.

Name of owner- M/s. Thakur Prasad Sao & Sons (P) Limited,

Situation of Boiler- At- Lahandabud, P.O.- H. Katapali, Dist.- Jharsuguda.

Repairs- As per repair order approved vide Memo No. 6605, Dated 28.11.2018 of  
Director of Factories & Boilers, Odisha, Bhubaneswar.

Remarks

Hydraulically Tested on 10.12.2018 to 94 Kg/cm<sup>2</sup>.

I hereby certify that the above described Boiler is permitted by me under the provisions of Section 7/8 of the Boilers Act, No. V of 1923 to be worked at a maximum pressure of 75 Kilogram per square centimeter for the period from 10.12.2018 to 09.12.2019. The loading of the Full Lift Spring Loaded Safety Valve is not to exceed 75 Kg /cm<sup>2</sup>.

Fee Rs. 8, 400/- paid on 04.12.2018.

Dated at Jharsuguda.

This 10<sup>th</sup> day of December, 2018.

Inspector

See Reverse for "Conditions"

Asst. Director of Factories & Boilers  
Jharsuguda Zone, Jharsuguda