

No. BLR/BBSR DIV/38 Counterfoil

Odisha Boiler Inspection Department

Registry Number of Boiler: OR-1249, Type of Boiler: Horizontal Multi Tubular  
Boiler Rating: 40, Place and year of manufacture: Maxtherm Private Limited,  
Ranipet 2011, Maximum continuous evaporation : 1000 Kg/Hr  
Name of Owner: Milk Mantra Dairy Private Limited  
Situation of Boiler: At/Po: Sarada, Via: Gop, Dt: Puri.

Repairs: \_\_\_\_\_


Remarks \_\_\_\_\_

Hydraulically tested on 25.07.2018 to 15.00 Kg /cm<sup>2</sup>

I hereby certify that the above described Boiler is permitted by me/the  
Chief Inspector under the provisions of Section 7/8 of the Boilers Act, No. V  
of 1923 to be worked at a maximum pressure of 10.54 Kg /cm<sup>2</sup> (Ten  
Decimal Five Four Kilogram per square centimeter) for the period from  
25.07.2018 to 24.07.2019. The loading of the full lift, single post spring  
loaded Safety Valve is not to exceed 10.54 Kg /cm<sup>2</sup> (Ten Decimal Five  
Four Kilogram per square centimeter) Fee : Rs 2400.00, (Rupees Two  
Thousand Four Hundred) paid on 20<sup>th</sup> July 2018.

Dated at Bhubaneswar

This 25<sup>th</sup> day of July 2018

  
25.07.18

Inspector  
Asst Director of Factories & Boilers,  
Bhubaneswar Zone-II

Countersigned

Chief Inspector  
Director of Factories & Boilers, Odisha

No. BLR/BBSR DIV/38 FORM VI

Odisha Boiler Inspection Department

CERTIFICATE FOR USE OF A BOILER

(Regulation 389)

Registry Number of Boiler: OR-1249, Type of Boiler: Horizontal Multi Tubular  
Boiler Rating: 40, Place and year of manufacture: Maxtherm Private Limited,  
Ranipet 2011, Maximum continuous evaporation : 1000 Kg/Hr  
Name of Owner : Milk Mantra Dairy Private Limited  
Situation of Boiler : At/Po: Sarada, Via: Gop, Dt: Puri.

Repairs: \_\_\_\_\_


Remarks \_\_\_\_\_

Hydraulically tested on 25.07.2018 to 15.00 Kg /cm<sup>2</sup>

I hereby certify that the above described Boiler is permitted by me/the Chief  
Inspector under the provisions of Section 7/8 of the Boilers Act, No. V, of 1923 to  
be worked at a maximum pressure of 10.54 Kg /cm<sup>2</sup> (Ten Decimal Five Four  
Kilogram per square centimeter) for the period from 25.07.2018 to 24.07.2019.  
The loading of the full lift, single post spring loaded Safety Valve is not to exceed  
10.54 Kg /cm<sup>2</sup> (Ten Decimal Five Four Kilogram per square centimeter) Fee : Rs  
2400.00, (Rupees Two Thousand Four Hundred) paid on 20<sup>th</sup> July 2018.

Dated at Bhubaneswar

This 25<sup>th</sup> day of July 2018

  
25.07.18

Inspector  
Asst Director of Factories & Boilers,  
Bhubaneswar Zone-II

Countersigned

Chief Inspector  
Director of Factories & Boilers, Odisha

See Reverse for "Conditions"