Fire Weather Operational Action Recommendation (OAR)

Puget Sound Energy • Wildfire Risk Management • Rev. 06/2026

Document Information

Date/Time Prepared:		**Prepared By:**		**Approving Authority:**	
Event Name/Reference:		**Approval Date/Time:**		**Updated Date/Time:**	

Fire Weather Summary — Meteorologist & Fire Behavior Analyst

Regional fire danger summary: Red Flag Warnings (active/forecast), wind gusts, PNW 7-day Significant Fire Potential, fire risk analysis.

System Operations/Load Office Recommendations — Presented at the Operations Call

Brief summary of recommendations: communications to interconnected customers, enable EPS / PSPS, etc. See the Asset Risk & Actions tab for per-circuit detail.

Modifications to Recommendations after the Operations Call

Document exceptions to the plan: what was added or subtracted, decision-maker, and time of change.

Staffing

Desired staffing levels for the event and the plan for acquiring resources. Owner: System Ops Supervisor, Load Office Supervisor, EFR Supervisor, Substation Supervisor.

System Operations	Load Office	EFR	Sub Ops	Plan for Resourcing

Asset Risk & Actions — one row per circuit, transmission line, or substation

Fill one row per affected asset. Filter by County or Fire Zone to view per-zone slices. Met/risk indicators are populated by the Meteorologist & FBA; protective-action columns (EPS, SCADA, Recommended Action onward) are populated by System Ops / Load Office. Composite Risk Score is calculated automatically.

ZONE & ASSET						WEATHER & RISK INDICATORS (Met/FBA)												RISK SCORE	PROTECTIVE ACTION & COORDINATION									
County	Fire Zone	Region	Asset Type	Asset ID (Circuit / Line)	Substation	Red Flag Warning	Relative Humidity (%)	Wind Gust Actual (mph)	Wind Gust Percentile (%)	PNW 7-Day Fire Potential	FBI	FPIC	POF	Fire Size Potential	ERC	Fuels	RH Recovery (%)	Sustained Wind (mph)	Composite Risk Score	EPS Capable	SCADA	Recommended Action	Device	Resource Need	Resource Available	Date/Time Required	Status	Owner	Notes/Abnormals/Work to Defer
King	WA-NW-654	Western Washingto	Distribution Circuit	*CKT-12345*	*SUB-ALPHA*	Active	18	42	92	High	7.0	72	0.18	Large	78	chaparr	35	22	62	Yes	Ye s	Enable EPS	*Recloser R-1234*	*1× Troubleman*	Yes	*T-2hr before event*	Not Started	*FDSO*	*Sample row — replace with real data.*

Level 2 Escalation Checklist

Mandatory for the System Operations Supervisor. Prerequisite: Level 2 escalation must be approved by the VP of Gas and Electric Operations before initiating any step below. Log the approval in the Wildfire Critical Decision Tracker before closing this checklist.

VP Approval (Gas & Electric Operations)							
Approver:		**Date/Time:**		**Decision Tracker ID:**		**Criterion Reference:**	

Step	Phase	Action	Responsible Role	Notes	Status	Completed By	Completed Date/Time
Phase 1 – Internal Communications & Notifications							
1	Phase 1	Coordinate all internal communications for Level 2 escalation.	System Operations Supervisor				
1a	Phase 1	Send an email to the Fire Weather – Red Flag Notification List with a summary of the Operations Planning Call, confirming escalation to Level 2.	System Operations Supervisor	*Dist. list: Appendix C*			
1b	Phase 1	Post an update in the ECC Team's General Channel.	System Operations Supervisor	*ECC Teams channel*			
1b-i	Phase 1	Tag "Fire Weather Comms" in the post. This initiates: (1) updating the PSE web banner, and (2) distributing external talking points to community affairs, government affairs, and the call center.	System Operations Supervisor	*Wildfire Comms Team is tagged recipient*			
1b-ii	Phase 1	If after business hours, call the 24-hour Public Info Hotline.	System Operations Supervisor				
1c	Phase 1	Contact interconnected customers and utilities by phone, as defined in the OAR, to advise that EPS activation may affect their operations.	System Operations Supervisor	*Refer to current OAR*			
1d	Phase 1	Send an email to the "Fire Weather Event Response" list including: (1) forecast timing, (2) escalation event details, (3) when settings must be in place, (4) expected return-to-normal time, and (5) a staffing table for System Operations and field personnel.	System Operations Supervisor	*Fire Weather Event Response list*			
Phase 2 – Regional Lead Operator Activation							
2	Phase 2	Provide the Regional Lead Operator with the list of distribution circuits and substations identified for EPS activation.	System Operations Supervisor				
2a	Phase 2	Establish incidents in ADMS to track fire-danger actions, beginning with the event incident. Transfer incident management to the FDSO upon completion and remain available to assist as needed.	Regional Lead Operator				
Phase 3 – FDSO Staffing							
3	Phase 3	Staff an FDSO for the full duration of the event.	System Operations Supervisor				
3a	Phase 3	Initiate FDSO callout immediately upon Level 2 approval.	System Operations Supervisor				
3b	Phase 3	If immediate FDSO coverage is needed, assign the most qualified on-shift operator to temporarily fill the role until relief arrives.	System Operations Supervisor				
3b-i	Phase 3	Assign remaining on-shift operators to cover any resulting vacant region.	System Operations Supervisor				

Step	Phase	Action	Responsible Role	Notes	Status	Completed By	Completed Date/Time
Phase 4 – Storm Mode Activation							
4	Phase 4	Enable Storm Mode in ADMS for distribution circuits and substations designated for EPS action up to one hour before initiation. Use storm reason: **FD <Region> MM/DD/YYYY**	System Operations Supervisor				
Phase 5 – EPS Activation							
5	Phase 5	Stand by and confirm completion of each action before proceeding to logging.	System Operations Supervisor				
5a	Phase 5	Coordinate with field resources to enable EPS on all designated assets. For assets without EPS capability, disable reclosing and enable the hot line work switch. Notify the System Operations Supervisor when all assets are complete.	FDSO				
5b	Phase 5	Evaluate all designated transmission line segments and take the following actions, then notify the System Operations Supervisor upon completion.	Load Office Supervisor / Power Dispatcher				
5c	Phase 5	Disable reclosing on identified high-risk transmission lines, if not already disabled due to PSE Wildfire Season.	Load Office Supervisor / Power Dispatcher				
5c-i	Phase 5	De-energize identified transmission line segments, if not already de-energized due to PSE Wildfire Season.	Load Office Supervisor / Power Dispatcher				
5c-ii	Phase 5	Log the status of all reclosing actions and transmission line segment changes in iTOA.	Load Office Supervisor / Power Dispatcher	*iTOA required*			
Phase 6 – Required Logging & Documentation							
6	Phase 6	Complete all required logging to ensure full traceability of Level 2 actions.	System Operations Supervisor				
6a	Phase 6	Log the escalation in the Wildfire Critical Decision Tracker. Include: (1) time-stamped approving authority, and (2) the applicable criterion reference.	System Operations Supervisor	*Wildfire Critical Decision Tracker*			
6b	Phase 6	Log confirmation in the event incident in ADMS that EPS has been enabled on all desired circuits and all Level 2 actions are complete.	System Operations Supervisor	*Event incident in ADMS*			
6c	Phase 6	Respond to the "Fire Weather Event Response" email list using **Reply All** to confirm that all actions have been taken and EPS is enabled.	System Operations Supervisor	*Reply All required*			

Checklist Completion Sign-off					
Completed By		**Role / Title**		**Date / Time**	