PUGET SOUND ENERGY • PROCEDURE

PSE Wildfire Threat Assessment and Response Procedure

Document Number	PSE-WRM-003	**Revision**	01
Effective Date	07-10-2026	**Owner**	Wildfire Risk Management

Contents

1 Purpose **3**

2 Scope **3**

3 Terms & Acronyms **3**

3.1 Defined Acronyms 3

3.2 Defined Terms 5

4 Roles & Responsibilities **6**

5 Prerequisites & Requirements **8**

5.1 Operational Prerequisites 8

5.2 Training Requirements 9

5.3 PSE Tools and Services 9

5.4 External Sources 9

6 Procedure **9**

6.1 Weekly PSE Wildfire Situation Updates 9

6.2 Continuous Monitoring of Wildfire Activity 10

6.2.1 On-Duty WLM Designation 10

6.2.2 Monitoring Schedule 10

6.2.3 WLM Situational Awareness 10

6.2.4 Notification Flow 11

6.3 New and Ongoing Wildfire Threat Determination 11

6.3.1 Threat Triggers 11

6.3.2 Evaluation Inputs 11

6.3.3 Wildfires Identified as Threats 12

6.4 Classification of Fires Identified as Threats 12

6.4.1 Classification Inputs 12

6.4.2 Decision Precedence 13

6.4.3 High Potential Impact Level 13

6.4.4 Moderate Potential Impact Level 13

6.4.5 Low Potential Impact Level 14

6.4.6 Logging and Updates 14

6.5 PSE Response to Potential Impact 14

6.5.1 High Potential Impact Level – Response 14
6.5.2 Moderate Potential Impact Level – Response 15
6.5.3 Low Potential Impact Level – Response 15
6.5.4 Wildfire Operations Planning Call Agenda 15
6.6 Wildfires Impacting PSE Assets 16
6.7 PSE Contracted Situational Awareness Tools 16
6.7.1 Watch Duty Application 16
6.7.2 Technosylva FireRisk 16
6.7.3 PANO AI Cameras 16
7 Documentation & Records 17
7.1 Incident Tracking Log 17
8 References 18
8.1 Related Documents 18
8.2 PSE Internal Tools 18
8.3 Public Information Sources 18
Appendix A – Contact List 19
Appendix B – Revision History 19

1 Purpose

This procedure establishes a consistent approach for evaluating and responding to wildfire threats to **Puget Sound Energy's** (**PSE**) Electric, Generation, Telecommunications, and Gas infrastructure. It defines monitoring expectations, threat-classification criteria, response actions, and a documentation framework for tracking incidents during PSE Wildfire Season. This procedure also provides recurring weekly Wildfire Situation Briefings to maintain a baseline of situational awareness and to support timely, defensible decisions by leadership.

2 Scope

This procedure applies during the declared PSE Wildfire Season (see *PSE Wildfire Season Declaration Procedure*). It applies to all PSE personnel and contractors involved in monitoring and responding to wildfire emergencies impacting PSE Assets, including:

- Electric Operations
- Emergency Management
- Gas Operations
- PSE Communications Team
- PSE Contractors
- PSE Leadership
- PSE Legal
- PSE Meteorologist
- Telecommunications
- **Wildfire Risk Management** (**WRM**) Team

3 Terms & Acronyms

3.1 Defined Acronyms

Table 1 lists the acronyms used in this procedure.

Table 1: Defined Acronyms

Acronym	Full Term	Definition
CIMT	Complex Incident Management Team	An interagency wildland-fire management team mobilized for large or complex incidents.
DNR	Department of Natural Resources	Washington State agency responsible for wildfire protection and outdoor burning regulation on state and private forested lands.
ECC	Emergency Coordination Center	PSE's centralized coordination facility staffed by the Incident Management Team (IMT) to manage PSPS planning, execution, communications, and restoration.

Acronym	Full Term	Definition
EFR	Electric First Response	PSE's electric field response personnel, including Troublemen, who perform patrols, respond to faults, and support de-energization and restoration during elevated critical fire weather events.
EGP	Enterprise Geospatial Portal	A federal interagency wildland-fire data and mapping portal used by PSE WLMs for situational awareness.
EMR	Emergency Management & Resiliency	PSE internal department responsible for emergency management coordination.
EOC	Emergency Operations Center	An external public agency coordination facility activated during emergencies.
FBI	Fire Behavior Index	A numerical index used to assess and predict fire behavior across various fuel types, aiding in operational fire management and decision-making.
FPIC	Fire Potential Index Composite	A metric used to assess fire potential, combining two key components: the fire danger forecasting fire potential index and the ignition component.
FSP	Fire Size Potential	A Technosylva FireRisk metric representing the potential acreage a fire could reach within 8 hours if initial attack is unsuccessful.
GIS	Geographic Information Systems	A spatial data and mapping system. Referenced in the Director of Engineering & GIS role and as a GIS Support IMT position.
IC	Incident Commander	The individual responsible for all incident activities at the scene of an emergency under the Incident Command System.
ICP	Incident Command Post	The on-scene location at which the primary incident command functions are performed.
IMT	Incident Management Team	The team staffed within the ECC to manage PSPS operations under the Incident Command System. Includes the ECC Director, Operations Section Chief, Planning Section Chief, Logistics Section Chief, Public Information Officer (PIO), and other functional positions.
NIFC	National Interagency Fire Center	The federal interagency coordination center supporting wildland-fire suppression nationally; produces fire weather and fire potential forecast products.
NOAA	National Oceanic and Atmospheric Administration	U.S. federal agency providing weather forecasts, including the National Weather Service.
NWCC	Northwest Interagency Coordination Center	Regional coordination center for wildfire suppression, resource management, and wildfire intelligence.
PALMS	PSE Adaptive Learning Management System	PSE's enterprise learning-management platform used to host and track training.

Acronym	Full Term	Definition
PIL	Potential Impact Level	The classification (Low, Moderate, or High) assigned by the WLM to a wildfire identified as a threat to PSE Assets.
PSE	Puget Sound Energy	The regulated electric and gas utility that owns and operates the electrical system governed by this procedure.
PSPS	Public Safety Power Shutoff	A planned, controlled de-energization of identified transmission and distribution circuits during critical fire weather conditions to reduce the risk of wildfire ignition caused by PSE's electrical equipment.
RMA	Risk Management Assistance	A federal/interagency wildland-fire risk-management product set, accessed via the RMA Dashboard.
ROS	Rate of Spread	The forward speed of a fire perimeter, expressed as a distance per unit time.
SME	Subject Matter Expert	An individual with specialized knowledge relevant to a given task or process.
UAS	Unmanned Aircraft System	An aircraft and its associated control systems operated without a pilot on board (commonly, a drone).
WLM	Wildfire Liaison Manager	PSE personnel who monitor wildfire indicators, maintain external agency coordination, and provide situational intelligence and subject-matter support to operational decision-making.
WRM	Wildfire Risk Management	The PSE business unit that is responsible for wildfire risk monitoring, analysis, and coordination of wildfire mitigation programs across PSE's service territory.
WWG	Western Weather Group	A third-party meteorological firm contracted by PSE to provide supplemental utility-oriented fire weather forecast products and backup meteorological services.

3.2 Defined Terms

Table 2 defines the key terms used in this procedure.

Table 2: Defined Terms

Term	Definition
Critical Fire Weather	Atmospheric conditions – including combinations of low relative humidity, elevated wind speeds, dry fuels, and high fire potential indices – that significantly increase the risk of wildfire ignition from PSE's electrical equipment.
Initial Attack	The first suppression action taken by fire-response agencies upon arrival at a wildfire.
PSE Asset	Electric, Generation, Telecommunications, or Gas infrastructure owned or operated by Puget Sound Energy.

Term	Definition
PSE Wildfire Season	The period of elevated fire weather risk annually declared by PSE when conditions and vegetation moisture levels create elevated wildfire risk, requiring enhanced operational mitigations.
Wildfire Operations Planning Call	A Microsoft Teams call convened by System Operations and/or the On-Duty WLM to coordinate PSE's operational response to a Moderate or High Potential Impact wildfire.

4 Roles & Responsibilities

The specific roles and responsibilities of critical functions in the decision process are identified in the RACI Matrix below (Table 3).

R = Responsible: The person(s) who owns and completes the project, task, or work.

A = Accountable: The person(s) who signs off on the work and who has final sign-off authority and is responsible for outcomes.

C = Consulted: The person(s) who has the ability or knowledge needed to complete the work. These are **Subject Matter Experts** (**SME**), or anyone else who can contribute consultatively to the task.

I = Informed: The person(s) who must be kept informed of the work but not necessarily consulted.

R	Responsible	A	Accountable	C	Consulted	I	Informed

Table 3: RACI Matrix

Position	Monitor Wildfire Activity	Determine Wildfire Threat	Determine Wildfire Response			
			Electric Delivery System Asset	Gas System Asset	Telecoms Asset	Generation Asset
Primary Monitoring & Risk Assessment						
Meteorologist	C	C	C	C	C	C
WLM	R	R	R	R	R	R
System Operations						
System Operations Supervisor	C	C	C	I	I	I
System Operations Manager	C	C	R	I	I	I
Load Office						
Load Office Supervisor	I	I	C	I	I	I
Load Office Manager	I	I	R	I	I	I
Electric Operations – Operational Management						
Manager Electric Operations Substations	I	I	C	I	I	I
Manager Electric Operations EFR	I	I	R	I	I	I
Supervisor of Energy Operations	I	I	R	I	I	I
Electric First Responder Supervisors (affected)	I	C	C	I	I	I
WRM						
WRM Manager	I	I	C	C	C	C
WRM Senior Program Manager	I	I	I	I	I	I
WRM Communications	I	I	I	I	I	I
Emergency Management & Corporate Functions						
Manager of EMR	I	I	I	I	I	I
Director of Communications	I	I	I	I	I	I
Director of Gas Operations	I	C	I	R	I	I
Telecoms	I	C	I	I	R	I

Position	Monitor Wildfire Activity	Determine Wildfire Threat	Determine Wildfire Response			
			Electric Delivery System Asset	Gas System Asset	Telecoms Asset	Generation Asset
Director of Generation	I	C	I	I	I	R
Director of Electric Operations	I	C	C	I	I	I
Director of Safety	I	I	I	I	I	I
Corporate Security	I	I	I	I	I	I
Director of Electric System Control	I	C	C	I	I	I
Executive Approval Authority						
Vice President of Gas & Electric Operations	C	C	C	C	C	C
Senior Vice President of Energy Operations	A	A	A	A	A	A

NOTE When multiple assets are impacted, all relevant asset-class Directors are elevated to Consulted.

5 Prerequisites & Requirements

5.1 Operational Prerequisites

The following conditions must be met before procedural steps in Section 6 are executed:

- PSE Wildfire Season has been declared (see *PSE Wildfire Season Declaration Procedure*), or year-round situational awareness activities (Section 6.2.3) are in effect.
- An On-Duty WLM has been designated for the current rotation.
- All tools listed in Section 5.3 are accessible to the On-Duty WLM.
- The Wildfire Liaison Manager Duty Roster is current.

5.2 Training Requirements

- All PSE personnel and contractors identified in Section 2 (Scope) must review this procedure annually.
- PSE Learning makes annual wildfire-safety training available to employees, including the **PSE Adaptive Learning Management System** (**PALMS**) module "Critical Fire Weather and PSPS for Electric Operations."
- PANO AI users complete platform-specific training before using the tool. Training is available as a recorded session in PALMS and may be supplemented by on-the-job training from experienced PSE users.

5.3 PSE Tools and Services

The following tools are used to support this procedure. The WRM Manager owns maintenance of this list and the corresponding access; tools may change as services evolve.

- PANO AI Dashboard/Alerts – PANO 360
- **Risk Management Assistance** (**RMA**) Dashboard – RMA Dashboard
- Technosylva Fire Analysis tools – My Technosylva
- Watch Duty Application – Watch Duty - Wildfire Maps & Alerts
- **Western Weather Group** (**WWG**) weather station data/dashboard – Western Weather Group

5.4 External Sources

- **Enterprise Geospatial Portal** (**EGP**) – EGP
- **National Interagency Fire Center** (**NIFC**) and **Northwest Interagency Coordination Center** (**NWCC**) forecast products – NWCC
- **National Oceanic and Atmospheric Administration** (**NOAA**) weather information – NOAA
- Wildland Fire Dispatch WildCAD information – WildWeb

6 Procedure

6.1 Weekly PSE Wildfire Situation Updates

During PSE Wildfire Season, the On-Duty WLM uses a standardized PSE Wildfire Situation Briefing Template (located in the 2026 Wildfire Situation Briefings folder) to prepare and distribute the Weekly Wildfire Situation Briefing every Monday morning. The PSE Meteorologist authors the forecast message that is incorporated into the briefing.

The briefing includes the following content:

- Key talking points
- Weather forecast and Critical Fire Weather assessment
- Fire potential and danger indicators
- Regional fire danger indices

- Current-year fire season statistics
- Current-year PSE Wildfire Season statistics

6.2 Continuous Monitoring of Wildfire Activity

6.2.1 On-Duty WLM Designation

The WLMs maintain a rotation schedule designating one WLM as the On-Duty WLM to serve as the 24/7/365 primary point of contact for wildfire activity in the PSE service territory during their rotation (see the Wildfire Liaison Manager Duty Roster). The System Operations Supervisor and the WLMs collaborate to monitor wildfire activity.

6.2.2 Monitoring Schedule

- **Weekdays, 07:00–19:00 PT:** The On-Duty WLM has primary responsibility for monitoring wildfire activity.
- **Weekends and weekday overnight hours, 19:00–07:00 PT:** System Operations has primary responsibility for monitoring reports of new wildfire incidents. The On-Duty WLM is available by phone to assist with assessing threats as needed.
- **Threshold notifications:** If a wildfire occurs that meets the threat criteria in Section 6.3, System Operations notifies the On-Duty WLM via the WLM Duty Phone for further assessment and action.

Daily handoff: During active wildfire activity, the On-Duty WLM and the System Operations Supervisor conduct a morning handoff at 06:00 PT and an evening handoff at 18:00 PT to confirm monitoring responsibility for the next shift.

6.2.3 WLM Situational Awareness

Throughout the year, WLMs maintain situational awareness using a variety of tools and inputs. During PSE Wildfire Season, WLMs monitor conditions daily. Outside of PSE Wildfire Season, WLMs monitor conditions as appropriate for the weather conditions. The following tools and sources are used for situational awareness:

- **Tools**
  - Technosylva FireRisk software
  - PANO AI wildfire detection cameras alerts
  - Watch Duty Application Alerts
  - Dispatch Center WildCAD Reports
- **Information products**
  - Wildfire Situation Reports
  - Fire Weather alerts
  - Other notification methods as appropriate

6.2.4 Notification Flow

- System Operations notifies the On-Duty WLM of all wildfire notifications received from Fire Response Agency Dispatch Centers via the WLM Duty Phone or Teams message.
- The On-Duty WLM and/or System Operations initiates internal communication, including Microsoft Teams calls and posts in the "Real-time Operations & WLM Chat", regarding specific wildland-fire incidents potentially threatening PSE Assets.
- System Operations posts updates to the **Emergency Coordination Center** (**ECC**) General Channel.
- System Operations may assist with internal communication updates as requested by the On-Duty WLM.

6.3 New and Ongoing Wildfire Threat Determination

The On-Duty WLM evaluates wildfires identified in Section 6.2 for threat potential based on proximity to PSE Assets and the situational criteria below. Fires that do not currently meet threat criteria are re-evaluated as needed based upon changing conditions, at least twice daily (12:00 and 18:00 PT).

6.3.1 Threat Triggers

- **Within approximately 2 miles:** Any fire within 2 miles of PSE Assets is evaluated as a potential threat. The WLM assesses the threat and assigns a **Potential Impact Level** (**PIL**) per Section 6.4.
- **Beyond approximately 2 miles:** The WLM assesses fires beyond 2 miles on a situational basis using the criteria below. If determined to be a threat, the WLM classifies the fire per Section 6.4.
  - Fire is large or rapidly escalating
  - Fire is occurring during periods of critical fire weather
  - Other indicators, such as declared evacuations, that indicate PSE Assets may be exposed

The On-Duty WLM or System Operations Supervisor measures the distance of the fire using PANO AI, Watch Duty, PSE **Geographic Information Systems** (**GIS**), or other available geospatial tools with a distance measuring function.

6.3.2 Evaluation Inputs

WLMs evaluate fires using all or some of the following resources on a case-by-case basis:

- Probability of fire spread into PSE Assets using fire-behavior spread modeling resources:
  - Technosylva Fire Behavior Service Contract
  - Spread modeling within Watch Duty Application
  - Other fire behavior modeling software as available
- Daily **Fire Potential Index Composite** (**FPIC**) for potentially impacted circuits
- WLM analysis of fire location and behavior related to PSE Assets, including slope, wind, available fuels, and barriers to spread
- Suppression difficulty, including access, fire-responder resource capacity, and fire-suppression-agency jurisdiction
- Spatial proximity to PSE Assets, evaluated via PSE GIS, Watch Duty, PANO AI, and other tools

WLMs may consult with the PSE Meteorologist, fire response agencies, or other **Subject Matter Experts** (**SME**) when assessing threats.

6.3.3 Wildfires Identified as Threats

If a wildfire is determined to meet the criteria for a threat, the WLM initiates internal communication (including Teams calls and chats as needed in the ECC General Channel) regarding specific wildland fire incidents potentially threatening PSE Assets.

- Calls are made as needed to Asset teams affected (Electric, Gas, Telecoms, Generation).
- System Operations may assist with internal communication updates as requested by WLMs.
- The WLMs begin populating the Incident Tracking Log.

6.4 Classification of Fires Identified as Threats

WLMs review and classify the PIL of wildfires determined to be a threat in Section 6.3 and adjust PILs periodically for incidents as they evolve.

6.4.1 Classification Inputs

WLMs evaluate the following metrics to inform PIL determination:

- Technosylva asset risk metrics:
  - FPIC
  - **Fire Size Potential** (**FSP**)
  - **Fire Behavior Index** (**FBI**)
  - **Rate of Spread** (**ROS**)
- Fire perimeter spread modeling
- Current and/or forecasted weather conditions
- Fuel conditions
- Barriers to fire spread
- Time of year
- Successful Initial Attack/fire suppression response by fire agencies
- Other factors including experience of the evaluator

6.4.2 Decision Precedence

WLMs evaluate PIL classification as “High,” “Moderate,” or “Low” based on the following precedence (Table 4):

Table 4: PIL Decision Precedence

Step	Evaluate	If Yes	If No
1	Evaluate the High criteria first (Section 6.4.3). Does any High criterion apply?	**Classify as High**	Go to Step 2
2	If no High criterion applies, evaluate the Moderate criteria (Section 6.4.4). Does any Moderate criterion apply?	**Classify as Moderate**	Go to Step 3
3	If no High or Moderate criterion applies (Section 6.4.5).	**Classify as Low**	—

6.4.3 High Potential Impact Level

A High PIL is an uncontrolled fire on the landscape that meets the Moderate criteria in Section 6.4.4 and at least one of the following:

- Fire is within ½ mile of a PSE Asset
- Fire is reported to be over 1 acre in size
- Evacuations have been declared
- Multiple alarm or high fire responses by responders (multiple suppression resources and fire aviation assets are being dispatched to the fire)
- Fire danger/fuel conditions are High or Extreme with high fire activity (high commitment of suppression resources to other incidents)
- Any other factor identified by the WLM, with rationale documented in the Incident Tracking Log per Section 7.1.

6.4.4 Moderate Potential Impact Level

A Moderate PIL is an uncontrolled fire on the landscape within approximately 2 miles of a PSE Asset that meets at least one of the following criteria:

- Wildfire has potential to move within 1 mile of a PSE Asset
- Continuous fuel exists between the fire and a PSE Asset
- Winds will promote fire growth toward a PSE Asset
- Fire is continuing to increase in size or is not controlled within the first 8 hours of being reported
- Fire danger/fuel conditions are Moderate or High, with light fire activity in the area (suppression resources are available)
- Any other factor identified by the WLM, with rationale documented in the Incident Tracking Log per Section 7.1.

6.4.5 Low Potential Impact Level

A Low PIL is any uncontrolled fire on the landscape that is highly unlikely to impact a PSE Asset. Examples include:

- Small Initial Attack wildfires (less than 1 acre) with apparent successful Initial Attack by fire-suppression resources
- Remote wildfires under a long-term management strategy
- Large wildfires in the service territory that are managed by a **Complex Incident Management Team** (**CIMT**) and are not expected to move toward or impact PSE Assets
- An uncontrolled fire more than 1 mile from a PSE Asset with low spread probability

6.4.6 Logging and Updates

- WLMs log all fires assigned a PIL in the Incident Tracking Log per Section 7.1.
- WLMs monitor all identified PILs and update them as the incident evolves.
- When the responding agency declares the fire as controlled, the WLM marks the incident "No Longer a Threat" in the Incident Tracking Log and notifies the ECC General Channel.

6.5 PSE Response to Potential Impact

Response actions correspond to the assigned PIL and the specific circumstances of the incident. Each PIL builds on the actions defined for the level below it; that is, Moderate actions are performed in addition to Low actions, and High actions are performed in addition to Moderate actions.

6.5.1 High Potential Impact Level – Response

In addition to actions for Moderate, the following steps take place:

1. The On-Duty WLM consults with System Operations to facilitate a Wildfire Operations Planning Call (see Section 6.5.4).
2. The On-Duty WLM ensures that all positions identified in Section 4 are advised at the appropriate level.
3. System Operations conducts PSE internal notifications following the Emergency Notification Matrix.
4. If available, the WLM reports to the **Incident Command Post** (**ICP**) and contacts the responding **Incident Commander** (**IC**)/**Incident Management Team** (**IMT**).
5. The WLM may assist with coordination between fire responders and the PSE EFR Supervisor/Troublemen on the following matters:
   - Access into fire area to conduct mitigation actions to prepare assets for fire impact
   - Requests for de-energization
   - PSE requests to fly **Unmanned Aircraft Systems** (**UAS**) or other aircraft
   - Post fire utility restoration work

6.5.2 Moderate Potential Impact Level – Response

In addition to the actions for Low, the following steps take place:

1. The On-Duty WLM may make direct contact with the responding suppression agency or dispatch center.
2. The On-Duty WLM may open a line of communication with the local **Electric First Response** (**EFR**) Supervisor.
3. The On-Duty WLM consults with System Operations to facilitate a Wildfire Operations Planning Call as needed (see Section 6.5.4).
4. The On-Duty WLM ensures that all positions identified in Section 4 are advised at the appropriate level.
5. The On-Duty WLM coordinates with the WRM Communications Team, which follows communications protocols to share information and updates with customers and other key stakeholders regarding PSE response.
6. The On-Duty WLM may respond to the incident vicinity and contact the on-scene fire response agency IC and share information about PSE Assets at risk to ensure that the IC is aware of values at risk of potential impact if utility service is interrupted.
7. The On-Duty WLM may use wildfire behavior spread modeling resources to estimate the timing of fire impact, which can inform the development of trigger points and management action points to take certain mitigation actions.

6.5.3 Low Potential Impact Level – Response

The WLMs and/or System Operations consider the following actions when a fire is identified as a potential impact, corresponding to the PIL and specific circumstances of the incident:

1. Provide updates in the “Real-time Operations & WLM Chat” and continue to monitor and provide updates when the PIL changes.
2. System Operations provides updates in the ECC General Channel.
3. Update the Incident Tracking Log per Section 7.1 for incidents meeting the criteria for Low or higher PILs.
4. Take additional action as warranted, including contacting the responding agency and/or responding to the incident to gather additional intelligence.

6.5.4 Wildfire Operations Planning Call Agenda

The On-Duty WLM facilitates the Wildfire Operations Planning Call. The agenda includes, at minimum, the following items:

- Storm Center/**Emergency Operations Center** (**EOC**) opening status
- De-energization plan
- Damage assessment
- Monitoring posture

6.6 Wildfires Impacting PSE Assets

If a fault has occurred in the fire vicinity, or if PSE Assets are reported as potentially being involved in the fire, the following actions take place:

1. System Operations and/or Load Office follow the System Operations Emergency Notification Matrix protocols and inform PSE Legal.
2. PSE Legal establishes clear lines of communication and responsibility. Certain actions of the response will be under the direction and coordination of the PSE Legal Team, following the PSE Legal Team's wildfire investigation protocol.

6.7 PSE Contracted Situational Awareness Tools

6.7.1 Watch Duty Application

The Watch Duty phone and desktop application provides notifications of incidents to users by county and provides near real-time updates on fire activity and location. Watch Duty includes information that can assist with threat assessment, including:

- Weather station information including the PSE weather network
- PSE GIS data for Electric, Gas, and Telecommunications Assets
- Alert West wildfire camera feeds
- Firefighting aircraft tracking
- Landowner information
- Pyrecast fire growth projections for active incidents

6.7.2 Technosylva FireRisk

Technosylva FireRisk software is used to inform daily operational decisions, as described in the PSE Critical Fire Weather Operations Procedure. It is also used to assess wildfire potential by looking at circuit level fire weather and fire behavior forecast information. FireRisk includes layers that may assist in threat assessment including:

- Fireguard – satellite heat detection fire spread monitoring
- Asset Risk Metrics such as Fire Potential Index and Initial Attack Assessment

6.7.3 PANO AI Cameras

Camera Alert Management

- PSE PANO AI Camera network continues to expand. PSE-hosted cameras are shared with fire agencies, dispatch centers, and other partners.
- Washington **Department of Natural Resources** (**DNR**) shares PANO AI Cameras with PSE as requested.
- PSE users can access all PSE cameras and select shared cameras and may use the zoom and other features as needed to gather intelligence.

Alerts

- PANO AI provides an automated fire detection service.
- The PANO AI operations center verifies all alerts pushed to customers through their operations center.
- PANO AI sends alerts via email and text to PSE-identified employees, fire response agencies, dispatch centers, and other partners.
- Individuals can manage their own notification settings within the application.

Alert Response

- During PSE Wildfire Season, PSE monitors all PANO AI Alert notifications and assesses potential impact of reported fires.
- Fire dispatch centers receive PANO AI notifications directly from PANO AI and are responsible for initiating fire responses associated with notifications. In cases where PANO AI fire reports are determined to have a potential impact to PSE Assets, PSE may contact the appropriate dispatch center to confirm that the report was received and that a fire response has been initiated.

7 Documentation & Records

7.1 Incident Tracking Log

The Incident Tracking Log captures the lifecycle of each wildfire incident that is assigned a PIL. The following requirements apply:

- The WLMs maintain the Incident Tracking Log in the 2026 Wildfire Incident Tracking Log folder and create a new log at the start of each calendar year.
- Incidents that do not meet the criteria for any PIL (Low, Moderate, or High) are not required to be logged.

The WLM records the following fields for each incident in the log:

- Host-agency fire name and number
- Report of fire date and time (HH:MM PT)
- PANO AI alert information
- Fire start location
- Fire cause information when available, as determined by a Wildland Fire Investigator
- Date and time stamp for each evolution of a PIL until the incident is deemed “No Longer a Threat”
- PSE Circuit(s)/Asset(s) threatened
- Technosylva asset risk metrics:
  - FPIC
  - FSP
  - FBI
  - ROS
- Tracking of contacts with response agencies

- Weather summary, including any active weather watches or warnings
- Comment log

8 References

8.1 Related Documents

Table 5 lists the documents related to this procedure and where to find them.

Table 5: Related Documents

Document Title	Location
Critical Fire Weather Operations Procedure	Critical Fire Weather Operations Procedure
PSE Wildfire Operating Plan	PSE Wildfire Operating Plan
PSE Wildfire Season Declaration Procedure	PSE Wildfire Season Declaration Procedure
PSE Wildfire Situation Briefing Template	2026 Wildfire Situation Briefings
Wildfire Incident Tracking Log	2026 Wildfire Incident Tracking Log Folder
PSE System Operations Emergency Notification Matrix	PSE System Operations Emergency Notification Matrix
Wildfire Liaison Manager Duty Roster	Wildfire Liaison Manager Duty Roster

8.2 PSE Internal Tools

- My Technosylva – Technosylva Fire Analysis tools
- Watch Duty (Wildfire Maps & Alerts) – Watch Duty Application
- PANO 360 – PANO AI Dashboard
- Western Weather Group – Weather-station data and dashboard
- RMA Dashboard – Risk Management Assistance dashboard

8.3 Public Information Sources

- Northwest Interagency Coordination Center (NWCC) – NIFC and NWCC forecast products
- National Weather Service – NOAA weather information
- WildWeb – WildCAD wildland-fire dispatch information
- Enterprise Geospatial Portal (EGP) – Federal interagency wildland-fire data and mapping portal

Appendix A – Contact List

Table 6 lists the phone numbers for key contacts referenced in this procedure.

> **NOTE** Contact numbers have been removed for this work sample.

Table 6: Contact List

Contact	Phone Number
Gas Dispatch	(xxx) xxx-xxxx
Load Office	(xxx) xxx-xxxx
WLM Duty Phone (24/7, On-Duty WLM)	(xxx) xxx-xxxx
System Operations	(xxx) xxx-xxxx
Telecommunications	(xxx) xxx-xxxx
PSE Legal Wildfire Hotline	(xxx) xxx-xxxx
Renewable Energy Generation	(xxx) xxx-xxxx

Appendix B – Revision History

Table 7 records the revision history of this procedure.

Table 7: Revision History

Revision Date	Revision Number	Summary of Changes	Changes Made By
07-10-2026	01	Initial release	D. Porter