SYNTHETIC - FICTIONAL OPERATIONS DOCUMENT - DEMONSTRATION ONLY

O&M Manual - Century Tywood J3 Corp BESS (synthetic)

Revision: A

System: Gotion Edge 760 battery energy storage system, outdoor pad

Inverter / PCS: 2 x Dynapower MPS125

Service contact: EQORE 24/7 operations desk (role-based, synthetic)

Set points and firmware: see controls schedule (synthetic)

Revision history

A 2026-10-01 Initial issue for commissioning

Section 4 - Startup, shutdown and isolation (synthetic)

4.2 Inverter isolation: stop each Dynapower MPS125 unit from the PCS controller, then open the AC disconnect next to the main distribution panel.

4.3 Restart only after BMS alarms are cleared by EQORE operations.

Section 6 - Maintenance schedule

Maintenance intervals are project-specific and set by EQORE and the owner. This synthetic manual does not state code-mandated frequencies.