SYNTHETIC - FICTIONAL OPERATIONS DOCUMENT - DEMONSTRATION ONLY

O&M Manual - Century Tywood J3 Corp BESS (synthetic)

Revision: B

System: Gotion Edge 760 battery energy storage system, outdoor pad

Inverter / PCS: 2 x Northbridge NPI-125

Service contact: EQORE 24/7 operations desk (role-based, synthetic)

Set points and firmware: see controls schedule (synthetic)

Revision history

A 2026-10-01 Initial issue for commissioning

B 2026-11-07 Inverter replacement 2 x Dynapower MPS125 to 2 x Northbridge NPI-125

Section 4 - Startup, shutdown and isolation (synthetic)

4.2 Inverter isolation: stop each Northbridge NPI-125 unit from the PCS controller, then open the AC disconnect next to the main distribution panel.

4.3 Restart only after BMS alarms are cleared by EQORE operations.

Section 6 - Maintenance schedule

Maintenance intervals are project-specific and set by EQORE and the owner. This synthetic manual does not state code-mandated frequencies.