SYNTHETIC SAMPLE - FICTIONAL MANUFACTURER - NOT FOR CONSTRUCTION

AC Switchgear / BESS Disconnect - Product Specification

Manufacturer: Northbridge Power Systems (fictional)

Document No.: NPS-SG-4000-SPEC

Revision: B

Date: 2026-11-06

Project: Century Tywood J3 Corp - 250 kW / 760 kWh BESS (synthetic)

Revision history

Rev A 2026-07-15 Initial release

Rev B 2026-11-06 Rated current increased to 600 A per updated inverter configuration

Electrical ratings are listed on page 2.

SYNTHETIC SAMPLE - FICTIONAL MANUFACTURER - NOT FOR CONSTRUCTION

Electrical Ratings

Manufacturer: Northbridge Power Systems

Model: NSG-4000

Rated voltage: 480 VAC, 3-phase, 4-wire

Rated continuous current: 600 A

Interrupting rating: 65 kA

Frequency: 60 Hz

Enclosure: NEMA 3R

Quantity: 1

Listing standard: UL 891

Ratings are synthetic and for software demonstration only.