SYNTHETIC SAMPLE - FICTIONAL MANUFACTURER - NOT FOR CONSTRUCTION

Interconnection Application - Electrical Interface Summary (synthetic)

Applicant: Century Tywood J3 Corp (synthetic)

Document No.: CTJ3-IX-002

Revision: B

Date: 2026-11-06

Point of interconnection

Utility service voltage: 13,200 V (Eversource primary)

Step-up transformer T1: 13,200 V primary / 600 V secondary

BESS disconnect NSG-4000 on transformer T1 secondary: 600 V

Export limit: 250 kW AC