SYNTHETIC SAMPLE - FICTIONAL MANUFACTURER - NOT FOR CONSTRUCTION

Engineered Plan Set - Century Tywood J3 Corp (synthetic)

Engineer of record: J. Doe, PE (fictional)

Revision: C

Date: 2026-11-02

AC System Size: 250 kW

DC System Size: 760 kWh

Revision block

A 2025-12-01 Issued for permit

B 2026-01-11 Change inverters to 2 x Dynapower MPS125

C 2026-11-02 Update ESS-13.0 line diagram for 600 VAC switchgear NSG-4000

SYNTHETIC SAMPLE - FICTIONAL MANUFACTURER - NOT FOR CONSTRUCTION

ESS-13.0 Single-Line Diagram Notes

AC disconnect: Northbridge NSG-4000

Rated voltage: 600 VAC

Rated continuous current: 400 A

Conductor insulation: 600 V rated (synthetic note)