SYNTHETIC SAMPLE - FICTIONAL MANUFACTURER - NOT FOR CONSTRUCTION

UL 9540A Test Method - Summary of Results

Manufacturer: Lumora Energy Storage (fictional)

Document No.: LES-9540A-SUM

Revision: A

Date: 2026-10-21

Project: Redwood Electronics Assembly (synthetic)

Results

Cell level: thermal runaway initiated at 212 C (synthetic)

Module level: no propagation beyond initiating module (synthetic)

Unit level: not required per module-level results (synthetic)

Listing standard: UL 9540A