

SDM630 DC

Din Rail Smart Energy Meter for Single and Three Phase Electrical Systems



USER MANUAL 2013 V1.1



Important Safety Information is contained in the Maintenance section. Familiarize yourself with this information before attempting installation or other procedures.

Symbols used in this document:



Risk of Danger: These instructions contain important safety information: Read them before starting installation or servicing of the equipment



Caution: Risk of Electric Shock



1 Introduction

This document provides operating, maintenance and installation instructions . The unit measures and displays the characteristics of single phase two wires(1p2w) , three phase three wires(3p3w,) and three phase four wires(3p4w) supplies, including voltage, frequency, current, power ,active and reactive energy, imported or exported. Energy is measured in terms of kWh, kVArh. Maximum demand current can be measured over preset periods of up to 60 minutes. In order to measure energy,the unit requires voltage and current inputs in addition to the supply required to power the product.

SDM630 DC supports max. 100A direct connection, saves the cost and avoid the trouble to connect external CTs, giving the unit a cost-effective and easy operation. Built-in interfaces provides pulse and Rs485 Modbus RTU outputs. Configuration is password protected.

1.1 Unit Characteristics

The Unit can measure and display:

- Line voltage and THD% (total harmonic distortion) of all phases
- Line Frequency
- Currents, Current demands and current THD% of all phases
- Power, maximum power demand and power factor
- Active energy imported and exported
- Reactive energy imported and exported

The unit has password-protected set-up screens for:

- Changing password
- Supply system selection 1p2w, 3p3w,3p4w
- Demand Interval Time(DIT)
- Reset for demand measurements
- Pulse output duration

Two pulse output indicates real-time energy measurement. An RS485 output allows remote monitoring from another display or a computer.

1.2 RS485 Serial - Modbus RTU

This uses an RS485 serial port with Modbus RTU protocol to provide a means of remotely monitoring and controlling the Unit


Set-up screens are provided for setting up the RS485 port. Refers to section 4.8

1.3 Pulse output

This provides two pulse outputs that clock up measured active and reactive energy. The constant of SDM630 DC type for active energy is 1000imp/kWh. The pulse width for active energy can be set from the set-up menu.




2. Start-up Screens



After a short delay, the screen will display active energy measurements.

3. Measurements

The buttons operate as follows:




3.1 Voltage and Current

Each successive pressing of the button selects a new range:

JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883 Web: www.eastrongroup.com Email: sales@eastrongroup.com






3.2 Frequency and Power factor and Demand

Each successive pressing of the




button selects a new range:



JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883






3.3 Power

Each successive pressing of the button select a new range:








3.4 Energy Measurements


Each successive pressing of the button selects a new range:



JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883





4. Set-up

To enter set-up mode, pressing the button for 3 seconds, until the password screen appears.



Setting up is password-protected so you must enter the correct password (default '1000') before processing. If an incorrect password is entered, the display will show: Err



JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883 Web: www.eastrongroup.com Email: sales@eastrongroup.com

Web: www.eastrongroup.com Email: sales@eastrongroup.com Add: No.1369. Chengnan Road, Nanhu District, Jiaxing City, Zhejiang, China 314001.




To exit setting-up mode, press repeatedly until the measurement screen is restored.

4.1 Set-up Entry Methods

Some menu items, such as password, require a four-digit number entry while others, such as supply system, require selection from a number of menu options.

4.1.1 Menu Option Selection

① Use the and buttons to select the required item from the menu shown in section 4.1. selection does not roll over between bottom and top of list



③ If an item flashes, then it can be adjusted by the and buttons. If not, there maybe a further layer.

(4) Having selected an option from the current layer, press to confirm your selection. The SET indicator will appear.

⑤Having completed a parameter setting, press to return to a higher menu level. The SET

indicator will be removed and you will be able to use the and buttons for further menu selection.

⑥ On completion of all set-up, press repeatedly until the measurement screen is restored.

4.1.2 Number Entry Procedure

When setting up the unit, some screens require the entering of a number. In particular, on entry to the setting up section, a password must be entered. Digits are set individually, from left to right. The procedure is as follows:

①the current digit to be set flashes and is set using the buttons

②Press to confirm each digit setting. The SET indicator appears after the last digit has been set.

③After setting the last digit, press to exit the number setting routine. The SET indicator will be removed.



4.2 Change password

4.2 Change password		
1	SE	Use the and password option to choose the change
2	SEŁ PRSS 1000	Press the to enter the change password routine. The new password screen will appear with the first digit flashing
3	5E	Use and to set the first digit and press to confirm your selection. The next digit will flash.
4	SEŁ PRSS 1 100	Repeat the procedure for the remaining three digits
5	SE	After setting the last digit, SET will show.
6	Press to exit the number setting routine and return to the Set-up menu. SET will be removed	


4.3 DIT Demand Integration Time

This sets the period in minutes over which the current and power readings are integrated for JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883




maximum demand measurement. The options are: off, 5, 10,15 30,60 minutes



4.4 Supply System


Use this section to set the type of power supply being monitored.



JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883






4.5 Pulse output

This option allows you to configure the pulse output. The output can be set to provide a pulse for a defined amount of energy active or reactive.


Use this section to set up the relay pulse output—Units: kWh, kVArh



JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883 Web: www.eastrongroup.com Email: sales@eastrongroup.com






4.5.1 Pulse rate

Use this to set the energy represented by each pulse. Rate can be set to 1 pulse per 0.01kWh/0.1kWh/10kWh/10kWh.




(It shows 1 impulse = 10kWh/kVArh)





4.5.2 Pulse Duration

The energy monitored can be active or reactive and the pulse width can be selected as 200, 100 or 60ms.



4.6 Communication

There is a RS485 port can be used for communication using Modbus RTU protocol. For Modbus RTU, parameters are selected from Front panel.


4.6.1 RS485 Address



(The range is from 0 to 247)



4.6.2 Baud Rate



4.6.3 Parity




JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883




On Completion of the entry procedure, press to confirm the setting and press to return to the main set up menu.

4.6.4 Stop bits



4.7 CLR

The meter provides a function to reset the maximum demand value of current and power.



JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883



3



to confirm the setting and press



to return to the main set up menu.

5 Specifications

5.1 Measured Parameters

The unit can monitor and display the following parameters of a single phase two wire(1p2w), three phase three wire(3p3w) or four phase four wire(3p4w) supply.

5.1.1 Voltage and Current

Phase to neutral voltages 100 to 289V a.c. (not for 3p3w supplies)

Voltages between phases 173 to 500V a.c. (3p supplies only)

Percentage total voltage harmonic distortion (THD%) for each phase to N (not for 3p3w supplies)

Percentage voltage THD% between phases (three phase supplies only)

Current THD% for each phase

5.1.2 Power factor and Frequency and Max. Demand

Frequency in Hz

Instantaneous power:

Power 0 to 3600 MW

Reactive Power 0 to 3600 MVAr

Volt-amps 0 to 3600 MVA

Maximum demanded power since last Demand reset Power factor

Maximum neutral demand current, since the last Demand reset (for three phase supplies only)

5.1.3 Energy Measurements

Imported active energy 0 to 9999999.9 kWh
Exported active energy 0 to 9999999.9 kWh
Imported reactive energy 0 to 9999999.9 kVArh
Exported reactive energy 0 to 9999999.9 kVArh
Total active energy 0 to 9999999.9 kWh
Total reactive energy 0 to 9999999.9 kVArh

5.2 Measured Inputs

Voltage inputs through 4-way fixed connector with 2.5mm² stranded wire capacity. single phase two wire(1p2w), three phase three wire(3p3w) or four phase four wire(3p4w) unbalanced. Line frequency measured from L1 voltage or L3 voltage.

Three current inputs (six physical terminals) with 2.5mm² stranded wire capacity for connection of external CTs. Nominal rated input current 5A or 1A a.c. Rms.

5.3 Accuracy

Voltage 0.5% of range maximum

Current 0⋅5% of nominal

JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883 Web: www.eastrongroup.com Email: sales@eastrongroup.com



Frequency 0.2% of mid-frequency Power factor 1% of unity (0.01)

Active power (W) ±1% of range maximum

Reactive power (VAr) ±2% of range maximum

Apparent power (VA) ±1% of range maximum

Active energy (Wh) Class 1 IEC 62053-21

Reactive energy (VARh) ±2% of range maximum

Total harmonic distortion 1% up to 31st harmonic

Temperature co-efficient Voltage and current = 0.013%/°C typical

Active energy = 0.018%/°C, typical

Response time to step input 1s, typical, to >99% of final reading, at 50 Hz.

5.4 Interfaces for External Monitoring

Three interfaces are provided:

- an RS-485 communication channel that can be programmed for Modbus RTU protocol
- an relay output indicating real-time measured energy.(configurable)
- An pulse output 1000lmp/kWh

The Modbus configuration (Baud rate etc.) and the pulse relay output assignments (kW/kVArh, import/export etc.) are configured through the Set-up screens.

5.4.1 Pulse Relay Output

The pulse relay output can be set to generate pulses to represent kWh or kVArh.

Rate can be set to generate 1 pulse per:

0.01 = 10 Wh/VArh

0.1 = 100 Wh/VArh

1 = 1 kWh/kVArh

10 = 10 kWh/kVArh

100 = 100 kWh/kVArh

Pulse width 200/100/60 ms.

Relay Rating 240V ac 50mA

5.4.2 RS485 Output for Modbus RTU

For Modbus RTU, the following RS485 communication parameters can be configured from the Set-up menu:

Baud rate 2400, 4800, ,9600, ,19200, 38400

Parity none/odd/even

Stop bits 1 or 2

RS485 network address nnn – 3-digit number, 1 to 247

Modbus™ Word order Hi/Lo byte order is set automatically to normal or reverse. It cannot be configured from the set-up menu.

JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883 Web: www.eastrongroup.com Email: sales@eastrongroup.com



5.5 Reference Conditions of Influence Quantities

Influence Quantities are variables that affect measurement errors to a minor degree. Accuracy is verified under nominal value (within the specified tolerance) of these conditions.

Ambient temperature 23°C ±1°C

Input waveform 50 or 60Hz ±2%

Input waveform Sinusoidal (distortion factor < 0.005)

Auxiliary supply voltage Nominal ±1%
Auxiliary supply frequency Nominal ±1%

Auxiliary supply waveform (if AC) Sinusoidal (distortion factor < 0.05)

Magnetic field of external origin Terrestrial flux

5.6 Environment

Operating temperature $-25^{\circ}\text{C to } +55^{\circ}\text{C*}$ Storage temperature $-40^{\circ}\text{C to } +70^{\circ}\text{C*}$

Relative humidity 0 to 90%, non-condensing

Altitude Up to 2000m Warm up time 1 minute

Vibration 10Hz to 50Hz, IEC 60068-2-6, 2g

Shock 30g in 3 planes

*Maximum operating and storage temperatures are in the context of typical daily and seasonal variation.

5.7 Mechanics


DIN rail dimensions 72 x 94.5 mm (WxH) per DIN 43880 (SDM630CT)


76 x 100 mm (WxH) per DIN 43880 (SDM630DC)

Mounting DIN rail (DIN 43880)
Sealing IP20 (minimum)

Material Self-extinguishing UL 94 V-0

6 Dimensions






JIAXING EASTRON ELECTRONIC INSTRUMENTS CO.,LTD.

TEL:0086-573-83698881/83698882 FAX: 0086-573-83698883 Web: www.eastrongroup.com Email: sales@eastrongroup.com




7. Installation

three phase four wires



three phase three wires



single phase two wires

