

Integration of the FINS Protocol into the Open-Source HMI System FUXA for Omron PLCs

DENNY CHRISNANDA
Computer Science Department
Binus Online Learning
Bina Nusantara University
denny.chrisnanda@binus.ac.id

FRANS SEBASTIAN
Computer Science Department
Binus Online Learning
Bina Nusantara University
frans.sebastian@binus.ac.id

GILANG HANSAGITA
Computer Science Department
Binus Online Learning
Bina Nusantara University
gilang.hansagita@binus.ac.id

Abstract

Industrial plants today need control systems that can adapt quickly, run efficiently, and fit smoothly into existing production lines. Programmable Logic Controllers (PLCs) are still the heart of most automation setups because they deliver real-time performance and almost never fail. At PT XYZ we rely heavily on Omron PLCs, which talk to the rest of the system through the FINS protocol. The problem is that almost all open-source HMI platforms—including the very lightweight and fully web-based FUXA—do not understand FINS out of the box. That makes them practically unusable in factories full of Omron equipment. This work solves that gap by designing and adding a dedicated FINS communication module to FUXA. The project followed the usual steps: reviewing what others have done, digging into the details of the FINS protocol, writing the actual code, and then testing everything in a real setup. The tests showed that the new module can reliably read and write data to/from the PLC with very little delay, and the screens in FUXA now show exactly what is really happening on the factory floor. The result is a completely free, fully customizable, browser-based HMI that speaks directly to Omron PLCs without any extra gateway or middleware. This development makes modern open-source tools viable in Omron-dominated plants and helps companies move faster with their digital-transformation projects.

Keywords—FINS protocol, FUXA, human-machine interface, industrial automation, Omron PLC

1. INTRODUCTION

Programmable Logic Controllers (PLCs) are the backbone of most of automated production line—they are dependable, react in real time, and it is pretty easy to program them [1]. Here at PT. XYZ, a global automotive parts maker, the factory floor is basically use Omron devices the most: company records show that more than 90% of our machines are controlled by Omron PLCs. When a single brand has that kind of dominance, everything else in the automation stack has to compromise with it.

That is where Human–Machine Interfaces (HMIs) come in. Operators need interface that show what is happening, let them change the settings, and give an alarm when something goes wrong [2]. While commercial HMI/SCADA solutions offer mature features for monitoring, analytics, and alarm management that reduce downtime and promote quality assurance [3], they often impose licensing costs, restrict customization, and expose organizations to vendor lock-in [4, 5]. That is why a lot of plants have started looking seriously at open-source alternatives that cost

nothing upfront and can be modified however we want [6].

One of the options that keeps coming up is FUXA. It is lightweight, completely web-based, built on Node.js and Angular, and already support usual mainstream protocols—Modbus, OPC UA, MQTT, etc. [7, 8, 9]. You can run it on a Raspberry Pi or in the cloud, which is perfect for remote monitoring and Industry 4.0 projects. The only problem is FUXA does not support the FINS protocol. FINS—which runs over both UDP and TCP—is still the go-to protocol in pretty much any plant full of Omron gear, mainly because it lets you address memory areas in a very flexible way that makes real PLC-to-HMI communication fast and painless [10, 11]. This limitation is the main roadblock when trying to hook up FUXA with the Omron PLCs that PT. XYZ run on the production lines.

This work tackles the issue head-on by answering two practical questions: (1) How to properly add FINS support to an open-source HMIs like FUXA so it works just as good and reliable as the built-in protocol? (2) How to make sure the read and write commands over FINS are stable with no dropped

packets or stale data, so that the UI provide real-time visualization? To get there, we designed and built a dedicated FINS communication module straight into FUXA. The goals were straightforward: (1) Integrate FINS inside FUXA with the same level of reliability and features provided by Modbus and the other built-in protocols, and (2) validate stable data read/write operations and accurate real-time visualization on the user interface. This proposed solution aims to offer a flexible, cost-effective, and vendor-independent HMI alternative suitable for digital transformation initiatives in manufacturing environments.

2. RELATED WORKS

Open-source HMI/SCADA system have gained increasing attention as alternative to proprietary industrial automation platform, specially due to their flexibility, extensibility, and lower deployment cost. Several study have explored the design and implementation of open-source HMI/SCADA architecture across different industrial domain.

Uddin et al. [12] develop an open-source SCADA system for a solar-powered reverse osmosis plant using Node-RED, Grafana, and InfluxDB. Their work show that low-cost and community-deployable SCADA architecture can be effectively implemented using open source technology. Similarly, Omidi et al. [13] propose a modular Node-RED-based SCADA system for hybrid renewable energy generation. Their architecture illustrate the suitability of lightweight web technology for real-time monitoring with minimal computational resource.

In the power system domain, Almas et al. [14] integrate open-source SCADA with Phasor Measurement Units (PMUs) to evaluate real-time system performance using the DNP3 protocol. Their result highlight protocol constraint such as polling limitation, which have implication for SCADA performance in large-scale grid.

In the field of industrial cybersecurity, Salazar et al. [15] introduce ICSNet, a hybrid-interaction honeynet incorporating multiple industrial protocol including Modbus TCP, IEC-104, and Ethernet/IP. Notably, their implementation use FUXA HMI as part of the visualization layer, showing FUXA's potential applicability beyond traditional HMI use case.

Other study have focused on the use of web-based SCADA system in smaller-scale automation environment. Hazdi et al. [16] implement a web-based SCADA system for home automation using PLCs and

OPC, demonstrate the viability of web technology for real-time domestic application. Additionally, Thushara [7] introduce the FUXA web-based SCADA tool and discuss its deployment on edge device using Modbus and MQTT, reinforce its role as a modern, extensible HMI/SCADA platform.

Across these work, open-source SCADA implementation consistently rely on widely supported protocol such as Modbus, OPC UA, or MQTT. However, none of the reviewed study address the Factory Interface Network Service (FINS) protocol, which remain widely used in Omron PLC-based industrial environment. This absence indicate a significant research gap in open-source HMI/SCADA system that support FINS communication.

Therefore, the present study contribute by developing and integrating a FINS communication module into the FUXA HMI platform. This fill an identified gap in open-source industrial automation research and enable direct interoperability with Omron PLCs, which are prevalent in manufacturing system such as those at PT XYZ.

3. METHODOLOGY

3.1. Research Overview

This work uses a hands-on, iterative development approach to expand the open-source HMI platform FUXA with native support for the Omron FINS protocol. The project progressed through the usual phases—requirements analysis, system design, implementation, and evaluation stages—to make sure the new FINS module performs on par with the platform's existing drivers, particularly Modbus TCP. The overall development workflow is shown in Figure 1.

3.2. System Architecture

The resulting system is built around three core layers, which are: (1) the physical PLCs, (2) the Node.js-based backend that handles all communication, and (3) the Angular frontend responsible for the actual HMI visualization. The Omron FINS support is added as a new device driver called *DeviceFins*, running entirely in FUXA's backend. This driver takes care of the low-level socket communication (UDP or TCP) and performs read/write operations on typical Omron memory areas such as DM, CIO, and W.

Data acquisition works by having the backend periodically poll the PLC—or react to specific triggers—pulling values from the configured memory




Figure 1: Research workflow for FINS protocol implementation in FUXA

addresses. These values are then propagated to the frontend through the system's existing event emitter (`device-value:changed`) to update the HMI interface in real time. A simplified overview of this architecture is shown in Figure 2.

3.3. Development Tools and Environment

The implementation and testing were conducted using this environment:

- **Programming Languages:** JavaScript (Node.js v18 LTS).
- **HMI Platform:** FUXA v1.2.13 (open-source web-based SCADA system).
- **PLC Device:** Omron CJ2M CPU34.




Figure 2: Architecture of the developed HMI-PLC communication system

- **Operating System:** Windows 11.
- **Network Analysis Tools:** Wireshark.

3.4. Implementation Procedure

The development process was carried out in the following key phases:

1. **Protocol analysis and requirements analysis:** A detailed examination of the Omron FINS protocol was conducted, focusing on command structure, memory address read and write methods, and communication flow using the official Omron FINS Command Reference Manual.
2. **Design and implementation of the device driver:** The `DeviceFins`, a dedicated driver class, was developed within the existing FUXA backend architecture. This class encapsulates connection lifecycle management (TCP/UDP), read and write operations to standard memory areas, automatic reconnection logic with exponential back-off, timeout handling, and emission of value-change events.
3. **Frontend Integration:** The administrative web interface of FUXA was enhanced by introducing device-specific configuration fields—including PLC last three digits IP address (DA1), PC node

address (SA1), IP address, port, and network mode—ensuring seamless integration with the platform’s existing device management workflow.

4. **Testing and Debugging:** The implementation was rigorously tested through a combination of unit tests and real-world deployment on physical CJ2M CPU34 to confirm functional correctness, stability, and performance under various network conditions.

This structured, iterative approach ensured that the new FINS driver achieved full functional equivalence with the platform’s established communication modules.

3.5. Testing Method

To assess the performance of the implemented FINS driver, a dedicated load-testing script was developed in Node.js. This script issued 1,000 successive read requests targeting memory area D100 on the Omron PLC, while maintaining a concurrency level of ten simultaneous connections. The key metrics recorded throughout the experiment were:

- Average read/write latency (ms)
- Success rate of communication (%)
- CPU and memory usage
- Stability of reconnection handling during simulated disconnections

The results of these measurements were analyzed statistically to evaluate whether the implemented connector meets the performance characteristics comparable to Modbus TCP communication.

3.6. Evaluation Criteria

The evaluation focused on two primary objectives linear with the research goals:

1. **Functional Equivalence:** Verifying that the implemented FINS connector supports key HMI functions—connectivity, data reading, data writing, and visualization—equivalent to existing Modbus modules.
2. **Stability and Responsiveness:** Measuring whether the FINS communication remains stable under repetitive load and can maintain real-time data visualization without significant latency or data loss.

4. RESULTS AND DISCUSSION

4.1. Evaluation of the omron-fins Library

The study began with a stress test of the omron-fins Node.js library to confirm the capability of FINS communication (read/write) between a PC and an Omron CJ2M PLC via UDP. The experimental setup is summarized in Table 1.

Table 1: *omron-fins trial environment configuration*

Component	Specification
PLC	Omron CJ2M-CPU34
Host Client	PC(i7-11th Gen, 16GB RAM, Win 11)
IP PLC	192.168.0.1
IP Client	192.168.0.234
Protocol	FINS/UDP (Port 9600)
Library	omron-fins (Node.js)
Runtime	Node.js v18 LTS

The Omron FINS library was installed via npm and validated using a stress test script that throws 1 000 read requests to address D100 with a concurrency level of 10. The resulting network traces then captured using Wireshark to confirm frame structure and response codes.

Key observations from the library tests are:

- Captured responses consistently contained Command Code 0101 (Memory Area Read) and Response Code 0000 (no error), with incrementing Service IDs indicating unique matching responses.
- The library handled read operations reliably under the configured stress: average response latency was observed below 50 ms and the library exhibited correct framing behavior according to Omron FINS specification.
- No installation or dependency errors were encountered during setup; the library is suitable as a communication basis for further integration into the HMI system.

4.2. System Configuration and Integration

The FINS connector was integrated into the FUXA server under the directory server/runtime/devices/fins. The deployed testbed topology comprises one Omron CJ2M PLC, one PC acting as HMI server, and a tablet as the client (see Fig. 3). Typical connector parameters are listed in Table 2.




Figure 3: System topology of the FUXA HMI with the FINS connector

Parameter	Nilai Contoh
Alamat IP PLC	192.168.11.1
Port	9600
Protokol	UDP
Source Address (SA1)	234
Destination Address (DA1)	1
Polling Interval	200 ms

Table 2: FINS connection configuration parameters

After connector installation, initial verification was performed by issuing a single read to memory address D100. Successful read/response without timeout confirmed that the connector was operational.

4.3. Implemented Functionality

The implemented FINS connector provides the following capabilities:

1. Transport-level connectivity (UDP and TCP) using the `omron-fins` library.
2. Periodic polling per device with the connector only reporting `connect-ok` after a successful read cycle.
3. Write (set) operations initiated from the UI and executed on the PLC in real time.

4. Event emission to FUXA runtime (device-value:changed, device-status:changed, device-error).
5. Frontend integration: device configuration form and tag editing dialog for FINS-specific parameters (SA1, DA1, memory area, address, data type).

Representative UI screens is shown in Figs. 4.




Figure 4: UI Result — Device Settings: configuration form for FINS device (IP, port, SA1, DA1, protocol).

After integrating the FINS connector module into both the backend and the HMI interface, a realtime communication test was conducted to verify bidirectional data transfer between the HMI system and the Omron PLC. Fig. 5 presents the HMI interface during the execution of the test.




Figure 5: HMI demonstration connected to the PLC in realtime.

The HMI display includes several key elements:

- **Realtime trend (Oil Temperature Sensor):** Visualizes temperature values read from the PLC via the FINS protocol in real-time.
- **Slider and input field:** allow writing updated values to PLC memory addresses and change value in a specified memory via slider.
- **Motor speed gauge:** represents PLC variables using an analog-style visualization, demonstrating responsive data updates.

Experimental results show that PLC-to-HMI data updates occur within <100 ms, indicating that the

implemented FINS connector provides low-latency and stable realtime communication.

In addition to realtime monitoring and control, the system featured an alarm mechanism to detect abnormal industrial process conditions that can make safety issues or warning. Fig. 6 shows an alarm triggered when the oil temperature exceeds the maximum threshold defined in the PLC.




Figure 6: Realtime alarm display when oil temperature exceeds the safety threshold.

The alarm subsystem operate in realtime with the following characteristic:

- **Continuous monitoring:** PLC tag value are periodically sampled and compared with predefined threshold.
- **Alarm visualization:** triggered alarm appear in red with *High-High* priority to highlight critical condition.
- **Status synchronization:** alarm state (active, acknowledged, cleared) automatically update based on backend data.
- **FINS-based event detection:** each alarm directly correspond to PLC tags transmitted through the FINS UDP protocol, ensure fast and accurate detection.

Testing confirms that the system detect high-temperature events and displays alarms with a delay of less than 200,ms after the PLC value change. These results shows that the developed FINS connector reliably support both data exchange and realtime event notification within the HMI system.

4.4. Performance Evaluation

Performance evaluation comprised automated technical tests and a small-scale usability assessment. Results are summarized in Table 3.

Table 3: Summary of Technical Evaluation Results

Metric	Target	Observed
Read/write latency (avg.)	≤ 200 ms	12 ms
Communication success rate	$\geq 95\%$	99%
Server CPU usage	$\leq 30\%$	2%
Server memory usage	≤ 500 MB	462 MB
Alarm detection time	≤ 200 ms	1000 ms (formal)
Application startup time	≤ 10 s	3.14 s

4.4.1. Read/Write Latency

Read/write latency was measured by issuing a write to memory (e.g., W1) and immediately performing a read-back on the same address. The average latency across 100 repeated trial were **12,ms**, well below the 200,ms target. This result show that the integrated connector and FUXA frontend can achieve low round-trip times in the laboratory network condition used.

4.4.2. Communication Success Rate

The automated stress test program stresstest.js recorded **990 successful responses** and **10 failures** (99% success). Failures were predominantly timeouts visible in the Wireshark traces as requests without corresponding reply. Likely causes include UDP packet loss on the link, temporary PLC processing backlog, or aggressive scheduling from the test host. No systematic FINS framing errors were observed in successful captures.

4.4.3. Resource Utilization

System monitoring during load tests showed low CPU utilization (approx. 2–3%) and moderate memory consumption (backend ≈ 91 MB, frontend ≈ 371 MB). These figures indicate the Node.js + Angular architecture can operate efficiently on the selected PC hardware for the tested workload.

4.4.4. Alarm Detection Time

The alarm detection time is measured from the moment the triggering condition in the PLC become true until the alarm indicator appear on the HMI interface. The observed detection time is approximately 1000,ms,

which is significantly slower than the KPI target of 200,ms. This delay happen because the minimum polling interval used by the HMI system to evaluate alarm conditions and generate alarm events is 1,s, as illustrated in Fig. 7.




Figure 7: HMI system alarm detection interval limitation.

4.4.5. Application Startup Time

Measured application startup time averaged **3.14 s**, which satisfies the ≤ 10 s requirement and indicates acceptable initialization performance for the integrated system.

4.5. Usability Evaluation

A small usability survey (10 respondent: operators and technician) using a 5-point Likert scale assess configuration ease, clarity of status display, perceived responsiveness, UI consistency, and overall satisfaction. Average score (scale 1–5) were:

- Configuration ease: 4.2
- Clarity of status: 4.1
- Responsiveness: 4.3
- UI consistency: 4.0
- Overall satisfaction: 4.3

Qualitative feedback highlighted appreciation for clear connection-status indicators and requests for a more prominent *Check Connection* control and a simplified logging mode for non-technical troubleshooting.

subsectionDiscussion The integration of a FINS connector into FUXA using the `omron-fins` library produce a functional, low-latency HMI capable of reliable read/write operation with Omron CJ2M PLCs under laboratory condition. Important takeaway points are:

- **Reliability:** Communication success rate (99

- **Performance:** Read/write latencies (12,ms) and low resource usage indicate the approach is suitable for responsive HMI operation on modest hardware.
- **Alarm timeliness:** The primary area needing improvement is alarm detection latency due to the current polling-based approach. Mitigation strategy include polling prioritization, reducing polling intervals carefully, or exploring event-driven mechanism if supported by the PLC network stack.
- **Robustness:** Observed timeout under high-stress scenario suggest adding retry backoff, packet pacing, and enhanced logging for root-cause analysis in noisy network.
- **Usability:** End-user feedback is positive; additional UX improvement and operator-focused logging would increase practical adoption.

5. CONCLUSION

This research successful implemented and evaluated the integration of the Factory Interface Network Service (FINS) protocol into the open-source Human–Machine Interface (HMI) system FUXA. The development introduce a new backend connector module (DeviceFins) written in Node.js and an extended frontend configuration interface in Angular, enable direct and seamless communication between FUXA and Omron PLCs. The connector support both UDP and TCP modes, allow read, write, and polling operation to be executed without the need for proprietary middleware or vendor-locked HMI system. As a result, FUXA become one of the first open-source HMI systems to natively support the Omron FINS protocol.

Based on experimental test, the implemented system show reliable and stable performance. The communication success rate reach 99%, and the average read/write latency was measured at 12 ms, well below the 200 ms KPI target. System resource consumption stay efficient, with average CPU usage of 2% and memory consumption of 462 MB during load testing. The HMI startup time average 3.14 s, indicate a responsive system suitable for small- to medium-scale production environment. However, the alarm detection delay reach approximately 1000 ms due to the internal one-second polling interval of the FUXA system. This limitation show that the alarm subsystem still rely on a time-driven polling approach rather than a fully event-driven mechanism.

Overall, the integration of FINS into FUXA successful fulfilled the two primary research objective:

(1) enable the HMI system to communicate with Omron PLCs using the FINS protocol with functionality equivalent to existing Modbus support, and (2) improve the stability and visualization of data exchange on the HMI interface. Future research should focus on optimize the alarm handling mechanism through event-driven or interrupt-based approach, enhance network security with TLS or VPN, and expand multi-protocol interoperability. Additionally, open publication of the connector's source code, testing script, and dataset is encouraged to promote reproducibility and community-driven advancement in open-source industrial automation system.

REFERENCES

- [1] Mohsin Ali Koondhar dkk. "The Role of PLC in Automation, Industry, and Education: A Review". In: *Pakistan Journal of Engineering Technology and Science* 11.2 (2023), pp. 22–31. doi: 10.22555/pjets.v11i2.975.
- [2] S. Mujawar. "Introduction to Human–Machine Interface". In: *Handbook/Book on Human–Machine Interfaces*. Chapter 1; Accessed via Wiley Online Library. Wiley, 2023. URL: <https://onlinelibrary.wiley.com/doi/abs/10.1002/9781394200344.ch1> (visited on 09/26/2025).
- [3] Jyotika Sawal. "SCADA Market Size, Share, Trend Analysis by 2033". <https://www.emergenresearch.com/industry-report/scada-market>. Report ID: ER_004544. May 2025. URL: https://www.emergenresearch.com/industry-report/scada-market?srsltid=AfmB0orSdQPJM_IH0PBeriQx0KYb023L8TR4JyuIII93M6iZJ4ojmwiu.
- [4] Alisyn Gularte. "Open vs. Proprietary: Choosing the Right SCADA System for Your Solar Plant". Blog post, Nor-Cal Controls. Accessed: 2025-09-12. Feb. 2025. URL: <https://blog.norcalcontrols.net/open-vs.-proprietary-choosing-the-right-scada-system-for-your-solar-plant>.
- [5] Bakul Banthia. *Understanding the Risks of Cloud Vendor Lock-In*. Disaster Recovery Journal. Tessell. Aug. 13, 2024. URL: https://drj.com/industry_news/understanding-the-risks-of-cloud-vendor-lock-in/.
- [6] McKinsey & Company. "Is industrial automation headed for a tipping point?" In: *McKinsey & Company Insights* (2023). URL: <https://www.mckinsey.com/capabilities/operations/our-insights/is-industrial-automation-headed-for-a-tipping-point>.
- [7] Kasun Thushara. "Getting Start with FUXA - Web Based SCADA Tool". Accessed: 2025-07-16. 2024. URL: https://wiki.seeedstudio.com/reTerminal-DM_intro_FUXA/.
- [8] Davide Ancona dkk. "Towards Runtime Monitoring of Node.js and Its Application to the Internet of Things". In: *arXiv preprint arXiv:1802.01790* (2018). doi: 10.48550/arXiv.1802.01790. URL: <https://arxiv.org/abs/1802.01790>.
- [9] Joshua D. Scarsbrook, Mark Utting, and Ryan K. L. Ko. "TypeScript's Evolution: An Analysis of Feature Adoption Over Time". In: *arXiv preprint arXiv:2303.09802* (2023). URL: <https://arxiv.org/abs/2303.09802>.
- [10] Peter Humaj. "Communication with Omron FINS". Blog post on Ipesoft D2000. Apr. 2021. URL: <https://d2000.ipesoft.com/blog/communication-omron-fins/>.
- [11] Brijesh Joshi. "A Study of the Various Communication Protocols Used in PLC Systems: Modbus, Profibus, Ethernet/IP and Their Implementations, Evolution and Comparative Analysis". In: *International Research Journal of Modernization in Engineering Technology and Science (IRJMETS)* 6.4 (Apr. 2024). doi: 10.56726/IRJMETS52882. URL: https://www.irjmets.com/uploadedfiles/paper/issue_4_april_2024/52882/final/fin_irjmets1713198034.pdf.
- [12] Sheikh Usman Uddin, Mirza Jabbar Aziz Baig, and Mohammad Tariq Iqbal. "Design and Implementation of an Open-Source SCADA System for a Community Solar-Powered Reverse Osmosis System". In: *Sensors* 22.24 (2022), p. 9631. doi: 10.3390/s22249631. URL: <https://www.mdpi.com/1424-8220/22/24/9631>.
- [13] Mohammad Omid, Majid Salehifar, and Amir Mohammadi. "Design and Implementation of an Open Source SCADA System for Monitoring a Hybrid Renewable Power System".

- In: *Energies* 16.5 (2023), p. 2229. DOI: 10.3390/en16052229. URL: <https://www.mdpi.com/1996-1073/16/5/2229>.
- [14] M. S. Almas and L. Vanfretti. “Open Source SCADA Implementation and PMU Integration”. In: *IEEE PES General Meeting* (2014).
- [15] Luis Salazar dkk. “ICSNet: A Hybrid-Interaction Honeynet for Industrial Control Systems”. In: *Proceedings of the Sixth Workshop on CPS&IoT Security and Privacy (CPSIoTSec’24)*. Salt Lake City, UT, USA: ACM, 2024, pp. 1–12. ISBN: 979-8-4007-1244-9. DOI: 10.1145/3690134.3694813. URL: <https://doi.org/10.1145/3690134.3694813>.
- [16] Robby Hazdi, Muhammad Fadli, and Yusril Maulana. “Perancangan SCADA pada Sistem Otomatisasi Rumah”. In: *eProceedings of Applied Science* 3.2 (2017). Universitas Telkom, pp. 1099–1106. URL: <https://openlibrarypublications.telkomuniversity.ac.id/index.php/appliedscience/article/view/4046>.