

SILVER ASPEN REGIONAL MEDICAL CAMPUS

OWNER: Silver Aspen Regional Medical Campus

PROJECT MANUAL - VOLUME 1 OF 3. Solicitation SARMC-CP-2026-03.

PROJECT: Central Plant Upgrade

SITE: Castle Rock, CO

BID DATE: October 16, 2026 at 2:00 PM MT

PRE-BID WALK: September 30, 2026 at 7:30 AM

NOTICE TO BIDDERS: This project manual is issued subject to addenda. Dates appearing on this cover sheet are as-issued and may be superseded by addendum. Refer to Part 4 for all issued addenda.

PART 1 - SUMMARY OF WORK

Replacement and expansion of the central utility plant: demolition of two steam-to-hot-water converters, three new condensing hot water boilers, replacement of the primary chilled water pumping assembly, new hydronic distribution piping, and complete replacement of the plant control system.

Base Bid trades are mechanical (HVAC), process and hydronic piping, and automatic temperature controls.

ALTERNATE NO. 1 is a separately priced add alternate covering standpipe and fire suppression riser modifications in the plant penthouse. Alternate No. 1 is NOT part of the Base Bid. Bidders who do not hold a fire protection license may bid the Base Bid and decline Alternate No. 1 without prejudice.

PART 2 - COMMERCIAL TERMS

ENGINEER ESTIMATE: \$1,800,000 to \$2,100,000

CONSTRUCTION START: March 15, 2027. SUBSTANTIAL COMPLETION: November 30, 2027.

Bonding: bid bond 5% of the total bid; performance bond and payment bond each 100% of the contract price. Commercial general liability \$2,000,000 per occurrence and \$4,000,000 aggregate.

PART 3 - SCHEDULE OF QUANTITIES

SPEC	DESCRIPTION	UNIT	BASE BID	ALT 1
			QTY	QTY
23 52 16	Condensing hot water boiler	EA	3	0
23 21 23	Primary CHW pump, 60 HP	EA	4	0
23 21 13	Hydronic piping, welded	LF	5,820	0
23 09 23	DDC plant controller	LS	1	0
21 12 00	Standpipe riser modification	EA	0	6
21 13 16	Wet pipe sprinkler relocation	EA	0	4

NOTE: The ALT 1 QTY column applies to Alternate No. 1 only. Items showing a BASE BID QTY of 0 are excluded from the Base Bid scope. Spec sections 21 12 00 and 21 13 16 are fire protection and are carried under Alternate No. 1 exclusively.

PART 4 - ADDENDA ISSUED

ADDENDUM NO. 1, issued September 4, 2026. Item 1.1: boiler manufacturer list amended to add one approved manufacturer. No change to the bid date results from this addendum.

ADDENDUM NO. 2, issued September 25, 2026.

Item 2.1: THE BID DATE IS EXTENDED. Bids are now due November 6, 2026 at 2:00 PM MT. The bid date of October 16, 2026 shown on the cover sheet is superseded and shall not be relied upon.

Item 2.2: The pre-bid walk-through held September 30, 2026 is not rescheduled. Firms that attended remain eligible to bid.

Item 2.3: Alternate No. 1 remains a separately priced add alternate. Several bidders asked whether the standpipe work is included in the Base Bid. It is not.