

SILVER ASPEN REGIONAL MEDICAL CAMPUS CENTRAL PLANT UPGRADE PROJECT MANUAL - VOLUME 1 OF 3

SOLICITATION	SARMC-CP-2026-03
OWNER	Silver Aspen Regional Medical Campus
SITE	Castle Rock, CO
ISSUED	August 14, 2026
BID DATE	October 16, 2026 at 2:00 PM MT
PRE-BID WALK	September 30, 2026 at 7:30 AM

NOTICE TO BIDDERS: This project manual is issued subject to addenda. Bidders are responsible for confirming they have received and incorporated all addenda prior to submission. Dates appearing on this cover sheet and in page footers are as-issued and may be superseded by addendum. Refer to Volume 1, Part 4 for all issued addenda.

The Owner reserves the right to reject any and all bids and to waive informalities in the bidding.

PART 1 - SUMMARY OF WORK

The Project consists of the replacement and expansion of the central utility plant serving the Silver Aspen Regional Medical Campus. Base Bid work includes demolition of two existing steam-to-hot-water converters, installation of three new condensing hot water boilers, replacement of the primary chilled water pumping assembly, new underground and above-grade hydronic distribution piping between the plant and Buildings A and C, and complete replacement of the plant control system including graphics and integration to the campus building automation network.

Base Bid trades are mechanical (HVAC), process and hydronic piping, and automatic temperature controls. The Contractor shall self-perform not less than thirty percent (30%) of the Base Bid work.

ALTERNATE NO. 1 is a separately priced add alternate covering modifications to the standpipe and fire suppression risers in the plant penthouse. Alternate No. 1 is NOT part of the Base Bid and shall be priced separately on the bid form. The Owner may elect not to award Alternate No. 1. Bidders who do not hold a fire protection license may bid the Base Bid and decline Alternate No. 1 without prejudice.

PART 2 - COMMERCIAL TERMS

ENGINEER ESTIMATE	\$1,800,000 to \$2,100,000
CONSTRUCTION START	March 15, 2027
SUBSTANTIAL COMPLETION	November 30, 2027
BID BOND	5% of base bid
PERFORMANCE BOND	100% of contract sum
PAYMENT BOND	100% of contract sum
GENERAL LIABILITY	\$5,000,000 per occurrence

PART 3 - SCHEDULE OF QUANTITIES

			BASE BID	ALT 1
SPEC	DESCRIPTION	UNIT	QTY	QTY

23 52 16	Condensing hot water boiler, 4,000 MBH	EA	3	0
23 21 23	Primary CHW pump, 60 HP, base mounted	EA	4	0
23 21 13	Hydronic piping, welded, 8 in. and larger	LF	2,180	0
23 21 13	Hydronic piping, welded, 6 in. and smaller	LF	3,640	0
23 09 23	DDC plant controller and graphics package	LS	1	0
23 05 93	TAB, complete plant	LS	1	0
21 12 00	Standpipe riser modification, penthouse	EA	0	6
			<-- ALT 1 ONLY	
21 13 16	Wet pipe sprinkler head relocation, plant penthouse	EA	0	altered under ALT 1

NOTE: The ALT 1 QTY column applies to Alternate No. 1 only. Items showing a BASE BID QTY of 0 are excluded from the Base Bid scope. Spec sections 21 12 00 and 21 13 16 are fire protection and are carried under Alternate No. 1 exclusively.

PART 4 - ADDENDA ISSUED

ADDENDUM NO. 1 - Issued September 4, 2026

Item 1.1: Specification Section 23 52 16, boiler manufacturer list is amended to add one additional approved manufacturer. Item 1.2: Drawing M-201, revise pipe routing at column line D-4 as shown on attached sketch SK-M-01. No change to the bid date results from this addendum.

ADDENDUM NO. 2 - Issued September 25, 2026

Item 2.1: THE BID DATE IS EXTENDED. Bids are now due November 6, 2026 at 2:00 PM MT. The bid date of October 16, 2026 shown on the cover sheet and in the page footers of this project manual is superseded and shall not be relied upon.

Item 2.2: The pre-bid walk-through held September 30, 2026 is not rescheduled. Firms that attended the September 30 walk-through remain eligible to bid. No additional walk-through will be held.

Item 2.3: Alternate No. 1 remains a separately priced add alternate. Several bidders inquired whether the standpipe work is included in the Base Bid. It is not.

END OF ADDENDA. Bidders shall acknowledge receipt of Addenda 1 and 2 on the bid form. Failure to acknowledge may render the bid non-responsive.