


2 SINGLE LINE DIAGRAM  
E1 SCALE:

| NEW PANEL 'E-208'                                   |      |     |     |   |     |     |      |                   |  |
|---|------|-----|-----|---|-----|-----|------|-------------------|--|
| 120/240V, 2 PHASE, 3 WIRE, 30 CIRCUIT, C/W 125A BUS |      |     |     |   |     |     |      |                   |  |
| DESCRIPTION   | LOAD | BKR | CCT |   | CCT | BKR | LOAD | DESCRIPTION       |  |
| ADDITION RECEPTACLES                                | x    | 15A | 1   | • | 2   | 15A | x    | FRIDGE            |  |
| KITCHEN COUNTER                                     | x    | 15A | 3   | • | 4   |     | x    | HWT               |  |
| KITCHEN COUNTER                                     | x    | 15A | 5   | • | 6   | 30A | x    |                   |  |
| LAUNDRY COUNTER                                     | x    | 15A | 7   | • | 8   | 15A | x    | POWER DOOR OPENER |  |
| HAND DRYER  | x    | 15A | 9   | • | 10  | 15A | x    | EF-1              |  |
| BATHROOM RECEPTACLE                                 | x    | 15A | 11  | • | 12  | 30A | x    | DRYER             |  |
| WASHING MACHINE                                     | x    | 15A | 13  | • | 14  |     |      |                   |  |
| FF-1 + BB-1   | x    | 20A | 15  | • | 16  | 30A | x    | FFH-2             |  |
|   |      |     | 17  | • | 18  |     |      |                   |  |
| BB-2 + BB-3   | x    | 15A | 19  | • | 20  | 15A | x    | EXIT SIGNS        |  |
|   |      |     | 21  | • | 22  | 15A | x    | ETP-1             |  |
| HRV-1   | x    | 15A | 23  | • | 24  | 15A | x    | PANEL RECEPTACLE  |  |
| SPARE   | x    | 15A | 25  | • | 26  | 15A | x    | SPARE             |  |
| SPARE   | x    | 15A | 27  | • | 28  | 15A | x    | SPARE             |  |
| SPARE   | x    | 15A | 29  | • | 30  | 15A | x    | SPARE             |  |



1 POWER LAYOUT  
E1 SCALE:

1/4" = 1'-0"

LEGEND

- RECEPTACLE
- DRYER RECEPTACLE
- COUNTER MOUNT
- WEATHER RATED
- GROUND FAULT INTERRUPTER
- DIRECT CONNECTION
- DISCONNECT
- PANEL
- EXISTING TO RELOCATE
- EXISTING TO REMOVE
- EXISTING TO REMAIN
- FAN FORCED HEATER
- BASEBOARD HEATER


NOTES:

- SUPPLY NEW PANEL E-208 FROM EXISTING 100A SPARE BREAKER IN PANEL E-206.
- HEATERS PROVIDED BY MECHANICAL INSTALLED BY ELECTRICAL.

| 0   | ISSUED FOR PERMIT | 06/18/2025 | DRM |
|-----|-------------------|------------|-----|
| NO. | DESCRIPTION       | DATE       | BY  |

REVISIONS

Kirkland Engineering Ltd BCIN: 28857



NOT TO BE USED FOR CONSTRUCTION UNLESS SIGNED BY THE ENGINEER.

THIS DRAWING IS AN INSTRUMENT OF PROFESSIONAL SERVICE FOR USE EXCLUSIVELY ON THIS PROJECT. RE-USE OF ANY PORTION OF THIS DOCUMENT IS PROHIBITED.

Copyright 2025 Kirkland Engineering Ltd



570 Water Street  
Peterborough, Ontario  
p. (705) 745-2831  
f. (705) 741-1526  
www.kirklandeng.com


KIRKLAND ENGINEERING LTD.

PROJECT  
KINMOUNT FIRE  
STATION

24 Majestic St.  
Kinmount, ON

TITLE  
POWER


| DESIGN   | DRM  | SCALE AS NOTED |
|----------|------|----------------|
| DRAWN    | AJM  | DWG NO.        |
| CHECKED  | DRM  |                |
| APPROVED | DRM  |                |
| PROJECT  | 7529 |                |



|   |   |                            |  |
|---|---|----------------------------|--|
| A | 4' LED STRIP LIGHT, 3000 LUMEN, 18.5 W 4000K, 120-277V, 80CRI, 0-10V DIMMER TO 10%, MATTE WHITE FINISH. | LITHONIA OR APPROVED EQUAL | CLX L48 3000LM SEF FDL MVOLT GZ10 40K 80CRI WH |
| B | 6" ROUND RECESSED LED DOWNLIGHT FOR WET LOCATION, 1300 LUMEN 16 W 3500K, 120V, MATTE WHITE, 120V        | LITHONIA OR APPROVED EQUAL | WF6 DREG B ALO20 SSW5 90CRI MW M6              |
| C | 8"x11" LED WALL PACK, 2900 LUMEN, 24 W 3000K, 120-277V, C/W PHOTOCELL, BLACK FINISH.                    | LITHONIA OR APPROVED EQUAL | WPX2 LED 30K MVOLT PE DDLXD                    |

|  |  |          |            |
|--|--|----------|------------|
|  | COMBO EXIT AND EMERGENCY LIGHT FIXTURE. C/W RUNNING MAN EXIT, ARROWS AS INDICATED 150W, 24W LAMPS. | LUMACELL | LAC SERIES |
|  | RUNNING MAN EXIT SIGN, SELF POWERED 120V.  | LUMACELL | LA SERIES  |

1 LIGHTING AND FIRE LAYOUT




- LEGEND
- \$ LIGHT SWITCH
  - \$ A AUTO ON/OFF OCCUPANCY SENSOR SWITCH
  - EMERGENCY LIGHT BATTERY PACK 72W C/W 2 4W LED HEADS
  - 4W LED REMOTE HEAD

- NOTES:
1. ADD LIGHTS AND EMERGENCY LIGHTS IN ADDITION TO NEW 15A CIRCUITS IN GENERATOR PANEL.
  2. NO ELECTRICAL UNLESS RATED FOR WET AREA, SHALL BE WITHIN 1M OF THE SHOWER WET AREA.
  3. PROVIDE POWER FOR NEW OUTDOOR WALL PACK FROM EXISTING OUTDOOR LIGHTING CIRCUIT.
  4. PROVIDE POWER FOR EXIT SIGNS

|     |                   |            |     |
|-----|-------------------|------------|-----|
| 0   | ISSUED FOR PERMIT | 06/18/2025 | DRM |
| NO. | DESCRIPTION       | DATE       | BY  |

REVISIONS

Kirkland Engineering Ltd BCIN: 28857




NOT TO BE USED FOR CONSTRUCTION UNLESS SIGNED BY THE ENGINEER.

THIS DRAWING IS AN INSTRUMENT OF PROFESSIONAL SERVICE FOR USE EXCLUSIVELY ON THIS PROJECT. RE-USE OF ANY PORTION OF THIS DOCUMENT IS PROHIBITED.

Copyright 2025 Kirkland Engineering Ltd



|                              |      |                |
|------------------------------|------|----------------|
| PROJECT                      |      |                |
| KINMOUNT FIRE STATION        |      |                |
| 24 Majestic St. Kinmount, ON |      |                |
| TITLE                        |      |                |
| LIGHTING AND FIRE            |      |                |
| DESIGN                       | DRM  | SCALE AS NOTED |
| DRAWN                        | AJM  | DWG NO.        |
| CHECKED                      | DRM  | E2             |
| APPROVED                     | DRM  |                |
| PROJECT                      | 7529 |                |



① DEMOLITION LAYOUT  
E3 SCALE: 1 0 3 6  
1/4" = 1'-0"


- LEGEND
- ⦿ RECEPTACLE
  - ⦿ DRYER RECEPTACLE
  - WP WEATHER RATED
  - GFI GROUND FAULT INTERRUPTER
  - DIRECT CONNECTION
  - DISCONNECT
  - ▨ PANEL
  - R EXISTING TO RELOCATE
  - X EXISTING TO REMOVE
  - E EXISTING TO REMAIN

- NOTES:
- EXISTING POWER, LIGHTING, AND CONTROL TO REMAIN UNLESS NOTED OTHERWISE.
  - EXISTING WASHROOM TO BE REMOVED DISCONNECT POWER IN WALLS TO BE DEMOLISHED, PULL WIRE BACK TO PANEL AND MAKE SAFE.

| 0   | ISSUED FOR PERMIT | 06/18/2025 | DRM |
|-----|-------------------|------------|-----|
| NO. | DESCRIPTION       | DATE       | BY  |

REVISIONS

Kirkland Engineering Ltd BCIN: 28857



NOT TO BE USED FOR CONSTRUCTION UNLESS SIGNED BY THE ENGINEER.

THIS DRAWING IS AN INSTRUMENT OF PROFESSIONAL SERVICE FOR USE EXCLUSIVELY ON THIS PROJECT. RE-USE OF ANY PORTION OF THIS DOCUMENT IS PROHIBITED.

Copyright 2025 Kirkland Engineering Ltd



PROJECT  
**KINMOUNT FIRE STATION**

24 Majestic St.  
Kinmount, ON

TITLE  
**DEMOLITION**

|          |      |                |
|----------|------|----------------|
| DESIGN   | DRM  | SCALE AS NOTED |
| DRAWN    | AJM  | DWG NO.        |
| CHECKED  | DRM  | <b>E3</b>      |
| APPROVED | DRM  |                |
| PROJECT  | 7529 |                |

SPECIFICATION

1. GENERAL CONDITIONS

1. DO ALL WORK IN ACCORDANCE WITH ONTARIO ELECTRICAL SAFETY CODE, CURRENT EDITION, BASED UPON THE CANADIAN ELECTRICAL CODE, PART I, CSA STANDARD C22.1, AND ALL BULLETINS TO DATE.

2. SCOPE OF WORK

2.1 PROVIDE ALL MATERIALS EQUIPMENT AND LABOUR TO PROVIDE A COMPLETE OPERATING INSTALATION AS DESIGNATED IN THIS SPECIFICATION AND AS INDICATED ON THE DRAWINGS EXCEPT WHERE OTHERWISE NOTED.  
2.2 THE SCOPE OF WORK INCLUDES, BUT IS NOT LIMITED TO, SUPPLY AND INSTALLATION OF THE FOLLOWING ITEMS:  
2.2.1 POWER DISTRIBUTION.  
2.2.2 LIGHTING  
2.2.3 EMERGENCY LIGHTING AND EXIT SIGNAGE.  
2.2.4 FEEDERS AND OVER CURRENT PROTECTION FOR MECHANICAL EQUIPMENT.  
2.2.5 MAIN SERVICE BOARD C/W METERING SYSTEM.  
2.2.6 MOTOR STARTERS FOR MECHANICAL EQUIPMENT.  
2.2.7 EMPTY RACEWAY SYSTEM FOR TELEPHONE AND CABLE TV SYSTEMS  
2.2.8 FIRE ALARM SYSTEM

3. GENERAL

3.1 ALL MATERIALS SHALL BE CSA APPROVED, NEW AND SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.

4. IDENTIFICATION

4.1 WIRES TO BE COLORED AS FOLLOWS: 120V AC NEUTRAL WHITE  
12V DC BLUE.  
120V AC SWITCHED, BLACK OR RED.  
120V AC LINE, BLACK.

4.2 PROVIDE LAMICOID LABELS FOR NEW OR REVISED BREAKER PANELS, SPLITTERS AND DISCONNECTS.  
4.3 PROVIDE TYPED CIRCUIT LISTING FOR NEW OR REVISED BREAKER PANELS.

5. EXAMINATION OF SITE

5.1 PRIOR TO SUBMITTING TENDERS, THIS CONTRACTOR SHALL VISIT THE SITE TO DETERMINE ALL EXISTING CONDITIONS.  
5.2 ALLOW FOR ALL COSTS ASSOCIATED WITH COMPLETING THE WORK OF DIVISION 16 IN ACCORDANCE WITH EXISTING SITE AND BUILDING CONDITIONS.  
5.3 NO ALLOWANCE FOR EXTRA PAYMENTS TO THE CONTRACTOR WILL BE MADE BY THE OWNER FOR FAILING TO VISIT AND EXAMINE SITE CONDITIONS.

6. INSURANCE

6.1 SUB-CONTRACTOR SHALL MAINTAIN SUCH INSURANCE AS WILL FULLY PROTECT BOTH THE OWNER AND THE SUB-CONTRACTOR FROM ANY AND ALL CLAIMS UNDER THE WORKMEN'S COMPENSATION ACT, ALSO ALL INSURANCE AS NOTED WITHIN ARCHITECTURAL GENERAL CONDITIONS.

7. AS BUILT DRAWINGS

7.1 MAINTAIN A SEPARATE SET OF WHITE PRINTS ON THE SITE AND NOTE ALL CHANGES AND DEVIATIONS FROM THE ORIGINAL DESIGN. TWO SETS OF THESE DRAWINGS SHOWING ALL AS-BUILT CONDITIONS SHALL BE FORWARDED TO THE ARCHITECT AT THE COMPLETION OF THIS CONTRACT AND BEFORE APPLYING FOR FINAL PAYMENT.

8. REVISIONS AND EXTRAS

8.1 ADDITIONAL MONEY OVER THE CONTRACT PRICE SHALL NOT BE PAID UNLESS AN APPROVED CHANGE ORDER IS ISSUED BY THE ARCHITECT. CLAIMS FOR EXTRAS SHALL BE SUBMITTED WITH A COMPLETE BREAKDOWN OF MATERIAL, LABOUR , HOURLY RATES, ETC.

9. CLEAN UP

9.1 BE RESPONSIBLE TO KEEP THE AREA CLEAN AT ALL TIMES AND TO PERIODICALLY REMOVE ALL DEBRIS.

10. CUTTING AND PATCHING

10.1 ALL CUTTING AND PATCHING REQUIRED FOR THE WORK OF THIS DIVISION SHALL BE CARRIED OUT BY THIS DIVISION. NO CHASING BLOCK WORK WILL BE ALLOWED. CUTTING AND DRILLING SHALL BE PERFORMED IN A MANNER SO AS TO CAUSE LITTLE DAMAGE. BE RESPONSIBLE AND PAY FOR ANY DAMAGE TO THE BUILDING INCURRED BY WORK OF THIS DIVISION.

11. COORDINATION

11.1 BE RESPONSIBLE TO COORDINATE THE INSTALLATION OF EQUIPMENT, CONDUIT WORK, LIGHTING FIXTURES, ETC. WITH OTHER TRADES AND THE OWNER'S REPRESENTATIVE PRIOR TO THE ACTUAL INSTALLATION.

12. RESPONSIBILITY

12.1 BE RESPONSIBLE FOR ELECTRICAL WORK UNTIL THE COMPLETION AND FINAL ACCEPTANCE, FOR REPLACING ANY ITEM THAT MAY BE DEFECTIVE, DAMAGED, LOST OR STOLEN WITHOUT ADDITIONAL COST TO THE OWNER OR DELAY TO THE COMPLETION OF THE PROJECT.

13. WIRING MATERIALS AND METHODS

13.1 USE MATERIALS AND METHODS APPROVED BY ONTARIO ELECTRICAL CODE FOR USE IN NON-COMBUSTIBLE CONSTRUCTION.  
13.2 ALL BUILDING WIRE SHALL BE COPPER TYPE RW90-XLPE WHERE APPROPRIATE EXCEPT WHERE OTHERWISE NOTED.  
13.3 USE MINIMUM OF #12 AWG FOR BRANCH CIRCUIT WIRING.  
13.4 ARMORED CABLE TYPE AC90 (BX) WITH INTERLOCKING ARMOUR FABRICATED FROM ALUMINUM STRIP C/W COPPER INSULATED CONDUCTORS, SIZE AS INDICATED, TO BE USED IN CONCEALED WALL AND CEILING CAVITIES.

14. SHOP DRAWINGS AND PRODUCT DATA

14.1 'SHOP DRAWINGS' MEANS DRAWINGS, DIAGRAMS, ILLUSTRATIONS, SCHEDULES, PERFORMANCE, CHARTS, BROCHURES, AND OTHER DATA WHICH ARE TO BE PROVIDED BY CONTRACTOR TO ILLUSTRATE DETAILS OF A PORTION OF THE WORK.  
14.2 INDICATE MATERIALS METHODS OF CONSTRUCTION AND ATTACHMENT OR ANCHORAGE, NECESSARY FOR COMPLETION OF WORK.  
14.3 ADJUSTMENTS MADE ON SHOP DRAWINGS BY OWNER OR ENGINEER ARE NOT INTENDED TO CHANGE CONTRACT PRICE.  
14.4 MAKE CHANGES IN SHOP DRAWINGS AS OWNER OR ENGINEER MAY REQUIRE.  
14.5 SUBMIT 6 HARD COPIES, OR 1 HIGH QUALITY ELECTRONIC COPY OF PRODUCT DATA SHEETS OR BROCHURES FOR LIGHTING FIXTURES, EMERGENCY LIGHTING, EXIT SIGNS, MAIN SERVICE BOARD, MOTOR STARTERS, FIRE ALARM EQUIPMENT AND POWER DISTRIBUTION EQUIPMENT.  
14.6 PROVIDE 2 MAINTENANCE MANUALS COMPLETE WITH WARRANTEE, CERTIFICATE OF INSPECTION BY ESA, FIRE ALARM VERIFICATION REPORT, AND COPY OF ALL PRODUCT LITERATURE AND MAINTENANCE INFORMATION.

15. SYSTEMS DEMONSTRATION

15.1 PRIOR TO FINAL INSPECTION DEMONSTRATE OPERATION OF EACH SYSTEM TO OWNER AND ENGINEER.  
15.2 INSTRUCT PERSONNEL IN OPERATION ADJUSTMENT AND MAINTENANCE OF EQUIPMENT AND SYSTEMS, USING PROVIDED OPERATION AND MAINTENANCE DATA AS BASIS FOR INSTRUCTION.

16. PERMITS, FEES AND INSPECTION

16.1 SUBMIT TO ELECTRICAL SAFETY AUTHORITY NECESSARY NUMBER OF DRAWINGS AND SPECIFICATIONS FOR EXAMINATION AND APPROVAL PRIOR TO COMMENCEMENT OF WORK.  
16.2 PAY ASSOCIATED FEES, INCLUDING EQUIPMENT APPROVAL INSPECTION FEE.  
16.3 OWNER WILL PROVIDE DRAWINGS AND SPECIFICATIONS REQUIRED BY ELECTRICAL SAFETY AUTHORITY AT NO COST.  
16.4 NOTIFY ENGINEER OF CHANGES REQUIRED BY ELECTRICAL SAFETY AUTHORITY PRIOR TO MAKING CHANGES.  
16.5 FURNISH CERTIFICATES OF ACCEPTANCE FROM ELECTRICAL SAFETY AUTHORITY AND AUTHORITIES HAVING JURISDICTION OF COMPLETION OF WORK TO ENGINEER.

17. THIRD PARTY TESTING

17.1 THE CONTRACTOR IS RESPONSIBLE TO PROVIDE THIRD PARTY TESTING OF THE LIGHTING SYSTEM IN ACCORDANCE WITH ASHRAE STANDARD 90.1-2010, SECTION 9.4.4 FUNCTIONAL TESTING. THE PARTY RESPONSIBLE FOR THE FUNCTIONAL TESTING SHALL NOT BE DIRECTLY INVOLVED IN EITHER THE DESIGN OR CONSTRUCTION OF THE PROJECT AND SHALL PROVIDE DOCUMENTATION CERTIFYING THAT THE INSTALLED LIGHTING CONTROLS MEET OR EXCEED ALL DOCUMENTED PERFORMANCE CRITERIA.  
17.2 LIGHTING CONTROL DEVICES AND CONTROL SYSTEMS SHALL BE TESTED TO ENSURE THAT CONTROL HARDWARE AND SOFTWARE ARE CALIBRATED, ADJUSTED, PROGRAMMED AND IN PROPER WORKING CONDITION IN ACCORDANCE WITH THE CONSTRUCTION DOCUMENTS AND MANUFACTURER'S INSTALLATION INSTRUCTIONS.  
17.3 WHEN SENSORS, TIME SWITCHES, PROGRAMMABLE SCHEDULE CONTROLS OR PHOTOSENSORS ARE INSTALLED, THE FOLLOWING PROCEDURES SHALL BE PERFORMED:  
17.2.1 CONFIRM THAT THE PLACEMENT, SENSITIVITY AND TIME-OUT ADJUSTMENTS FOR OCCUPANT SENSORS YIELD ACCEPTABLE PERFORMANCE, LIGHTS TURN OFF ONLY AFTER SPACE IS VACATED. WHERE AN AUTO-ON MODE HAS BEEN SELECTED, LIGHTS DO NOT TURN ON UNLESS SPACE IS OCCUPIED.  
17.2.2 CONFIRM THAT THE TIME SWITCHES AND PROGRAMMABLE SCHEDULE CONTROLS ARE PROGRAMMED CORRECTLY TO TURN THE LIGHTS OFF.  
17.2.3 WHERE DAYLIGHT HARVESTING CAPABILITY HAS BEEN INSTALLED, CONFIRM THAT PHOTOSENSOR CONTROLS REDUCE ELECTRIC LIGHT LEVELS BASED ON THE AMOUNT OF USABLE DAYLIGHT IN THE SPACE AS SPECIFIED.

18. WARRANTY

18.1 AFTER THE WORK IS COMPLETED, GIVE A WRITTEN GUARANTEE FOR ONE YEAR COVERING WORKMANSHIP AND MATERIALS. REPAIR OR REPLACE, WITHOUT EXPENSE TO THE OWNER, ANY DEFECTS DUE TO WORKMANSHIP OR MATERIALS WHICH IN THE OWNER'S OPINION, ARE NOT DUE TO MISUSE OR NEGLECT.

19. CONDUITS AND RACEWAYS

19.1 RIGID GALVANIZED STEEL CONDUIT TO BE USED WHERE SUBJECT TO MECHANICAL DAMAGE.  
19.2 ELECTRICAL METALLIC TUBING (EMT) WITH COUPLINGS TO BE USED EXCEPT WHERE EMBEDDED IN CONCRETE OR SUBJECT TO UNDUE MOISTURE OR MECHANICAL DAMAGE.  
19.3 RIGID PVC CONDUIT WHERE EMBEDDED IN CONCRETE OR BELOW GRADE.  
19.4 FLEXIBLE ALUMINUM CONDUIT WITH WEATHERPROOF COVERING TO BE USED WHERE SUBJECT TO VIBRATION OR STRAIN RELIEF.  
19.5 CONDUITS IN FINISHED AREA SHALL BE CONCEALED.  
19.6 CONDUITS SHALL BE MINIMUM 1/2".

20. INSTALLATION OF OUTLETS

20.1 THE DRAWINGS SHOW APPROXIMATE LOCATION OF OUTLETS, EXACT LOCATION SHALL BE COORDINATED ON THE SITE WITH OTHER TRADES, ARCHITECTURAL DRAWINGS, ETC. OUTLETS INACCURATELY LOCATED SHALL BE READJUSTED OR RELOCATED AT THE CONTRACTOR'S EXPENSE. UNLESS OTHERWISE NOTED ON THE DRAWING LOCATE OUTLETS AS FOLLOWS:  
20.1.1 RECEPTACLES, TELEPHONE AND DATA OUTLETS (15.7") 400MM ABOVE FINISHED FLOOR.  
20.1.2 OUTLETS OVER COUNTER (45") 1143MM ABOVE FLOOR OR CO-ORDINATION.  
20.1.3 OUTLETS IN MECHANICAL, ELECTRICAL AND TELEPHONE ROOMS (48") 1220MM ABOVE FLOOR.  
20.1.4 LIGHT SWITCHES NOT LESS THAN (35.4") 900MM AND NOT MORE THAN (43") 1100MM ABOVE FLOOR.  
20.2 RACEWAYS SHALL BE EMT UNLESS OTHERWISE NOTED.  
20.3 SUPPORT OUTLET BOXES, JUNCTION BOXES, CONDUIT AND THE LIKE.

21. RECEPTACLES

21.1 IVORY DUPLEX RECEPTACLES CSA TYPE 5-15R, 125V OR CSA 5-20A 20A, T-SLOT, U GROUND.  
21.2 IVORY COVER PLATES.  
21.3 INSTALL RECEPTACLES WITH GROUND POSITION UP.  
21.4 IF RECEPTACLE IS SURFACE MOUNTED USE CAST BOX AND STAINLESS STEEL COVER PLATE.

22. EXCAVATION, BACKFILL AND CONCRETE WORK

22.1 WHERE REQUIRED FOR UNDERGROUND SERVICE (POWER OR TELEPHONE) THE EXCAVATION, BACKFILL AND CONCRETE WORK SHALL BE BY THE GENERAL CONTRACTOR. THE ELECTRICAL TRADE SHALL SUPERVISE THE PROCESSING OF CONCRETE AROUND DUCT BANK, TO ENSURE THEY ARE FREE FROM VOIDS SHALL ADVISE THE GENERAL CONTRACTOR OF THIS WORK FOR INCLUSION IN THE GENERAL CONTRACTOR'S TENDER PRICE.

23. MECHANICAL EQUIPMENT

23.1 PROVIDE ALL CONDUIT, WIRING, SPLITTERS, OUTLET BOXES AND DISCONNECT SWITCHES AS SHOWN. ALL MOTORS, STARTERS AND CONTROL WIRING PROVIDED BY MECHANICAL DIVISION UNLESS OTHERWISE NOTED. INSTALL ALL STARTERS AND WIRE COMPLETE. ALL EXTERIOR DISCONNECTS TO BE WEATHERPROOF.  
23.2 THE ELECTRICAL CONTRACTOR SHALL VERIFY ALL MOTOR CONNECTION FOR PROPER PHASE ROTATION, WHERE APPLICABLE.

24. SWITCHES

24.1 20A, 120V, SINGLE POLE SWITCHES  
24.2 IVORY TOGGLE  
24.3 IVORY COVER PLATES.  
24.4 IF SWITCH IS SURFACE MOUNTED USE CAST BOX.

25. EQUIPMENT FOR EMERGENCY LIGHTING

25.1 SUPPLY VOLTAGE: 120V AC  
25.2 OUTPUT VOLTAGE: 12V DC.  
25.3 OPERATIONS TIME: 30 MINUTES MINIMUM.  
25.4 CABINET: SUITABLE FOR DIRECT OR SHELF MOUNTING TO WALL C/W KNOCKOUTS FOR CONDUIT, REMOVABLE OR HINGED FRONT PANEL FOR EASY ACCESS TO BATTERIES.

26. TELEPHONE CABLE T.V./COMPUTER RACEWAY SYSTEM (ETC.)

26.1 PROVIDE EMPTY CONDUIT SYSTEMS FOR TELEPHONE AS SHOWN ON THE DRAWINGS.  
26.2 WHERE CONDUITS NOT SHOWN ON DRAWINGS PROVIDE CONDUITS FROM OUTLET BOX TO ACCESSIBLE CEILING SPACE.  
26.3 THIS CONTRACTOR SHALL PROVIDE AND/OR COORDINATE THE SIZE, TYPE AND LOCATION OF THE INCOMING TELEPHONE CONDUIT WITH THE TELEPHONE COMPANY OR THE BUILDING OWNER.  
26.4 RACEWAYS (OTHER THAN INCOMING) SHALL BE EMT.  
26.5 A MAXIMUM OF 2 LONG RADIUS 90 DEGREE BENDS SHALL BE PROVIDED BETWEEN PULL BOXES.  
26.6 A WIRE SHALL BE PULLED AND LEFT IN EACH CONDUIT RUN TO FACILITATOR THE FUTURE PULLING OF WIRES.  
26.7 PROVIDE NECESSARY BOXES AND ASSOCIATED COVER PLATES AS REQUIRED FOR THE ABOVE SYSTEMS.

27. TEMPORARY SERVICES

27.1 IN CASES OF NEW CONSTRUCTION, ALL TEMPORARY ELECTRICAL SERVICES, AS REQUIRED, SHALL BE PROVIDED BY THE GENERAL CONTRACTOR AS SPECIFIED IN THE ARCHITECTURAL/STRUCTURAL CONTRACT DOCUMENTATION.  
27.2 PROVIDE TEMPORARY GENERAL LIGHTING THROUGHOUT CONSTRUCTION SITE. LIGHTING STRINGS WITH LAMPS AT SUITABLE CENTERS TO CONFORM TO CONSTRUCTION STANDARDS AND ALL AUTHORITIES HAVING JURISDICTION.  
27.3 PROVIDE TEMPORARY GENERAL POWER SUPPLIES WITH RECEPTACLES FOR ALL TRADES AS DIRECTED BY THE GENERAL CONTRACTOR.  
27.4 MAINTAIN THE TEMPORARY FACILITIES IN GOOD REPAIR AND SAFE WORKING CONDITION THROUGHOUT THE DURATION OF CONSTRUCTION PROJECT.  
27.5 REMOVE AT THE END OF PROJECT THE ABOVE NOTED TEMPORARY SYSTEM.

28. FIRE ALARM


28.1 PROVIDE ALL MATERIAL EQUIPMENT AND LABOUR REQUIRED FOR A COMPLETE AND ADEQUATE INSTALLATION OF THE FIRE ALARM SYSTEM AS SHOWN ON THE DRAWINGS AND AS DESCRIBED HEREIN. MATCH EXISTING SYSTEM.  
28.2 SHOP DRAWINGS FOR THE COMPLETE SYSTEM, INCLUDING LAYOUT OF EQUIPMENT, ZONING AND COMPLETE WIRING DIAGRAMS FOR CONNECTIONS AND DEVICES, AND METHODS OR OPERATION SHALL BE SUBMITTED.  
28.3 ALL COMPONENTS OF THE SYSTEM, ITS INSTALLATION AND THE SYSTEM AS A WHOLE SHALL BE ULC LISTED AND LABELED AND SHALL MEET THE REQUIREMENTS OF ALL AUTHORITIES HAVING JURISDICTION OF THE APPLICATION. THE ENTIRE INSTALLATION SHALL BE CARRIED OUT IN ACCORDANCE WITH CAN. ULC S524 AND SHALL BE VERIFIED IN ACCORDANCE WITH CAN. ULC S537.  
28.4 BREAKER FOR FIRE ALARM CONTROL PANEL AND BOOSTER PANELS TO BE LOCKABLE AND CLEARLY IDENTIFIED BY PAINTING IT RED.  
28.5 PROVIDE SEPARATE CIRCUITS FROM CONTROL PANEL TO EACH ZONE OF INITIATING DEVICES.  
28.6 SINGLE STAGE OPERATION.  
28.7 ACTUATION OF ANY SINGLE OPERATION DEVICE TO INITIATE BUILDING EVACUATION ALARM DEVICES TO OPERATE IN TEMPORAL CODE. CONFIRM WITH LOCAL AUTHORITY.  
28.8 ZONE OF ALARM DEVICE TO BE INDICATED ON CONTROL PANEL.  
28.9 POWER SUPPLY IS 120VAC, 60HZ INPUT, 24VDC OUTPUT FROM RECTIFIER TO OPERATE ALARM AND SIGNAL CIRCUITS WITH STANDBY POWER GELL CELL BATTERIES. MINIMUM EXPECTED LIFE OF FOUR YEARS, SIZED IN ACCORDANCE WITH NBC.  
28.10 PROVIDE FIRE ALARM SYSTEM RISER DIAGRAM IN CONTROL PANEL.  
28.11 ARRANGE AND PAY FOR ON-SITE LECTURE AND DEMONSTRATION BY FIRE ALARM EQUIPMENT MANUFACTURER TO TRAIN OPERATIONAL PERSONNEL IN USE AND MAINTENANCE OF FIRE ALARM SYSTEM.  
28.12 COORDINATE WITH MANUFACTURER TO PROVIDE STROBE LIGHT SYNCHRONIZATION MODULES AS REQUIRED.  
28.13 PROVIDE SUFFICIENT OUTPUT MODULES IN FIRE ALARM CONTROL PANEL.  
28.14 PROVIDE OUTPUT POWER BOOSTERS AS REQUIRED. COORDINATE WITH MANUFACTURER.  
28.15 ALL FIRE ALARM JUNCTION BOXES SHALL BE PAINTED RED.

|  |  |  |  |
|--|--|--|--|
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |

|     |                   |            |     |
|-----|-------------------|------------|-----|
| 0   | ISSUED FOR PERMIT | 06/18/2025 | DRM |
| NO. | DESCRIPTION       | DATE       | BY  |

REVISIONS

Kirkland Engineering Ltd BCIN: 28857



NOT TO BE USED FOR CONSTRUCTION UNLESS SIGNED BY THE ENGINEER.

THIS DRAWING IS AN INSTRUMENT OF PROFESSIONAL SERVICE FOR USE EXCLUSIVELY ON THIS PROJECT. RE-USE OF ANY PORTION OF THIS DOCUMENT IS PROHIBITED.

Copyright 2025 Kirkland Engineering Ltd



|                                 |      |                |
|---------------------------------|------|----------------|
| PROJECT                         |      |                |
| KINMOUNT FIRE<br>STATION        |      |                |
| 24 Majestic St.<br>Kinmount, ON |      |                |
| TITLE<br>DEMOLITION             |      |                |
| DESIGN                          | DRM  | SCALE AS NOTED |
| DRAWN                           | AJM  | DWG NO.        |
| CHECKED                         | DRM  | E3             |
| APPROVED                        | DRM  |                |
| PROJECT                         | 7529 |                |