

ADDENDUM NO. 2

KOC Dormitory Project

Procurement Name: KOC Dormitory

Procurement Number: KOC07102023

Date Issued: October 7, 2026

This Addendum forms part of the Contract Documents and shall be read, interpreted, and coordinated with all other Contract Documents. Bidders shall acknowledge receipt of this Addendum in their submission.

Where the provisions of this Addendum conflict with previously issued addenda, the provisions of this Addendum shall govern.

Responses provided in this Addendum apply to all bidders.

Revisions to Addendum No. 1

Item 1 - Structural (Q10)

Addendum No. 1, Response A10 is supplemented as follows:

Connection details between the new and existing building are shown on revised Drawing A-08 and shall be used for tendering and construction purposes.

Item 2 - Structural (Q11)

Addendum No. 1, Response A11 is replaced in its entirety with the following:

The lintel at opening D3 shall be comprised of two (2) 2" x 8" members.

Item 3 - Civil & Site Works (Q15)

Addendum No. 1, Response A15 is revised as follows:

Provide 200 mm topsoil in accordance with Drawing C-102. Landscaping shall comply with the Natural Heritage requirements. Native shrubs and trees shall be provided where required by the Natural Heritage requirements. Sod is not required in areas identified for native landscaping.

Item 4 - Mechanical (Q16)

Addendum No. 1, Response A16 is supplemented as follows:

For tendering purposes, bidders shall use the mechanical drawings to determine the required quantity, capacity, and arrangement of fan coil units.

Additional Bidder Question (Q21)

Q21.

The Fan Coil Unit Schedule identifies Trane GAM5B0A48 units with capacities noted as 2.5 ton and 3.5 ton. The scheduled equipment utilizes R410 refrigerant, which is no longer available. Similarly, the Condensing Unit Schedule references model A4AC3030 utilizing R410 refrigerant.

A21.

Bidders may provide units utilizing R454 refrigerant or an approved equivalent refrigerant, provided that the proposed equipment matches the scheduled performance and capacity requirements.

Additional Architectural Clarifications

Clarification No. 1

Refer to revised Drawings A-02, A-02B, A-08 and the revised Site Plan included with this Addendum.

1. Parking Spaces 1 and 2 shall be relocated adjacent to Parking Space 3 as shown on the revised drawings.
2. Provide a compacted granular accessible surface for Barrier-Free Parking Spaces 4 and 5 and for the accessible route connecting these spaces to the building entrance.
3. Provide a one-hour fire separation wall between the dormitory addition and the existing washroom building in accordance with revised Drawing A-02B and associated details. Bidders shall include all labour, materials, equipment, framing, gypsum board assemblies, firestopping, slab modifications, and all associated work necessary to provide the complete one-hour fire separation assembly shown on the revised drawings.
4. Associated revisions to slab construction and building interface details shown on the revised drawings shall be included in the Bid Price.

Revised Drawings Issued with this Addendum

The attached drawings supersede all previously issued versions of the respective drawings.

21-42 KOC-Floor Plan_A-02

21-42 KOC-Floor Plan_A-02B

21-42 KOC_HC-Washroom_Details_Section_A-08

21-42 KOC_Survey & Site Plan-2026-10-06-1-Site Plan

Bidders shall review all revised drawings and incorporate the requirements of this Addendum into their Bid Price.

END OF ADDENDUM NO. 2

All other terms, conditions, specifications, drawings, and requirements of the Contract Documents remain unchanged.

END OF DOCUMENT