Republic of the Philippines
DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
ENVIRONMENTAL MANAGEMENT BUREAU III

ISO 9001 : 2015 ISO 14001 : 2015
CERTIFICATE NO.
SC P0 0054 5QI

Masinop corner Matalino St.
Diosdado Macapagal Government
Center, Brgy. Maimpis, City of
San Fernando, Pampanga, 2000
Tel. Nos. (045) 963-36-23
Email: emb_region3@emb.gov.ph
https://r3.emb.gov.ph

Permit No: PTO-OL-R03-2025-01504-R
Application Type: Renewal

Date Issued: 26 Feb 2025
Date Expiration: 26 Feb 2030

PERMIT TO OPERATE
Air Pollution Source and Control Installations

Pursuant to Part IV, Rule XIX of the Rules and Regulations of R.A. 8749, authority is hereby granted to:

VENTORILLO MANAGEMENT CORPORATION (VENTORILLO MANAGEMENT CORPORATION)

MAC ARTHUR HI-WAY, SAN AGUSTIN, CITY OF SAN FERNANDO (CAPITAL), PAMPANGA

subject to the following terms and conditions:

TERMS AND CONDITIONS

1. This Permit is issued for the permittee to operate installations identified on the Annex of the Permit.
2. During the period of validity, this Bureau may modify this Permit by amending any existing condition or imposing any new or additional condition, subject to provisions of Rule XIX of the Implementing Rules and Regulations (IRRs) of Republic Act No. 8749.
3. An application for renewal of this Permit shall be filed not less than thirty (30) days before the expiry date as indicated in this Permit.
4. The first page of this Permit shall be posted in a conspicuous location at the premises, and shall be adequately framed or otherwise protected against damage.
5. The operation of any installation at this establishment that produces, generates, captures, treats, reduces, controls, emits, releases or disperses air pollutants without a valid Permit to Operate, or violations of all other provisions in this Act and its Implementing Rules and Regulations, shall be subject to penalties of not less than ten thousand (10,000) pesos and not more than one hundred thousand (100,000) pesos, pursuant to Rule LVI of the Implementing Rules and Regulations of RA 8749
6. The installations, processes, or activities at this establishment shall be operated, conducted, and managed by the permittee, and the associated plant and equipment shall be maintained and operated by the permittee so that emissions of air pollutants are kept to a practicable minimum and do not cause air pollution or have adverse effects on a person. The permittee shall be responsible for ensuring that any emissions of air pollutants from the establishment, including fugitive or uncontrolled emissions or releases of air pollutants from abnormal or unexpected events, do not cause air pollution in the surrounding air environment or have adverse effects on persons in that environment.
7. Without limiting the generality of the previous condition, the permittee shall ensure that the emissions from the permitted installations or processes comply with the National Ambient Air Quality Standards for Source-Specific Air Pollutants from Industrial Sources/Operations as specified in Rule XXVI of the IRR of RA 8749.
8. The permittee shall submit quarterly Self-Monitoring Reports (SMR) to this Bureau (thru iis.emb.gov.ph/crs) in accordance with DENR Administrative Order No. 27 (Series of 2003). The deadline for the submission of the SMR shall be fifteen (15) days after the end of each quarter.
9. The permittee shall at all times have an appointed or designated Pollution Control Officer (PCO) who shall be the day-to-day point of contact between the Bureau and the establishment. The permittee shall ensure that the PCO is familiar with the operations and activities are undertaken at the establishment, relevant emission sources, and air pollution control devices and equipment. The permittee shall give the PCO the necessary authority to take or to direct corrective action in the event of a malfunction, accident, breakdown, or other abnormal events that results in excessive

Filing Fee	: Php 600.00	O.R. No. : 8875012	Date : Feb. 24, 2025
Permit Fee	: Php 15000.00	O.R. No. : 8875012	Date : Feb. 24, 2025
PD1856	: Php 10.00	O.R. No. : 8875012	Date : Feb. 24, 2025
Documentary Stamp Tax	: Php 30.00	O.R. No. : 8875012	Date : Feb. 24, 2025

This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

emissions or emissions that do not comply with relevant Permit conditions, emissions standards, or ambient air quality standards.

10. The permittee shall report in writing to the Bureau any malfunction, accident, breakdown, leak, spill, or other abnormal or unexpected events that result in emissions to the atmosphere that do not comply with relevant Permit conditions, emissions standards, or ambient air quality standards, or in any other abnormal or unexpected releases of air pollutants. The report shall indicate the nature of the incident or event, its impact on emissions or releases, remedy any air pollution problems that may have occurred and minimized the probability of reoccurrence of the event or the release.
11. The permittee shall at all times allow authorized officers of the Department or the Bureau entry to the establishment and access to any part of the establishment to conduct inspections, gather information, test emissions, or take samples. The permittee and its personnel shall not obstruct such officers in the performance of these functions and shall furnish any information or materials requested by them that is reasonable for them to have. The permittee shall obey any lawful instruction or direction given by an authorized officer of the Department or the Bureau at all times.
12. The permittee shall not make any alterations or modifications to operations, activities, installations, processes, plant, or equipment at the establishment that might substantially change the nature or quantity of the associated emission without obtaining the approval of this Bureau, including the obtaining of any necessary Permit to Operate.
13. Standby Generator Set regardless of capacity under the following circumstances, shall not be required to conduct source emission testing for permitting and compliance monitoring purposes:
    - Operating not more than 200 hours annually, provided it operates not more than 3 hours per day nor more than three (3) days per week, for light Commercial and Industrial Operation (Hotels, Malls, Banks, Buildings, Schools, Telecommunication towers, Fuel Dispensing Facilities, and Manufacturing Firms among others).
    - During (a) Emergency Hospital Operations; (b) Rescue and Medical Missions related to Natural Calamities; (c) Conflict Areas such as War, Terrorist Attacks, and the like; or (d) All activities affecting National Security.
14. In lieu of source emission testing as a permitting requirement, the applicant shall include in the quarterly Self-Monitoring Reports (SMR) the schedule and duration of preventive maintenance of the Generator Set, and monthly records of power interruption.

Non-compliance with or violation of any provision of RA 8749, its Implementing Rules and Regulation, and/or these Permit conditions, shall be sufficient ground for suspension or revocation of this Permit.

Recommended by:

RALDY R. PAGADOR, ME, DBA
OIC, Clearance and Permitting Division

Approved by:

ENGR. GERI-GERONIMO R. SAÑEZ
OIC-Regional Director

Filing Fee	: Php 600.00	O.R. No. : 8875012	Date : Feb. 24, 2025
Permit Fee	: Php 15000.00	O.R. No. : 8875012	Date : Feb. 24, 2025
PD1856	: Php 10.00	O.R. No. : 8875012	Date : Feb. 24, 2025
Documentary Stamp Tax	: Php 30.00	O.R. No. : 8875012	Date : Feb. 24, 2025

This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

Annex

Fuel Burning					
ID	**APSI**	**Capacity**	**Brand name**	**Type of Fuel**	**APCD**
530498	800KW Caterpillar Generator Set (Standby)	800.0 kw	Caterpillar	Diesel	---
530544	1250KW Caterpillar Generator Set (Standby)	1250.0 kw	Caterpillar	Diesel	---
530545	1360KW Caterpillar Generator Set (Standby)	1360.0 kw	Caterpillar	Diesel	---

Non Fuel Burning					
ID	**APSI**	**Capacity**	**Brand name**	**Material**	**APCD**
538541	Diesel Storage Tank	11000.0 liters			Venti Pipe 1 (0.0 m^3/min)
538542	Diesel Storage Tank	35000.0 liters			Vent Pipe 2 (0.0 m^3/min)
538543	Diesel Storage Tank	35000.0 liters			Vent Pipe 3 (0.0 m^3/min)

APCD-APSI Mapping			
ID	**APCD**	**Connected APSIs (<name> (id))**	**Connected APCDs (<name> (id))**
84646	Venti Pipe 1 (4)	Diesel Storage Tank (4)	---
84648	Vent Pipe 2 (5)	Diesel Storage Tank (5)	---
84649	Vent Pipe 3 (6)	Diesel Storage Tank (6)	---

Filing Fee	: Php 600.00	O.R. No. : 8875012	Date : Feb. 24, 2025
Permit Fee	: Php 15000.00	O.R. No. : 8875012	Date : Feb. 24, 2025
PD1856	: Php 10.00	O.R. No. : 8875012	Date : Feb. 24, 2025
Documentary Stamp Tax	: Php 30.00	O.R. No. : 8875012	Date : Feb. 24, 2025

This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.