Water Service Call Record

Service Record

Customer: Meadowcrest Storage LLC. Claim reference: CLM-26-437673.

Visit: 2026-08-17. Address: 1488 Alder Court, Suite F.

Cause Assessment

A branch connection at the high-level supply route separated over the central aisle. The automatic valve remained open until the operator reached the plant room. The plumber replaced the failed section and held the line under test while the emptied storage rooms were inspected from below.

Work Notes

The service ticket was closed on 2026-08-17 after the connection test. The technician recorded work at the connection and the accessible immediate area. Finish reinstatement was not carried out under this ticket.