Water Service Call Record

Service Record

Customer: Westfield Orthodontics LLC. Claim reference: CLM-26-678338.

Visit: 2026-08-23. Address: 1590 Alder Court, Suite B.

Cause Assessment

The water-heater cold inlet connector split inside the equipment store. Staff found active spray against the lower shelving. The plumber isolated the inlet, replaced the connector and checked pressure on restart. Water had already passed beneath the door into the alcove corridor.

Work Notes

The service ticket was closed on 2026-08-23 after the connection test. The technician recorded work at the connection and the accessible immediate area. Finish reinstatement was not carried out under this ticket.